

Feasibility Study



North of Dryden and Remote Communities Study

Final Report

Issue 1.0

(A study to determine the system enhancements required for different transmission reinforcement options to accommodate new load in the area north of Dryden)

Disclaimer

This document may contain a summary of a particular *market rule*. Where provided, the summary has been used because of the length of the *market rule* itself. The reader should be aware, however, that where a *market rule* is applicable, the obligation that needs to be met is as stated in the “Market Rules”. To the extent of any discrepancy or inconsistency between the provisions of a particular *market rule* and the summary, the provision of the *market rule* shall govern.

Document ID	IESO_REP_0827
Document Name	North of Dryden and Remote Communities Study
Issue	1.0
Reason for Issue	First Release
Effective Date	August 12, 2013

Document Change History

Issue	Reason for Issue	Date
1.0	First Release	August 12, 2013

Table of Contents

Table of Contents..... **i**

List of Figures **iii**

List of Tables..... **iv**

1. Executive Summary **1**

 1.1 Major Findings and Recommendations 2

 1.1.1 230 kV Test Cases.....2

 1.1.2 115 kV Test Cases.....5

2. Introduction **8**

 2.1 Reason for the Study 8

 2.2 Specific Questions Addressed 8

 2.3 Standards and Criteria 8

3. Assumptions and Study Procedure..... **11**

 3.1 Proposed Connection Options 11

 3.2 Study Assumptions 14

 3.2.1 Area Assumptions 14

 3.2.2 New Facility Assumptions 15

 3.3 Load Forecast..... 18

 3.4 Study Scenarios..... 18

 3.5 Relevant Contingencies 19

 3.6 Study Procedure 20

4. 230 kV Test Cases – Findings and Recommendations **21**

 4.1 Pre-Contingency Voltage Stability Margin – Step 1 21

 4.2 Line Energization – Step 2..... 22

 4.3 Device Sizing – Step 3..... 23

 4.4 Post-Contingency Voltage Stability Margin – Step 4..... 25

 4.5 Thermal Loading Assessment 26

 4.6 Voltage Assessment 27

 4.7 Intertie Flows 27

 4.8 Transmission Losses 27

 4.9 Load Sensitivity Analysis at McFaulds..... 28

5. 115 kV Test Cases - Findings and Recommendations.....	32
5.1 Pre-Contingency Voltage Stability Margin – Step 1	32
5.2 Line Energization – Step 2.....	33
5.3 Device Sizing – Step 3.....	34
5.4 Post-Contingency Voltage Stability Margin – Step 4.....	36
5.5 Thermal Loading Assessment	37
5.6 Voltage Assessment	38
5.7 Intertie Flows	38
5.8 Transmission Losses	39
Appendix A: Detailed Diagrams.....	40
Appendix B: 230 kV Test Cases – Thermal Assessment Results.....	46
Appendix C: 230 kV Test Cases - Voltage Assessment Results.....	50
Appendix D: 115 kV Test Cases – Thermal Assessment Results.....	74
Appendix E: 115 kV Test Cases – Voltage Assessment Results	78
References	102

List of Figures

Figure 1: Pickle Lake Supply to Remote Communities under Options 1 or 2	13
Figure 2: Pickle Lake Supply to Remote Communities under Options 3 or 4	13
Figure 3: Existing configuration at Mackenzie TS	17
Figure 4: Proposed configuration at Mackenzie TS	17
Figure 5: Detailed Single Line Diagram – 230 kV Ignace Junction.....	40
Figure 6: Detailed Single Line Diagram – 230 kV Dinorwic Junction.....	41
Figure 7: Detailed Single Line Diagram – 115 kV Valora Junction	42
Figure 8: Detailed Single Line Diagram – 115 kV Dinorwic Junction.....	43
Figure 9: West of Thunder Bay System – 230 kV Test Cases	44
Figure 10: West of Thunder Bay System – 115 kV Test Cases	45

List of Tables

Table 1 : Ear Falls Area System Configurations	1
Table 2: Reactive Compensation Requirements – 230 kV Ignace Jct Test Case 1	2
Table 3: Reactive Compensation Requirements – 230 kV Dinorwic Jct Test Case 2	3
Table 4: Sensitivity – Reactive Compensation Requirements – 230 kV Ignace Jct Test Case 1	3
Table 5: Summary of Transmission Losses West of Marathon for the 230 kV Test Cases	4
Table 6: Reactive Compensation Requirements – 115 kV Valora Jct Test Case 3	5
Table 7: Reactive Compensation Requirements – 115 kV Dinorwic Jct Test Case 4	6
Table 8: Summary of Transmission Losses West of Marathon for the 115 kV Test Cases	7
Table 9: Dependable Water Conditions for Area Hydro Facilities	15
Table 10: Load Forecast	18
Table 11: List of Test Cases	19
Table 12: List of Contingencies	19
Table 13: Pre-Contingency Voltage Stability Reactive Compensation Requirements for the 230 kV Test Cases – Step 1	21
Table 14: Line Energization Test Results for the 230 kV Test Cases – Step 2	22
Table 15: Maximum Switching Step Size for the 230 kV Test Cases	23
Table 16: Reactive Compensation Requirements based on Step Size for the Ignace Junction Test Case – Step 3	24
Table 17: Reactive Compensation Requirements based on Step Size for the Dinorwic Junction Test Case – Step 3	24
Table 18: Final New Reactive Compensation Requirements for the Ignace Junction Test Case – Step 4	25
Table 19: Final New Reactive Compensation Requirements for the Dinorwic Junction Test Case – Step 4	26
Table 20: Additional Intertie Flows following a Double-Circuit Contingency	27
Table 21: Summary of Transmission Losses West of Marathon for the 230 kV Test Cases	28
Table 22: Sensitivity – Reactive Compensation Requirements for the Ignace Junction Test Case – Step 1	28
Table 23: Sensitivity – Line Energization Test Results for the Ignace Junction Test Case – Step 2	29
Table 24: Sensitivity – Summary of Transmission Losses West of Marathon for the Ignace Junction Test Case	29
Table 25: Sensitivity – Reactive Compensation Requirements based on Step Size with 30 MW McFaulds Load – Step 3	30
Table 26: Sensitivity – Final New Reactive Compensation Requirements with 30 MW McFaulds Load – Step 4	31
Table 27: Pre-Contingency Voltage Stability Reactive Compensation Requirements for the 115 kV Test Cases – Step 1	32
Table 28: Line Energization Test Results for the 115 kV Test Cases – Step 2	33
Table 29: Maximum Switching Step Size for the 115 kV Test Cases	34
Table 30: Reactive Compensation Requirements based on Step Size for the Valora Junction Test Case – Step 3	35
Table 31: Reactive Compensation Requirements based on Step Size for the Dinorwic Junction Test Case – Step 3	35

Table 32: Final New Reactive Compensation Requirements for the Valora Junction Test Case – Step 4.....	36
Table 33: Final New Reactive Compensation Requirements for Dinorwic Junction Test Case – Step 4.....	37
Table 34: Limiting Line Segments for Test Cases 3 and 4 for the Loss of D26A.....	37
Table 35: Additional Inertie Flows following a Double-Circuit Contingency.....	38
Table 36: Summary of Transmission Losses West of Marathon for the 115 kV Test Cases	39
Table 37: Thermal Loading for Test Case 1 – Ignace Junction with All Elements in-service – Single-Circuit Contingency.....	46
Table 38: Thermal Loading for Test Case 1 – Ignace Junction with All Elements in-service – Double-Circuit Contingency.....	47
Table 39: Thermal Loading for Test Case 2 – Dinorwic Junction with All Elements in-service – Single-Circuit Contingency.....	48
Table 40: Thermal Loading for Test Case 2 – Dinorwic Junction with All Elements in-service – Double-Circuit Contingency.....	49
Table 41: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Element in-service – Single Circuit Contingency.....	50
Table 42: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Double Circuit Contingency.....	52
Table 43: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions.....	54
Table 44: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions.....	56
Table 45: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Single Circuit Contingency.....	58
Table 46: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Double Circuit Contingency.....	59
Table 47: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions.....	60
Table 48: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions.....	61
Table 49: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency.....	62
Table 50: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency.....	64
Table 51: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions.....	66
Table 52: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions.....	68
Table 53: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency.....	70
Table 54: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency.....	71
Table 55: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions.....	72
Table 56: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions.....	73
Table 57: Thermal Loading for Test Case 3 – Valora Junction with All Elements in-service – Single-Circuit Contingency.....	74
Table 58: Thermal Loading for Test Case 3 – Valora Junction with All Elements in-service – Double-Circuit Contingency.....	75

Table 59: Thermal Loading for Test Case 4 – Dinorwic Junction with All Elements in-service – Single-Circuit Contingency	76
Table 60: Thermal Loading for Test Case 4 – Dinorwic Junction with All Elements in-service – Double-Circuit Contingency	77
Table 61: HV Voltage Assessment for Test Case 3 – Valora Junction with All Element in-service – Single Circuit Contingency	78
Table 62: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Double Circuit Contingency	80
Table 63: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions	82
Table 64: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions	84
Table 65: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Single Circuit Contingency	86
Table 66: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Double Circuit Contingency	87
Table 67: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions	88
Table 68: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service) – Loss of Reactive Devices under Light Load Conditions	89
Table 69: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency	90
Table 70: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency	92
Table 71: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions	94
Table 72: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions	96
Table 73: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency	98
Table 74: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency	99
Table 75: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions	100
Table 76: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions	101

1. Executive Summary

The IESO conducted this Feasibility Study at the Ontario Power Authority (OPA)'s request to investigate four transmission reinforcement options that would increase the supply capability to the North of Dryden area, as well as enable twenty-one First Nations communities to connect to the grid. The results are based on the assumptions listed in Section 3.2, including the dependable water levels under which the OPA requested the study be performed. The test cases are as follows:

1. 230 kV Ignace Junction
 - A new 300 km 230 kV single circuit overhead line to Pickle Lake, tapped off of the Dryden-to-Mackenzie 230 kV circuit D26A at Ignace Junction, to accommodate 190 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in Figure 5 of Appendix A. Ear Falls area configuration assumptions are listed in Table 1.
2. 230 kV Dinorwic Junction
 - A new 300 km 230 kV single circuit overhead line to Pickle Lake, tapped off of D26A at Dinorwic Junction, to accommodate 190 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in Figure 6 of Appendix A. Ear Falls area configuration assumptions are listed in Table 1.
3. 115 kV Valora Junction
 - A new 226 km 115 kV single circuit overhead line to Pickle Lake, tapped off of radial circuit 29M1 at Valora Junction, which is supplied from the Dryden-to-Mackenzie 115 kV circuit M2D, to accommodate 130 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in Figure 7 of Appendix A. Ear Falls area configuration assumptions are listed in Table 1.
4. 115 kV Dinorwic Junction
 - A new 300 km 115 kV single circuit overhead line to Pickle Lake, tapped off of M2D at Dinorwic Junction, to accommodate 130 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in
 - Figure 8 of Appendix A. Ear Falls area configuration assumptions are listed in Table 1.

Table 1 summarizes key Ear Falls Area system configuration assumptions for each test case.

Table 1 : Ear Falls Area System Configurations

Test Case #	Circuit to Pickle Lake	E1C loop	E4D upgrade	E2R upgrade
1	230 kV from Ignace Jct.	Open - Radial out of Pickle Lake with Ear Falls load on E1C	Max-Rated (665 A)	New Parallel circuit
2	230 kV from Dinorwic Jct.	Open – Radial out of Pickle Lake with Ear Falls load on E1C	Max-Rated (665 A)	New Parallel circuit
3	115 kV from Valora Jct.	Open – Radial out of Ear Falls	New Parallel circuit	New Parallel circuit
4	115 kV from Dinorwic Jct.	Open – Radial out of Ear Falls	New Parallel circuit	New Parallel circuit

1.1 Major Findings and Recommendations

The following lists the major findings for each of the test cases based on the study assumptions listed in Section 3.2. This study determined the transmission system enhancements required to accommodate new load, focusing on the impact on the Mackenzie, Dryden, Ear Falls and north of Dryden areas.

1.1.1 230 kV Test Cases

Reactive Compensation Requirements

Table 2 and Table 3 summarize the additional reactive compensation required for the 230 kV test cases.

SVCs are needed at Ear Falls, Mackenzie, Pickle Lake, McFaulds, Esker and Musselwhite to provide fast-acting reactive support to the system. The total reactive compensation of these SVCs is 395/ -135 MVar for test case 1, and 413/ -135 MVar for test case 2.

For all other locations, an auto-switching shunt device will be required. The total reactive compensation of these shunt devices is 100/ -23 MVar for both test cases. Further analysis is needed to determine the required switching speed of the shunt devices, as it is beyond the scope of this study.

The overall reactive compensation requirements are similar for both the Ignace and Dinowic Junction cases. It was observed that as the junction point moves further from Mackenzie (from Ignace to Dinowic), the reactive requirement at Mackenzie increases from 123 MVar to 141 MVar.

Table 2: Reactive Compensation Requirements – 230 kV Ignace Jct Test Case 1

Bus Name	Test Case 1 – 230 kV Ignace Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	65/ -15 MVar		130/ -30 MVar
Dryden	Switched Capacitor	220	1	2	20 MVar	40 MVar
Mackenzie	SVC *	220	1	123 MVar * or 123/ -35 MVar *		123 MVar * or 123/ -35 MVar *
Pickle Lake	SVC	220	2	40/ -35 MVar		80/ -70 MVar
Kingfisher Jct	Switched Reactor	118.05	5	1	-3 MVar	-15 MVar
Neskantaga	Switched Capacitor	118.05	2	3	4 MVar	24 MVar
Webequie	Switched Capacitor	118.05	2	3	3 MVar	18 MVar
	Switched Reactor		1	2	-3 MVar	-6 MVar
McFaulds	SVC	44	1	48 MVar		48 MVar
Esker	SVC	13.8	1	10 MVar		10 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages. Step size is based on the maximum step size at the device's location, while the number of blocks is determined by the maximum permissible reactive compensation behind a single breaker.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

Table 3: Reactive Compensation Requirements – 230 kV Dinorwic Jct Test Case 2

Bus Name	Test Case 2 – 230 kV Dinorwic Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	65/ -15 MVar		130/ -30 MVar
Dryden	Switched Capacitor	220	1	2	20 MVar	40 MVar
Mackenzie	SVC *	220	1	141 MVar * or 141/ -35 MVar *		141 MVar * or 141/ -35 MVar *
Pickle Lake	SVC	220	2	40/ -35 MVar		80/ -70 MVar
Kingfisher Jct	Switched Reactor	118.05	5	1	-3 MVar	-15 MVar
Neskantaga	Switched Capacitor	118.05	2	3	4 MVar	24 MVar
Webequie	Switched Capacitor	118.05	2	3	3 MVar	18 MVar
	Switched Reactor		1	2	-3 MVar	-6 MVar
McFaulds	SVC	44	1	48 MVar		48 MVar
Esker	SVC	13.8	1	10 MVar		10 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages. Step size is based on the maximum step size at the device's location, while the number of blocks is determined by the maximum permissible reactive compensation behind a single breaker.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

Furthermore, as per OPA request, a sensitivity study was performed on test case 1 with the load at McFaulds reduced from 60 MW to 30 MW. Results for the sensitivity are provided in Table 4.

This eliminated the need for reactive compensation at Mackenzie, Dryden and Neskantaga, resulting in a total dynamic reactive requirement of 200/ -112 MVar, and a total static reactive requirement of 18/ -26 MVar.

Table 4: Sensitivity – Reactive Compensation Requirements – 230 kV Ignace Jct Test Case 1

Bus Name	Test Case 1 Sensitivity- 230 kV Ignace Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	65/ -15 MVar		130/ -30 MVar
Pickle Lake	SVC	220	2	18/ -41 MVar		36/ -82 MVar
Kingfisher Jct	Switched Reactor	118.05	6	1	-3 MVar	-18 MVar
Webequie	Switched Reactor	118.05	1	2	-3 MVar	-6 MVar
McFaulds	SVC	44	1	20 MVar		20 MVar
Esker	SVC	13.8	1	10 MVar		10 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages. Step size is based on the maximum step size at the device's location, while the number of blocks is determined by the maximum permissible reactive compensation behind a single breaker.

Thermal Limitations

For both 230 kV test cases, the only thermal limitation observed was on 115 kV Dryden-to-Ear Falls circuit E4D, for the loss of one Manitou Falls unit. This circuit was loaded post-contingency over its LTE and STE rating by approximately 5%. Line upgrades to achieve a LTE rating of about 700 A, or pre-contingency control actions, such as generation re-dispatch if available, are recommended to reduce post-contingency flows to within acceptable limits. Otherwise, pre-contingency load curtailment may have to be implemented during low water conditions.

Local Voltage Limitations

For both test cases, under peak load conditions, the following post-contingency voltage limitations were observed:

- The 115 kV bus voltage at Sapawe DS was above 127 kV following the loss of the Mackenzie-to-Lakehead 230 kV line and subsequent opening of the 115 kV Birch-to-Moose Lake circuit (B6M) at Moose Lake from protection (cross-trip) as listed in one of the assumptions in section 3.2.2. The overvoltage is marginal and can be mitigated through post-contingency control actions (if acceptable to Hydro One) or by installing a small reactor at the station. Alternatively, B6M can be entirely cross-tripped rather than having it open at Moose Lake. A West of Thunder Bay single line diagram is provided in Figure 9 of Appendix A.
- The 230 kV bus voltages at Mackenzie and Lakehead were above 250 kV following the simultaneous loss of D26A and Fort Frances-to-Mackenzie 230 kV circuit F25A, and cross-trip of 115 kV circuit M2D as listed in one of the assumptions in section 3.2.2. To mitigate this overvoltage concern, it is recommended to either install an additional reactor at Mackenzie or to eliminate the contingency from consideration by separating the circuits from common structures shared by D26A and F25A, such that the circuits share at most 4 structures. A West of Thunder Bay single line diagram is provided in Figure 9 of Appendix A.

Transmission Losses

Table 5 summarizes the impact that adding up to 190 MW of load has on transmission losses in the region west of Marathon. For test case 1, the active power losses west of Marathon increased by 76.8 MW, from 35 MW to 111.8 MW, while the reactive power losses increased by 454.9 MVar, from 192 MVar to 646.9 MVar. These losses are slightly higher in test case 2 as the junction points moves further from Mackenzie. If the McFaulds load reduces from 60 MW to 30 MW, the active power losses west of Marathon are reduced from 111.8 MW to 76.3 MW, and the reactive power losses are reduced from 646.9 MVar to 466.6 MVar.

Table 5: Summary of Transmission Losses West of Marathon for the 230 kV Test Cases

Case	Active Power Losses	Reactive Power Losses	Total New Load	Δ MW losses/ Δ load (%)
Reference Case - Base Case with no new load	35 MW	192 MVar	0 MW	N/A
Test Case 1 - 230 kV Ignace Junction	111.8 MW	646.9 MVar	190 MW	40%
Test Case 2 - 230 kV Dinorwic Junction	117.2 MW	676.4 MVar	190 MW	43%
Sensitivity - 230 kV Ignace Junction with 30 MW McFaulds Load	76.3MW	466.6 MVar	160 MW	26%

1.1.2 115 kV Test Cases

Reactive Compensation Requirements

Tables 6 and 7 summarize the additional reactive compensation required for the 115 kV test cases.

SVCs are needed at Ear Falls, Mackenzie, Pickle Lake, Esker, Musselwhite and Valora Junction (for test case 3) to provide fast-acting reactive support to the system. The total reactive compensation of these SVCs is 265/ -119 MVar for test case 3, and 222/ -129 for test case 4.

For all other locations, an auto-switching shunt device is required. The total reactive compensation of these shunt devices is 27/ -33 MVar for test case 3, and 137/ -33 MVar for test case 4. Further analysis is needed to determine the required switching speed of these devices, as it is beyond the scope of this study.

The overall reactive requirement for the Dinorwic Junction case is higher than that of the Valora Junction case. This is primarily due to the fact that reactive support for the Valora case was directly connected at the junction since there is an existing station, Valora DS. Whereas in the Dinorwic Junction case, it was assumed that since there is no existing station at the junction, reactive support would need to be supplied from neighboring stations, ultimately increasing the requirement.

Table 6: Reactive Compensation Requirements – 115 kV Valora Jct Test Case 3

Bus Name	Test Case 3 – 115 kV Valora Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	33/ -22 MVar		66/ -44 MVar
Mackenzie	SVC *	220	1	85 MVar * or 85/ -35 MVar *		85 MVar * or 85/ -35 MVar *
Pickle Lake	SVC	118.05	2	11/ -20 MVar		22/ -40 MVar
Kingfisher Jct	Switched Reactor	118.05	11	1	-2 MVar	-22 MVar
Valora Jct	SVC	118.05	2	38 MVar		76 MVar
Thierry Mine	Switched Reactor	118.05	1	3	-3 MVar	-9 MVar
	Switched Capacitor	4.16	1	3	3 MVar	9 MVar
Esker	SVC	13.8	1	12 MVar		12 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages. Step size is based on the maximum step size at the device's location, while the number of blocks is determined by the maximum permissible reactive compensation behind a single breaker.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

Table 7: Reactive Compensation Requirements – 115 kV Dinorwic Jct Test Case 4

Bus Name	Test Case 4 – 115 kV Dinorwic Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	33/ -22 MVar		66/ -44 MVar
Dryden	Switched Capacitor	220	1	3	25 MVar	75 MVar
Mackenzie	SVC *	220	1	100 MVar * or 100/ -35 MVar *		100 MVar * or 100/ -35 MVar *
Pickle Lake	SVC	118.05	2	20/ -25 MVar		40/ -50 MVar
Kingfisher Jct	Switched Reactor	118.05	11	1	-2 MVar	-22 MVar
Valora Jct	Switched Capacitor	118.05	1	5	7 MVar	35 MVar
Thierry Mine	Switched Reactor	118.05	1	3	-3 MVar	-9 MVar
	Switched Capacitor	4.16	1	3	3 MVar	9 MVar
Esker	SVC	13.8	1	12 MVar		12 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages. Step size is based on the maximum step size at the device's location, while the number of blocks is determined by the maximum permissible reactive compensation behind a single breaker.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

Thermal Limitations

Valora Junction – Test Case 3

The following thermal limitations were observed:

- The line section between Ignace Junction and Ignace DS Junction on 29M1 was overloaded by 44% of its continuous rating pre-contingency. In addition, this section was overloaded by 20% of its LTE rating for the loss of D26A. It is recommended to upgrade this line section to achieve a continuous rating of 462 A and a LTE rating of 479 A.
- The line section between Moose Lake and Ignace Junction on M2D was overloaded by 24% of its LTE rating for the loss of D26A. It is recommended to upgrade this line section to achieve a LTE rating of 680 A.

Dinorwic Junction – Test Case 4

The following post-contingency thermal limitations were observed for the loss of D26A:

- The line section between Moose Lake and Ignace Junction on M2D was overloaded by 7% of its LTE rating. It is recommended to upgrade this section to achieve a LTE rating of 590 A.
- The line section between Ignace Junction and Dryden on M2D was overloaded by 33% of its LTE rating. It is recommended to upgrade this section to achieve a LTE rating of 557 A.

Local Voltage Limitations

The only voltage limitations observed for both cases was for the loss of D26A + F25A followed by the cross-tripping of M2D as listed in one of the assumptions in section 3.2.2, resulting in the 230 kV bus voltages at Mackenzie and Lakehead to be above 250 kV. To mitigate this overvoltage concern, it is recommended to either install an additional reactor at Mackenzie or to eliminate the contingency from consideration by separating common structures such that the circuits share at most 4 structures.

Transmission Losses

Table 8 summarizes the impact that the new load of 130 MW has on transmission losses in the region west of Marathon. For test case 3, the active power losses west of Marathon increased by 56.6 MW, from 35 MW to 91.6 MW, while the the reactive power losses increased by 296.3 MVar from 192 MVar to 488.3 MVar. The active power losses are slightly higher in test case 3 as the resulting path to Pickle Lake has a higher resistance than in test case 4. However, the reactive power losses are higher in test case 4 as the overall impedance to Pickle Lake is higher than in test case 3.

Table 8: Summary of Transmission Losses West of Marathon for the 115 kV Test Cases

Case	Active Power Losses	Reactive Power Losses	Total New Load	Δ MW losses/ Δ load (%)
Reference Case: Summer 2011 Base Case	35 MW	192 MVar	0 MW	N/A
Test Case 3 - 115 kV Valora Junction	91.6 MW	488.3 MVar	130 MW	44%
Test Case 4 - 115 kV Dinorwic Junction	82.7 MW	508.7 MVar	130 MW	37%

– End of Section –

2. Introduction

2.1 Reason for the Study

The IESO conducted this Feasibility Study at the OPA's request to investigate four transmission reinforcement cases that would increase the supply capability to the North of Dryden area, as well as enable twenty-one First Nations communities to connect to the grid.

2.2 Specific Questions Addressed

This assessment was performed to determine the transmission system enhancements required to accommodate new load, focusing on the impact in the Mackenzie, Dryden, Ear Falls and north of Dryden areas. In each of the proposed options, the technical studies determined the system reinforcements needed to address the following:

- Thermal loading and voltage levels
- Voltage change
- Steady state voltage stability
- Reactive element switching
- Location, size and type of reactive compensation devices

2.3 Standards and Criteria

The assessment in this study was based on the Ontario Resource and Transmission Assessment Criteria (ORTAC) document. A new Bulk Electricity System definition is currently under development by NERC which will likely result in the Northwest System being re-classified from a local area to being part of the bulk power system. However, the current local area classification of the Northwest was assumed for the study with the understanding that reinforcements for full compliance of the NERC TPL-001-2 standards associated with bulk power system definition would be dealt with in a separate study.

The specific criteria used for this study are listed below:

- Section 4.2: Pre-contingency voltage limits and Section 4.3: Voltage change limits
 - Pre-contingency voltages on the 230 kV nominal voltage buses should be within 220 - 250 kV, and on the 115 kV nominal voltage buses should be within 113 - 132 kV.
 - Post-contingency voltage change limits on the 230 kV and 115 kV nominal voltage buses should not exceed 10% before and after tap action post-contingency. Voltages on the 230 kV nominal voltage buses should be within 207 - 250 kV, and on the 115 kV nominal voltage buses should be within 108 - 132 kV.

- Section 4.3.1: Reactive Element Switching Change
 - Reactive devices should be sized to ensure that voltage declines or rises at delivery point buses on switching operations will not exceed 4% of the steady state rms voltage before tap changer action using a voltage dependent load model.
- Section 4.3.2: Capacitive Element Switching Change
 - Capacitive devices should be sized to ensure that voltage declines or rises at delivery point buses on switching operations will not exceed 4% of the steady state rms voltage for line switching operations per Chapter 4 of the Market Rules. This 4% is based on load flows before tap changer action using a voltage dependent load model.
- Section 4.5.1: Power-Voltage (P-V) curves
 - The maximum acceptable pre-contingency power transfer must be the lesser of:
 - a pre-contingency power transfer that is 10% lower than the voltage instability point of the pre-contingency P-V curve (pre-contingency switching of capacitor banks to improve the limit is allowed), and
 - a pre-contingency transfer that results in a post-contingency power flow that is 5% lower than the voltage instability point of the pre-contingency curve. (Post-contingency switching of capacitor banks is not permitted)
- Section 4.7.2: Loading Criteria
 - All line and equipment loads shall be within their continuous ratings with all elements in service and within their long-term emergency ratings with any one element out of service. Immediately following contingencies, lines may be loaded up to their short-term emergency ratings where control actions such as re-dispatch, switching, etc. are available to reduce the loading to the long-term emergency rating (within a maximum of 15-minutes).
- Section 7.1: Load security criteria
 - The *transmission system* must be planned to satisfy *demand* levels up to the extreme weather, median-economic forecast for an extended period with any one transmission element out of service. The *transmission system* must exhibit acceptable performance, as described below, following the design criteria contingencies defined in sections 2.7.1 and 2.7.2. For the purposes of this section, an element is comprised of a single zone of protection.
 - With all transmission *facilities* in service, equipment loading must be within continuous ratings, voltages must be within normal ranges and transfers must be within applicable normal condition stability limits. This must be satisfied coincident with an outage to the largest local generation unit.
 - With any one element out of service, equipment loading must be within applicable long-term *emergency* ratings, voltages must be within applicable *emergency* ranges, and transfers must be within applicable normal condition stability limits. Planned load *curtailment* or load rejection, excluding voluntary *demand* management, is permissible only to account for local generation outages. Not more than 150 MW of load may be interrupted by configuration and by planned load *curtailment* or load rejection, excluding voluntary *demand* management.
 - With any two elements out of service, voltages must be within applicable *emergency* ranges, equipment loading must be within applicable short-term *emergency* ratings and transfers must be within applicable *emergency* condition stability limits. Equipment loading must be reduced to the applicable long-term *emergency* ratings in the time afforded by the short-time ratings. Planned load *curtailment* or load rejection

exceeding 150 MW is permissible only to account for local generation outages. Not more than 600 MW of load may be interrupted by configuration and by planned load *curtailment* or load rejection, excluding voluntary *demand* management.

– End of Section –

3. Assumptions and Study Procedure

3.1 Proposed Connection Options

The following connection options were prepared for evaluation to increase the supply capability of the transmission system north of Dryden to Pickle Lake:

1. 230 kV Ignace Junction
 - A new 300 km 230 kV single circuit overhead line to Pickle Lake, tapped off of the Dryden-to-Mackenzie 230 kV circuit D26A, at Ignace Junction, to accommodate 190 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in Figure 5 of Appendix A.
2. 230 kV Dinorwic Junction
 - A new 300 km 230 kV single circuit overhead line to Pickle Lake, tapped off of D26A at Dinorwic Junction, to accommodate 190 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in Figure 6 of Appendix A.
3. 115 kV Valora Junction
 - A new 226 km 115 kV single circuit overhead line to Pickle Lake, tapped off of radial circuit 29M1 at Valora Junction, which is supplied from the Dryden-to-Mackenzie 115 kV circuit M2D, to accommodate 130 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in Figure 7 of Appendix A.
4. 115 kV Dinorwic Junction
 - A new 300 km 115 kV single circuit overhead line to Pickle Lake, tapped off of M2D at Dinorwic Junction, to accommodate 130 MW of new load. The load distribution is presented in Table 10 of Section 3.3, and the single line diagram is presented in
 - Figure 8 of Appendix A.

In addition to system upgrades 1 to 4 above, the study also considers:

- A new 115 kV single circuit overhead line from Ear Falls to Red Lake in parallel with E2R (parallel circuit) to support the load growth and Remote Communities in the Red Lake area.
- Upgrading the existing 115 kV E4D circuit from Dryden to Ear Falls to max-rated (665 A) in options 1 and 2.
- Installing a new 115 kV single circuit overhead line from Dryden to Ear Falls in parallel with E4D (parallel circuit), and having similar characteristics with E4D in option 3 and 4.

The following 115 kV circuits and transformer stations were proposed to connect the Remote Communities north of Red Lake and Pickle Lake. The proposed load to be supplied at each station is presented in Table 10 of section 3.3.

Red Lake Line:

- Pikangikum TS, connecting the Pikangikum and Poplar Hill communities
- Deer Lake TS, connecting the Deer Lake and North Spirit Lake communities
- Sandy Lake TS, connecting the Sandy Lake and Kee-Way-Win communities

Pickle Lake:

- Muskrat Dam Line:
 - North Caribou Lake TS, connecting the North Caribou Lake community
 - Muskrat Dam TS, connecting the Bearskin Lake, Sachigo Lake and Muskrat Dam communities
- Big Trout Line:
 - Kingfisher Lake TS, connecting the Kingfisher Lake community (and the Wunnumin Lake community for options 1 and 2)
 - Wapekeka TS, connecting the Big Trout Lake, Wapekeka, Kasabonika Lake and Wawakapewin communities
- Webequie Line:
 - Wunnumin Lake TS, connecting the Wunnumin Lake community in for options 3 and 4
 - Nibinamik TS, connecting the Nibinamik (Summer Beaver) and Webequie communities for options 3 and 4
- Ebanes Line:
 - Neskantaga TS, connecting the Neskantaga (Lansdowne House) and Eabametoong (Fort Hope) communities
 - Webequie TS, connecting the Nibinamik (Summer Beaver) and Webequie communities in options 1 and 2. In addition, if Pickle Lake option 1 or 2 is considered, the new mining loads at the Ring of Fire (McFaulds) would be supplied by extending the Ebanes line past Webequie.

Figure 1 and Figure 2 illustrate the supply configuration from Pickle Lake to the Remote Communities for connection options 1-4.




Figure 1: Pickle Lake Supply to Remote Communities under Options 1 or 2




Figure 2: Pickle Lake Supply to Remote Communities under Options 3 or 4

3.2 Study Assumptions

3.2.1 Area Assumptions

Steady state and voltage analysis simulations were performed using PSS/E base cases. A summer 2011 scenario including all existing and committed projects was used to develop the study scenarios with the following assumptions:

- Hydro-electric generation at drought levels. Table 9 lists the dependable water conditions for Hydro-electric stations in the area under which the OPA requested the study be performed.
- Load levels corresponding to the connection year (2016-2019), 2020 and 2031 provided by the OPA for both peak and light load conditions.
- No imports from Manitoba and Minnesota.
- The East-West Transfer West (E-W-TR-W) upgrades as per the feasibility study: *An Assessment of the Westward Transfer Capability of Various Options for Reinforcing the East-West Tie*.
- Atikokan TGS out of service.
- Balmer, Esker and Thierry Mine in-service.
- All proposed 115 kV circuits had line characteristics equivalent to that of a 477 kcmil ACSR conductor, with the exception of the new 115 kV single circuit overhead line from Dinorwic Junction in option 4, which had line characteristics equivalent to that of a 795 kcmil ACSR conductor. All proposed 230 kV circuits had line characteristics equivalent to that of a 795 kcmil ACSR conductor, as per OPA's instructions.
- The 115 kV/LV transformers at McFaulds were assumed to be similar to the existing Red Lake transformers. Other 115 kV/LV transformers were assumed to be similar to the existing Crow River transformer for loads greater than 3 MVA, or the Slate Falls transformer for loads smaller than 3 MVA. The Pickle Lake 230/115 kV autotransformer was assumed to be similar to the existing Lakehead autotransformers.
- The thermal line ratings in the north of the Dryden area were verified through the Hydro One database, and were assumed to be at 30 °C ambient temperature at 4 km/hr wind velocity. The new line ratings were provided by the OPA.
- The load power factor is assumed to be 0.95 at the LV busbar so to comply with the Market Rule of 0.90 at the defined meter point at the HV Busbar.
- For steady state and voltage assessment, the loads are modeled as constant megavolt-ampere (MVA).

Table 9: Dependable Water Conditions for Area Hydro Facilities

98 % Dependable Water - Summer	
Hydro Unit	Generation (MW)
Lac Seul	0
Ear Falls (G1)	3
Ear Falls (G2)	0
Ear Falls (G3)	0
Ear Falls (G4)	0
Manitou Falls (G1)	9.3
Manitou Falls (G2)	0
Manitou Falls (G3)	0
Manitou Falls (G4)	0
Manitou Falls (G5)	0
White Dog (G1)	12.4
White Dog (G2)	0
White Dog (G3)	0
Caribou Falls (G1)	19.8
Caribou Falls (G2)	0

3.2.2 New Facility Assumptions

The following study assumptions were made regarding the availability and design of future facilities:

- Load Rejection (LR) schemes were assumed to be implemented for all the test cases to address any potential E2R (and parallel circuit) or E4D (and parallel circuit) overload issues following the loss of their companion circuit. Based on simulation results, the loss of one E4D circuit would result in the need to reject approximately 70 MW of load in the Red Lake Area. Similarly, the loss of one E2R circuit would result in the need to reject up to 60 MW of load in the Red Lake Area.
- Special Protection Scheme (SPS) were available to reject load with any two major elements out of service.
- An auto-tripping scheme for Lakehead capacitor SC11 was in place when Lakehead 230 kV bus voltage exceeds 250 kV. Studies have shown that the Lakehead 230 kV bus voltage could exceed 250 kV while the Lakehead 115 kV bus voltage is below 125.5 kV, which would not trigger the current auto-tripping scheme for Lakehead SC11.
- It was assumed that the loss of shunt devices connected at load stations (McFaulds, Esker, Musselwhite, Red Lake, Balmer, Sandy Lake, Thierry Mine) would also result in the loss of the associated load.
- The maximum continuous voltage for the 115 kV system that connects to new transmission areas was assumed to be 132 kV. The maximum continuous voltages for existing stations was based on the ORTAC and the 115 kV Bus Voltages System Control Order (SCO).

- The post-contingency SPS and auto-switching action happened before the ULTC actions.
- For the LR in the 230 kV test cases, the Pickle Lake load could be rejected by tripping the new 230 kV single circuit overhead line from Ignace or Dinorwic Junction to Pickle Lake using a single breaker at the tap point. The line could also be left radial given that the Pickle Lake SVC would regulate the 230 kV voltage to 230 kV as a part of the SPS scheme.
- For the LR in the 115 kV test cases, the Pickle Lake load could be rejected by tripping the new 115 kV single circuit overhead line from Valora or Dinorwic Junction to Pickle Lake using a single breaker at the tap point. The line could also be left radial given that the Pickle Lake SVC would regulate the 115 kV voltage to 120 kV for the Valora configuration and 117 kV for the Dinorwic configuration to neutralize the charging on the line.
- Circuits E2R and M3E are currently terminating at the same terminal at Ear Falls. It was assumed for the purpose of this study that the station would be upgraded such that each line would have its own terminal.
- It was assumed that circuit B6M would be opened at Moose Lake for the double-circuit contingency on A21L and A22L to avoid overloads on circuit B6M.
- It was assumed that circuit M2D would be cross-tripped for the double-circuit contingency on D26A and F25A to avoid overloads on circuit M2D.
- It was assumed that an auto-switching scheme for Fort Frances capacitors SC1 and SC2 is in place when Fort Frances 115 kV bus voltage reaches 112 kV.
- A single breaker configuration was assumed at Ignace and Dinorwic Junction.
- Reconfiguration of Mackenzie was assumed to be in place. Under the current station configuration at Mackenzie, as shown in Figure 3, the loss of double-circuit contingency A21L and A22L would split the Mackenzie 230 kV bus. In order to avoid this bus splitting at Mackenzie, which results in worse post-contingency voltages, a new station configuration was assumed by adding a new diameter between the P and H buses as shown in Figure 4. Circuits A21L and D26A were placed on the new diameter, with circuit F25A and the new Mackenzie SVC on the other diameter to prevent the possibility of losing D26A and the Mackenzie SVC for a breaker failure.




Figure 3: Existing configuration at Mackenzie TS




Figure 4: Proposed configuration at Mackenzie TS

3.3 Load Forecast

The load forecast in Table 10 was provided by the OPA and used in the simulation studies. The minimum loading level was determined based on the type of load:

- Minimum industrial loads (Balmer, Thierry Mine and Musselwhite) were assumed to be 85% of their peak load.
- Minimum non-industrial loads (Ear Falls, Cat Lake, Slate Falls, Crow River and Perrault Falls) were assumed to be 30% of their peak.
- At Red Lake, 8 MW of the peak load was assumed to be retail/commercial and the rest industrial load.

Table 10: Load Forecast

Existing Stations	Minimum Load (MW)		Peak Load (MW)	
	Options 1 or 2	Options 3 or 4	Options 1 or 2	Options 3 or 4
Ear Falls TS	1.02	1.02	3.4	3.4
Red Lake TS	52.55	52.55	67	67
Balmer TS	38.25	38.25	45	45
Cat Lake CTS	0.3	0.3	1	1
Slate Falls CTS	0.36	0.36	1.2	1.2
Thierry Mine	7.65	7.65	9	9
Crow River DS	1.32	1.32	4.4	4.4
Musselwhite CSS	34	34	40	40
Perrault Falls TS	0.18	0.18	0.6	0.6
New Stations				
North Caribou Lake	0.338	0.338	2.192	2.192
Muskrat Dam TS	0.671	0.671	4.345	4.345
Kingfisher Lake TS	0.465	0.188	2.785	1.126
Wapekeka TS	1.075	1.075	6.437	6.437
Wunnumin Lake TS	N/A	0.649	N/A	1.659
Nibinamik TS	N/A	0.383	N/A	2.387
Neskantaga TS	0.552	0.552	3.865	3.865
Webequie TS	0.354	N/A	2.387	N/A
Pikangikum TS	0.726	0.726	4.894	4.894
Deer Lake TS	0.279	0.279	3.033	3.033
Sandy Lake TS	1.07	1.07	6.929	6.929
McFaulds TS	36	N/A	60	N/A

3.4 Study Scenarios

The initial base cases were developed based on the connection options presented in Section 3.1, the study assumptions in Section 3.2, and the load forecast in Section 3.3 of this report. Different study test cases were developed based on different operations of the 115 kV circuit E1C and the upgrade of the 115 kV circuit E4D. The following table shows the test cases that were prepared for this study.

Table 11: List of Test Cases

Test Case #	Circuit to Pickle Lake	E1C loop	E4D upgrade	E2R upgrade
1	230 kV from Ignace Jct.	Open - Radial out of Pickle Lake with Ear Falls load on E1C	Max-Rated (665 A)	New Parallel circuit
2	230 kV from Dinorwic Jct.	Open – Radial out of Pickle Lake with Ear Falls load on E1C	Max-Rated (665 A)	New Parallel circuit
3	115 kV from Valora Jct.	Open – Radial out of Ear Falls	New Parallel circuit	New Parallel circuit
4	115 kV from Dinorwic Jct.	Open – Radial out of Ear Falls	New Parallel circuit	New Parallel circuit

3.5 Relevant Contingencies

A detailed representation of the existing and proposed system in the north of Dryden area, for both the 115 kV and 230 kV configurations, is presented in Appendix A. The contingencies considered for the studies were:

- Any area single element contingency; and
- The simultaneous loss of two 230 kV circuits mounted on a common transmission tower or pole west of Lakehead. The East of Lakehead area was assumed to be addressed by the East-West Tie reinforcement feasibility study.

The following table summarizes the key single and double element contingencies that were assessed for each test case.

Table 12: List of Contingencies

Single Element Contingencies
A21L or A22L
D26A
F25A
K23D
1 Manitou Falls unit
1 Shunt reactive device
Double Element Contingencies
A21L & A22L – Isolation on to Manitoba assuming B6M is opened at Moose Lake (cross-tripped)
D26A & F25A – Isolation on to Manitoba assuming M2D is cross-tripped

3.6 Study Procedure

For each test case, base cases were developed for both peak and light load conditions. The location and size of the reactive compensation devices for each test case was determined under the following load scenarios to satisfy the criteria listed in section 2.3.

- **Peak Load Conditions:** Voltage stability analysis was performed to ensure the required margins from the voltage instability point were at least 10% pre-contingency and 5% post-contingency. This test determined the reactive compensation required to ensure sufficient margin from the voltage collapse point.
- **Zero Load Conditions.** Line energization tests were performed with all existing elements in-service using the following procedure:
 - 1) Connect a new transmission line with no load.
 - 2) Supply 25% of the minimum load on this transmission line.
 - 3) Repeat step 1 for a different transmission line.

The order in which the transmission lines were energized was varied to determine the largest reactive compensation required. This test determined the reactive compensation to manage high voltages.

Equipment loading and voltage levels were assessed with all elements in-service and following the contingencies presented in Table 12 to determine the feasibility of each test case with the reinforcements determined above. This test determined additional reinforcements required to meet the thermal loading and voltage level criteria.

In addition, the switching of reactive elements was tested under light load conditions to determine the largest acceptable step size to be switched.

– End of Section

4. 230 kV Test Cases – Findings and Recommendations

4.1 Pre-Contingency Voltage Stability Margin – Step 1

Section 4.5.1 of the ORTAC indicates that there must be sufficient margin from the voltage instability point such that the maximum pre-contingency transfer is the lesser of:

- a pre-contingency power transfer that is 10% lower than the voltage instability point of the pre-contingency P-V curve, and
- a pre-contingency transfer that results in a post-contingency power flow that is 5% lower than the voltage instability point of the pre-contingency curve

In addition, Section 7.1 of the ORTAC indicates that with any one element out of service:

- transfers must be within applicable normal condition stability limits. Not more than 150 MW of load may be interrupted by configuration and by planned load *curtailment* or load rejection for local generation outages.

To determine the amount of reactive compensation required to supply the new load north of Dryden with the required stability margin when a transmission element is on an outage, voltage stability analysis was performed at a load level 10% higher than forecast. The most limiting element out of service was determined to be 230 kV circuit A21L.

The results of this test are summarized in Table 13 below.

Table 13: Pre-Contingency Voltage Stability Reactive Compensation Requirements for the 230 kV Test Cases – Step 1

Bus Name	Test Case 1 - Ignace Junction	Test Case 2 – Dinorwic Junction
	Voltage Stability (+10% Load Pre-Contingency)	Voltage Stability (+10% Load Pre-Contingency)
	Compensation Required at Base Voltage (MVar)	Compensation Required at Base Voltage (MVar)
Ear Falls 115 kV	91	94
Dryden 230 kV	38	39
Mackenzie 230 kV	123	141
Mackenzie LV	0	0
Pickle Lake 230 kV	78	76
Kingfisher Jct 115 kV	0	0
Neskantaga 115 kV	19	19
Webequie 115 kV	17	17
McFaulds LV	48	48
Esker LV	15 (5 Existing)	15 (5 Existing)
Musselwhite LV	18 (14 Existing)	18 (14 Existing)
Red Lake LV	20 (26.5 Existing)	20 (26.5 Existing)
Balmer LV	15	16
Deer Lake 115 kV	0	0
Sandy Lake LV	2	2
Total	484	505

From Table 13, it can be seen that a total reactive compensation of 484 MVar is required for test case 1, and 505 MVar for test case 2. The table lists the total requirement at each station with the value of any existing shunt devices in brackets.

The largest reactive compensation requirement is located at the Mackenzie 230 kV bus. This is expected with A21L out of service, since it leaves only 230 kV circuit A22L and 115 kV circuit B6M supplying the west of Mackenzie load. It should be noted that as the junction point moves further from Mackenzie from Ignace to Dinorwic, the reactive requirement at Mackenzie increases.

The reactive compensation at Ear Falls is required primarily to support the forecasted load growth and Remote Communities in the Red Lake Area.

4.2 Line Energization – Step 2

To ensure that bus voltages do not exceed their maximum allowable levels, as specified in the Section 4.2 of ORTAC and the 115 kV Bus Voltages SCO, energization tests were performed to identify the amount of reactive compensation needed to control the voltages below their maximum continuous limits. The study results are provided in Table 14 below.

Table 14: Line Energization Test Results for the 230 kV Test Cases – Step 2

Bus Name	Test Case 1 - Ignace Junction	Test Case 2 – Dinorwic Junction
	Energization Test	Energization Test
	Compensation Required at Base Voltage (MVar)	Compensation Required at Base Voltage (MVar)
Ear Falls 115 kV	-30	-30
Dryden 230 kV	0	0
Mackenzie 230 kV	0	0
Mackenzie LV	-40 (Existing)	-40 (Existing)
Pickle Lake 230 kV	-64	-64
Kingfisher Jct 115 kV	-12	-12
Neskantaga 115 kV	0	0
Webequie 115 kV	-6	-6
McFaulds LV	0	0
Esker LV	0	0
Musselwhite LV	0	0
Red Lake LV	0	0
Balmer LV	0	0
Deer Lake 115 kV	-2	-2
Sandy Lake LV	0	0
Total	-154	-154

In both 230 kV test cases, a total reactive compensation requirement of -154 MVar was identified for energization. The results show that reactive compensation is needed at:

- Pickle Lake, Kingfisher and Webequie buses to energize the area north of Dryden.
- Ear Falls and Deer Lake buses to energize the area north of Red Lake.

4.3 Device Sizing – Step 3

A switching test was performed for each shunt device identified in Sections 4.1 and 4.2 to determine the maximum step size that can be switched without causing a voltage deviation larger than 4%, as specified in the switching change requirement in Sections 4.3.1 and 4.3.2 of ORTAC. The maximum step size for each location is given in Table 15.

Table 15: Maximum Switching Step Size for the 230 kV Test Cases

Bus Name	Test Case 1 - Ignace Junction		Test Case 2 – Dinorwic Junction	
	Maximum Step Size for Switching		Maximum Step Size for Switching	
	Step Size (MVar)	Base Voltage (kV)	Step Size (MVar)	Base Voltage (kV)
Ear Falls 115 kV	11	118.05	11	118.05
Dryden 230 kV	30	220	30	220
Mackenzie 230 kV	36.5	220	36.5	220
Mackenzie LV	32	13.8	32	13.8
Pickle Lake 230 kV	8.5	220	8.5	220
Kingfisher Jct 115 kV	3.5	118.05	3.5	118.05
Neskantaga 115 kV	4.5	118.05	4.5	118.05
Webequie 115 kV	3.5	118.05	3.5	118.05
McFaulds LV	3	44.	3	44
Esker LV	3.5	13.8	3.5	13.8
Musselwhite LV	3	4.16	3	4.16
Red Lake LV	7	44.	7	44
Balmer LV	8	44	8	44
Deer Lake 115 kV	3	118.05	3	118.05
Sandy Lake LV	1.5	27.6	1.5	27.6

Based on the maximum step size and the total reactive compensation required at each location as determined in steps 1 and 2, the number of steps for shunt devices was calculated. These results are listed in Tables 16 and 17 for test cases 1 and 2 respectively.

Table 16: Reactive Compensation Requirements based on Step Size for the Ignace Junction Test Case – Step 3

Bus Name	Capacitor			Reactor		
	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)
Ear Falls 115 kV	9	10	90	3	-10	-30
Dryden 230 kV	2	20	40	0	0	0
Mackenzie 230 kV	4	31	124	0	0	0
Mackenzie LV	0	0	0	2	-20	-40 (Existing)
Pickle Lake 230 kV	10	8	80	8	-8	-64
Kingfisher Jct 115 kV	0	0	0	4	-3	-12
Neskantaga 115 kV	5	4	20	0	0	0
Webequie 115 kV	6	3	18	2	-3	-6
McFaulds LV	16	3	48	0	0	0
Esker LV	5	3	15 (5 Existing)	0	0	0
Musselwhite LV	6	3	18 (14 Existing)	0	0	0
Red Lake LV	3	7	21 (26.5 Existing)	0	0	0
Balmer LV	2	8	16	0	0	0
Deer Lake 115 kV	0	0	0	1	-2	-2
Sandy Lake LV	2	1	2	0	0	0
Total			492			-154

Table 17: Reactive Compensation Requirements based on Step Size for the Dinorwic Junction Test Case – Step 3

Bus Name	Capacitor			Reactor		
	# of Steps	Step Size (Mvar)	Reactive Requirements (MVar)	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)
Ear Falls 115 kV	10	9.5	95	3	-10	-30
Dryden 230 kV	2	20	40	0	0	0
Mackenzie 230 kV	4	35	140	0	0	0
Mackenzie LV	0	0	0	2	-20	-40 (Existing)
Pickle Lake 230 kV	10	8	80	8	-8	-64
Kingfisher Jct 115 kV	0	0	0	4	-3	-12
Neskantaga 115 kV	5	4	20	0	0	0
Webequie 115 kV	6	3	18	2	-3	-6
McFaulds LV	16	3	48	0	0	0
Esker LV	5	3	15 (5 Existing)	0	0	0
Musselwhite LV	6	3	18 (14 Existing)	0	0	0
Red Lake LV	3	7	21 (26.5 Existing)	0	0	0
Balmer LV	2	8	16	0	0	0
Deer Lake 115 kV	0	0	0	1	-2	-2
Sandy Lake LV	2	1	2	0	0	0
Total			513			-154

The shunt devices at Ear Falls, Mackenzie, Pickle Lake and McFaulds require a large number of steps, it is more practical to install SVC instead of switch devices, and they would also provide fast-acting

reactive support to the system and limit the amount of shunt devices at a single location. Therefore, SVCs are strongly recommended for these locations.

The existing size of the SVCs at Esker and Musselwhite will need to be increased to 15 MVar and 18 MVar, respectively. For the remaining locations, auto-switching shunt devices will be required. Further analysis is required to determine the switching speed of the shunt devices as it is beyond the scope of this study.

4.4 Post-Contingency Voltage Stability Margin – Step 4

To ensure that there is a sufficient voltage stability margin in response to the loss of each shunt device, a voltage stability test was performed at a load level 5% higher to determine if the capacitive devices require splitting. Similarly, a test was performed to determine if the splitting of reactors is required to ensure that all maximum voltages are respected for the loss of each inductive device.

Based on the simulation results for both test cases, it was found that a minimum of 65 MVar is required at Ear Falls to avoid voltage instability, therefore two SVCs, each with a capability of +65/ -15 MVar, are required.

Similarly, the Pickle Lake SVC will need to be split into two separate SVCs, each with a capability of +40/ -35 MVar. In addition, the switched capacitors at Neskantaga and Webequie will also need to be split into two blocks. The switched reactor at Kingfisher could not be split, therefore an additional step of -3 MVar is required. Tables 18 and 19 summarize the new reactive compensation requirements for test cases 1 and 2, respectively.

Table 18: Final New Reactive Compensation Requirements for the Ignace Junction Test Case – Step 4

Bus Name	230 kV Test Case 1 - Ignace Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	65/ -15 MVar		130/ -30 MVar
Dryden	Switched Capacitor	220	1	2	20 MVar	40 MVar
Mackenzie	SVC *	220	1	123 MVar * or 123/ -35 MVar *		123 MVar * or 123/ -35 MVar *
Pickle Lake	SVC	220	2	40/ -35 MVar		80/ -70 MVar
Kingfisher Jct	Switched Reactor	118.05	5	1	-3 MVar	-15 MVar
Neskantaga	Switched Capacitor	118.05	2	3	4 MVar	24 MVar
Webequie	Switched Capacitor Switched Reactor	118.05	2 1	3 2	3 MVar -3 MVar	18 MVar -6 MVar
McFaulds	SVC	44	1	48 MVar		48 MVar
Esker	SVC	13.8	1	10 MVar		10 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All shunt devices are assumed to be auto-switching based on controlled bus voltages.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

Table 19: Final New Reactive Compensation Requirements for the Dinorwic Junction Test Case – Step 4

Bus Name	230 kV Test Case 2 - Dinorwic Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	65/ -15 MVar		130/ -30 MVar
Dryden	Switched Capacitor	220	1	2	20 MVar	40 MVar
Mackenzie	SVC *	220	1	141 MVar * or 141/ -35 MVar *		141 MVar * or 141/ -35 MVar *
Pickle Lake	SVC	220	2	40/ -35 MVar		80/ -70 MVar
Kingfisher Jct	Switched Reactor	118.05	5	1	-3 MVar	-15 MVar
Neskantaga	Switched Capacitor	118.05	2	3	4 MVar	24 MVar
Webequie	Switched Capacitor Switched Reactor	118.05	2 1	3 2	3 MVar -3 MVar	18 MVar -6 MVar
McFaulds	SVC	44	1	48 MVar		48 MVar
Esker	SVC	13.8	1	10 MVar		10 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All shunt devices are assumed to be auto-switching based on controlled bus voltages.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

4.5 Thermal Loading Assessment

Section 4.7.2 of ORTAC requires that elements be loaded within their continuous ratings with all elements in-service, and within their long-term emergency ratings with any one element out of service. Equipment loading was assessed with all elements in-service under peak load conditions and following a relevant contingency as listed in Table 12. The results for the thermal assessment are presented in detail in Appendix B for test cases 1 and 2.

Pre-contingency loadings on all monitored line sections were within their continuous ratings for both test cases 1 and 2.

The loss of one Manitou Falls unit under the assumed conditions resulted in E4D loaded at approximately 105% of its STE ratings. As the LTE and STE ratings for this circuit are identical, line upgrades to achieve a LTE rating of about 700 A or pre-contingency control actions, such as generation re-dispatch if available, could be used to reduce post-contingency flows within acceptable limits. Otherwise, pre-contingency load curtailment may have to be implemented during low water conditions.

Although transformer loading results were not included in this report, there were no thermal limitations on all key transformers monitored in the area.

4.6 Voltage Assessment

Sections 4.2 and 4.3 of ORTAC set the maximum and minimum acceptable system voltages under pre-contingency conditions with all elements in-service, as well as the permissible voltage change limits following a contingency. Voltage assessment was performed with all elements in-service under peak and light load conditions following a relevant contingency listed in Table 12. The detailed results for the voltage assessment are presented in Appendix C for test cases 1 and 2.

Voltages were within their acceptable pre-contingency ranges, under peak or light load conditions, for both test cases 1 and 2.

In both test cases, the 115 kV bus voltages at Sapawe DS was above 127 kV for the loss of A21L + A22L and the subsequent opening of B6M at Moose Lake. This overvoltage occurs largely because, following the opening of B6M at Moose Lake, the station is located at the end of a lightly loaded line. The concern can be mitigated by installing a small reactor at the bus or by removing the 115 kV Birch capacitor post-contingency. Alternatively, B6M could be entirely cross-tripped rather than opening it at Moose Lake.

In addition, the 230 kV bus voltages at Mackenzie and Lakehead were above 250 kV for the loss of D26A + F25A and the subsequent cross-trip of M2D. To mitigate this overvoltage concern, it is recommended to either install an additional reactor at Mackenzie or to eliminate the contingency from consideration by separating the circuits from common structures such that the circuits share at most 4 structures.

4.7 Intertie Flows

The pre-contingency intertie flows on the Ontario-to-Manitoba and Ontario-to-Minnesota interfaces were assumed to be zero. The loss of A21L + A22L with B6M cross-tripped or D26A + F25A with M2D cross-tripped, results in a system separation, leaving Ontario load connected radially to the Northwest interties circuits (K21W, K22W and F3M). Table 20 shows the resulting intertie flows following the system separation contingencies for test cases 1 and 2. All intertie circuits were well within their thermal capability.

Table 20: Additional Intertie Flows following a Double-Circuit Contingency

Contingency	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line		Loss of AxLs and Cross-Trip B6M + E2R Lines		Loss of D26A + F25A and Cross-Trip M2D	
	Flow In (MW)		Flow In (MW)		Flow In (MW)	
	Test Case 1	Test Case 2	Test Case 1	Test Case 2	Test Case 1	Test Case 2
F3M	74	78	88	89	78	78
K21W	69	66	78	77	77	77
K22W	69	66	78	77	77	77

4.8 Transmission Losses

Table 21 summarizes the impact that the new load has on transmission losses. This table lists the total active and reactive power losses on all circuits in the region west of Marathon before the additional load and for test cases 1 and 2. In both 230 kV test cases, the total load added to the system was 190 MW. For test case 1, the active power losses increased by 76.8 MW, from 35 MW to 111.8 MW, while the reactive

power losses increased by 454.9 MVar, from 192 MVar to 646.9 MVar. These losses are slightly higher in test case 2 as the junction point moves further west with supply coming from the east.

Table 21: Summary of Transmission Losses West of Marathon for the 230 kV Test Cases

Case	Active Power Losses	Reactive Power Losses	Total New Load	Δ MW losses/ Δ load (%)
Reference Case - Base Case with no new load	35 MW	192 MVar	0 MW	N/A
Test Case 1 - 230 kV Ignace Junction	111.8 MW	646.9 MVar	190 MW	40%
Test Case 2 - 230 kV Dinorwic Junction	117.2 MW	676.4 MVar	190 MW	43%

4.9 Load Sensitivity Analysis at McFaulds

A sensitivity study, as per OPA request, was conducted for the 230 kV Ignace test case to determine the amount of reactive compensation needed when the load at McFaulds is reduced from 60 MW to 30 MW. This sensitivity analysis focused on voltage stability and line energization, and did not include thermal and voltage assessments. The study results are presented in Tables 22 and 23 below.

Table 22: Sensitivity – Reactive Compensation Requirements for the Ignace Junction Test Case – Step 1

Bus Name	60 MW McFaulds Load	30 MW McFaulds Load
	Voltage Stability (+10% Load Pre-Contingency)	Voltage Stability (+10% Load Pre-Contingency)
	Compensation Required at Base Voltage (MVar)	Compensation Required at Base Voltage (MVar)
Ear Falls 115 kV	91	91
Dryden 230 kV	38	0
Mackenzie 230	123	0
Mackenzie LV	0	0
Pickle Lake 230	78	35
Kingfisher Jct 115	0	0
Neskantaga 115	19	0
Webequie 115 kV	17	0
McFaulds LV	48	20
Esker LV	15 (5 Existing)	15 (5 Existing)
Musselwhite LV	18 (14 Existing)	18 (14 Existing)
Red Lake LV	20 (26.5 Existing)	20 (26.5 Existing)
Balmer LV	15	15
Deer Lake 115 kV	0	0
Sandy Lake LV	2	2
Total	484	216

Table 23: Sensitivity – Line Energization Test Results for the Ignace Junction Test Case – Step 2

Bus Name	60 MW McFaulds Load	30 MW McFaulds Load
	Energization Test	Energization Test
	Compensation Required at Base Voltage (MVar)	Compensation Required at Base Voltage (MVar)
Ear Falls 115 kV	-30	-30
Dryden 230 kV	0	0
Mackenzie 230 kV	0	0
Mackenzie LV	-40 (Existing)	-40 (Existing)
Pickle Lake 230 kV	-64	-72
Kingfisher Jct 115	-12	-15
Neskantaga 115 kV	0	0
Webequie 115 kV	-6	-6
McFaulds LV	0	0
Esker LV	0	0
Musselwhite LV	0	0
Red Lake LV	0	0
Balmer LV	0	0
Deer Lake 115 kV	-2	-2
Sandy Lake LV	0	0
Total	-154	-165

When the load level at McFaulds is 30 MW, the total capacitive requirement is reduced from 484 MVar to 216 MVar, and the total inductive requirement for energization is increased slightly from 154 MVar to 165 MVar.

Reactive support at Mackenzie, Dryden and Neskantaga is no longer required as the load reduction at McFaulds, which is located at the end of a long 115 kV transmission line, greatly reduces the transmission line losses within the area.

Table 24 summarizes the active and reactive power losses as well as the total new load in the area west of Marathon for the two load levels considered at McFaulds. The active power losses decreased from 118.8 MW to 76.3 MW and reactive power losses decreased from 646.9 MVar to 466.6 MVar.

Table 24: Sensitivity – Summary of Transmission Losses West of Marathon for the Ignace Junction Test Case

Case	Active Power Losses	Reactive Power Losses	Total New Load	Δ MW losses/ Δ load (%)
Reference Case - Base Case with no new load	35 MW	192 MVar	0 MW	N/A
Test Case 1 – 230 kV Ignace Junction with 60 MW McFaulds Load	111.8 MW	646.9 MVar	190 MW	40%
Sensitivity – 230 kV Ignace Junction with 30 MW McFaulds Load	76.3MW	466.6 MVar	160 MW	26%

The reactive compensation requirements for each location, with the maximum step size and the number of steps, are presented in Table 25. SVCs were assumed at Ear Falls, Pickle Lake and McFaulds due to a large number of steps.

Similar to the test case 1 with 60 MW of McFaulds Load, the device size of existing SVCs at Esker and Musselwhite will need to be increased to 15 MVar and 18 MVar, respectively. For the other locations, an auto-switching device will be required. A more detailed analysis is recommended to determine the device type that should be installed at those locations.

Table 25: Sensitivity – Reactive Compensation Requirements based on Step Size with 30 MW McFaulds Load – Step 3

Bus Name	Capacitor			Reactor		
	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)
Ear Falls 115 kV	9	10	90	3	-10	-30
Dryden 230 kV	0	0	0	0	0	0
Mackenzie 230 kV	0	0	0	0	0	0
Mackenzie LV	0	0	0	2	-20	-40 (Existing)
Pickle Lake 230 kV	5	7	35	9	-8	-72
Kingfisher Jct 115 kV	0	0	0	5	-3	-15
Neskantaga 115 kV	0	0	0	0	0	0
Webequie 115 kV	0	0	0	2	-3	-6
McFaulds LV	7	3	21	0	0	0
Esker LV	5	3	15 (5 Existing)	0	0	0
Musselwhite LV	6	3	18 (14 Existing)	0	0	0
Red Lake LV	3	7	21 (26.5 Existing)	0	0	0
Balmer LV	2	8	16	0	0	0
Deer Lake 115 kV	0	0	0	1	-2	-2
Sandy Lake LV	2	1	2	0	0	0
Total			218			-165

In order to determine the need for the splitting of shunt devices, tests were performed to ensure that there is sufficient voltage stability margin for the loss of each capacitive device, and also to ensure that all bus voltages are below the maximum voltages for the loss of a reactor.

It was found that a minimum of 65 MVar is required at Ear Falls to avoid voltage instability. Therefore two SVCs, each with a capability of +65/ -15 MVar, are required. The Pickle Lake SVC will need to be split into two separate SVCs, each with a capability of +18/ -41 MVar. The switched reactor at Kingfisher could not be split, therefore an additional step of -3 MVar is required. Table 26 summarizes the new reactive compensation requirements for the Ignace Junction test case with 30 MW load at McFaulds.

Table 26: Sensitivity – Final New Reactive Compensation Requirements with 30 MW McFaulds Load – Step 4

Bus Name	230 kV Test Case 1 - Ignace Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	65/ -15 MVar		130/ -30 MVar
Pickle Lake	SVC	220	2	18/ -41 MVar		36/ -82 MVar
Kingfisher Jct	Switched Reactor	118.05	6	1	-3 MVar	-18 MVar
Webequie	Switched Reactor	118.05	1	2	-3 MVar	-6 MVar
McFaulds	SVC	44	1	20 MVar		20 MVar
Esker	SVC	13.8	1	10 MVar		10 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All shunt devices are assumed to be auto-switching based on controlled bus voltages.

– End of Section –

5. 115 kV Test Cases - Findings and Recommendations

5.1 Pre-Contingency Voltage Stability Margin – Step 1

As previously mentioned in section 4.1, the ORTAC requires a 10% margin from the voltage stability point during normal conditions, which applies with an element out of service pre-contingency.

To determine the amount of reactive compensation required to supply the new load north of Dryden with the required stability margin when a transmission element is on an outage, voltage stability analysis was performed at a load level 10% higher than forecast. The most limiting element out of service was determined to be 230 kV circuit D26A.

The results of this test are summarized in Table 27 below.

Table 27: Pre-Contingency Voltage Stability Reactive Compensation Requirements for the 115 kV Test Cases – Step 1

Bus Name	Test Case 3 - Valora Junction	Test Case 4 – Dinorwic Junction
	Voltage Stability (+10% Load Pre-Contingency)	Voltage Stability (+10% Load Pre-Contingency)
	Compensation Required at Base Voltage (MVar)	Compensation Required at Base Voltage (MVar)
Ear Falls 115 kV	65	65
Dryden 230 kV	0	73
Mackenzie 230 kV	85	100
Mackenzie LV	0	0
Pickle Lake 115 kV	21	39
Kingfisher Jct 115 kV	-9	-9
Valora Jct 115 kV	75	33
Thierry Mine 115 kV	0	0
Thierry Mine LV	7	7
Esker LV	17 (5 Existing)	17 (5 Existing)
Musselwhite 115 kV	0	0
Musselwhite LV	18 (14 Existing)	18 (14 Existing)
Red Lake LV	19 (26.5 Existing)	19 (26.5 Existing)
Balmer LV	15	15
Deer Lake 115 kV	0	0
Sandy Lake LV	2	2
Total	324/ -9	388/ -9

The total reactive compensation required for test case 3 is 324 MVar, with 388 MVar required for test case 4. Both cases required a -9 MVar reactor at Kingfisher Junction to ensure that voltages do not exceed their maximum permissible levels. The values in Table 27 represent the total requirement at each station, with the value of any existing shunt devices in brackets.

For test cases 3 and 4, the largest reactive compensation requirement is located at the Mackenzie 230 kV bus since it is the main supply point for new load when transfers are from east to west.

It can be observed that more reactive compensation is required for test case 4 than for test case 3. This is primarily due to the fact that reactive support for the Valora case was directly connected at the junction due to the presence of an existing station, Valora DS. Whereas in the Dinorwic Junction case, it was assumed that since there is no existing station at the junction, reactive support would need to be supplied from neighboring stations, ultimately increasing the requirement.

The reactive compensation at Ear Falls is required to support the forecasted load growth and Remote Communities in the Red Lake Area.

5.2 Line Energization – Step 2

To ensure that bus voltages do not exceed their maximum allowable levels, as specified in the Section 4.2 of ORTAC and the 115 kV Bus Voltages SCO, energization tests were performed to identify the amount of reactive compensation needed to control the voltages below their maximum continuous limits. The study results are provided in the following table.

Table 28: Line Energization Test Results for the 115 kV Test Cases – Step 2

Bus Name	Test Case 3 – Valora Junction	Test Case 4 – Dinorwic Junction
	Energization Test	Energization Test
	Compensation Required at Base Voltage (MVar)	Compensation Required at Base Voltage (MVar)
Ear Falls 115 kV	-43	-44
Dryden 230 kV	0	0
Mackenzie 230 kV	0	0
Mackenzie LV	-40 (Existing)	-40 (Existing)
Pickle Lake 115 kV	-34	-34
Kingfisher Jct 115 kV	-18	-19
Valora Jct 115 kV	0	0
Thierry Mine 115 kV	-8	-8
Thierry Mine LV	0	0
Esker LV	0	0.0
Musselwhite 115 kV	-6 (-13 Existing)	-6 (-13 Existing)
Musselwhite LV	0	0
Red Lake LV	0	0
Balmer LV	0	0
Deer Lake 115 kV	-2	-2
Sandy Lake LV	0	0
Total	-151	-153

For both 115 kV test cases, a total reactive compensation of approximately -150 MVar is required for energization. The results show that reactive compensation is required at:

- Pickle Lake and Kingfisher to energize the area north of Dryden.
- Ear Falls and Deer Lake to energize the area north of Red Lake.
- Thierry Mine to energize E1C.

5.3 Device Sizing – Step 3

A switching test was performed for each shunt device identified in the Sections 5.1 and 5.2 to determine the maximum step size that can be switched without causing a voltage deviation larger than 4%, as specified in the switching change requirement in sections 4.3.1 and 4.3.2 of ORTAC. The maximum step size of each device is given in Table 29.

Table 29: Maximum Switching Step Size for the 115 kV Test Cases

Bus Name	Test Case 3 - Valora Junction		Test Case 4 – Dinorwic Junction	
	Maximum Step Size for Switching		Maximum Step Size for Switching	
	Step Size (MVar)	Base Voltage (kV)	Step Size (MVar)	Base Voltage (kV)
Ear Falls 115 kV	15	118.05	15	118.05
Dryden 230 kV	30	220	30	220
Mackenzie 230 kV	35	220	35	220
Mackenzie LV	30	13.8	30	13.8
Pickle Lake 115 kV	3.5	118.05	3.5	118.05
Kingfisher Jct 115 kV	2	118.05	2	118.05
Valora Jct 115 kV	8	118.05	7.5	118.05
Thierry Mine 115 kV	3	118.05	3	118.05
Thierry Mine LV	3	4.16	3	4.16
Esker LV	3.5	13.8	3	13.8
Musselwhite 115 kV	3.5	118.05	3.5	118.05
Musselwhite LV	4	4.16	4	4.16
Red Lake LV	8.5	44	8.5	44
Balmer LV	10	44	10	44
Deer Lake 115 kV	3.5	118.05	3.5	118.05
Sandy Lake LV	1.5	27.6	1.5	27.6

Based on the maximum step size and the total reactive compensation required at each location as determined in steps 1 and 2, the number of steps for shunt devices was calculated. These results are listed in Table 30 and Table 31 for test cases 3 and 4, respectively.

Table 30: Reactive Compensation Requirements based on Step Size for the Valora Junction Test Case – Step 3

Bus Name	Capacitor			Reactor		
	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)
Ear Falls 115 kV	5	13	65	3	-15	-45
Dryden 230 kV	0	0	0	0	0	0
Mackenzie 230 kV	3	30	90	0	0	0
Mackenzie LV	0	0	0	2	-20	-40 (Existing)
Pickle Lake 115 kV	6	3.5	21	10	-3.5	-35
Kingfisher Jct 115 kV	0	0	0	10	-2	-20
Valora Jct 115 kV	10	7.5	75	0	0	0
Thierry Mine 115 kV	0	0	0	3	-3	-9
Thierry Mine LV	3	3	9	0	0	0
Esker LV	6	3	18 (5 Existing)	0	0	0
Musselwhite 115 kV	0	0	0	2	-3	-6 (-13 Existing)
Musselwhite LV	5	4	20 (14 Existing)	0	0	0
Red Lake LV	3	7	21 (26.5 Existing)	0	0	0
Balmer LV	2	8	16	0	0	0
Deer Lake 115 kV	0	0	0	1	-2	-2
Sandy Lake LV	2	1	2	0	0	0
Total			337			-157

Table 31: Reactive Compensation Requirements based on Step Size for the Dinorwic Junction Test Case – Step 3

Bus Name	Capacitor			Reactor		
	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)	# of Steps	Step Size (MVar)	Reactive Requirements (MVar)
Ear Falls 115 kV	5	13	65	3	-15	-45
Dryden 230 kV	3	25	75	0	0	0
Mackenzie 230 kV	3	33	99	0	0	0
Mackenzie LV	0	0	0	2	-20	-40 (Existing)
Pickle Lake 115 kV	12	3.5	42	10	-3.5	-35
Kingfisher Jct 115 kV	0	0	0	10	-2	-20
Valora 115 kV	5	7	35	0	0	0
Thierry Mine 115 kV	0	0	0	3	-3	-9
Thierry Mine LV	3	3	9	0	0	0
Esker LV	6	3	18 (5 Existing)	0	0	0
Musselwhite 115 kV	0	0	0	2	-3	-6 (-13 Existing)
Musselwhite LV	5	4	20 (14 Existing)	0	0	0
Red Lake LV	3	7	21 (26.5 Existing)	0	0	0
Balmer LV	2	8	16	0	0	0
Deer Lake 115 kV	0	0	0	1	-2	-2
Sandy Lake LV	2	1	2	0	0	0
Total			402			-157

The shunt devices at Ear Falls, Mackenzie, Pickle Lake and Valora Junction (for test case 3) require a large number of steps, it is more practical to install SVC instead of switch devices, and they would also provide fast-acting reactive support to the system and limit the amount of shunt devices at a single location. Therefore, SVCs are strongly recommended for these locations.

The existing size of the SVCs at Esker and Musselwhite will need to be increased to 17 MVar and 18 MVar, respectively. For the remaining locations, auto-switching shunt devices will be required. Further analysis is required to determine the switching speed of the shunt devices as it is beyond the scope of this study.

5.4 Post-Contingency Voltage Stability Margin – Step 4

To ensure that there is a sufficient voltage stability margin in response to the loss of each shunt device, a voltage stability test was performed at a load level 5% higher to determine if the capacitive devices require splitting. Similarly, a test was performed to determine if the splitting of reactors is required to ensure that all maximum voltages are respected for the loss of each inductive device.

Based on the simulation results, it was found that the SVCs at Ear Falls and Pickle Lake for both test cases, and the SVC at Valora Junction for test case 3, need to be split into two separate SVCs. The reactor at Kingfisher could not be split, therefore an additional step of -2 MVar is required. Tables 32 and 33 summarize the new reactive compensation requirements for test cases 3 and 4, respectively.

Table 32: Final New Reactive Compensation Requirements for the Valora Junction Test Case – Step 4

Bus Name	Test Case 3 - Valora Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	33/ -22 MVar		66/ -44 MVar
Mackenzie	SVC *	220	1	85 MVar * or 85/ -35 MVar *		85 MVar * or 85/ -35 MVar *
Pickle Lake	SVC	118.05	2	11/ -20 MVar		22/ -40 MVar
Kingfisher Jct	Switched Reactor	118.05	11	1	-2 MVar	-22 MVar
Valora Jct	SVC	118.05	2	38 MVar		76 MVar
Thierry Mine	Switched Reactor/ Switched Capacitor	118.05	1	3	-3 MVar	-9 MVar
		4.16	1	3	3 MVar	9 MVar
Esker	SVC	13.8	1	12 MVar		12 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable

Table 33: Final New Reactive Compensation Requirements for Dinorwic Junction Test Case – Step 4

Bus Name	Case 4 – Dinorwic Junction					
	Recommended Device Type	Base Voltage (kV)	# of Blocks or SVCs	# of Steps per Block or SVC Range	Step Size	Total Compensation
Ear Falls	SVC	118.05	2	33/ -22 MVar		66/ -44 MVar
Dryden	Switched Capacitor	220	1	3	25 MVar	75 MVar
Mackenzie	SVC *	220	1	100 MVar * or 100/ -35 MVar *		100 MVar * or 100/ -35 MVar *
Pickle Lake	SVC	118.05	2	20/ -25 MVar		40/ -50 MVar
Kingfisher Jct	Switched Reactor	118.05	11	1	-2 MVar	-22 MVar
Valora Jct	Switched Capacitor	118.05	1	5	7 MVar	35 MVar
Thierry Mine	Switched Reactor/ Switched Capacitor	118.05	1	3	-3 MVar	-9 MVar
		4.16	1	3	3 MVar	9 MVar
Esker	SVC	13.8	1	12 MVar		12 MVar
Musselwhite	SVC	4.16	1	4 MVar		4 MVar
Balmer	Switched Capacitor	44	1	2	8 MVar	16 MVar
Deer Lake	Switched Reactor	118.05	1	1	-2 MVar	-2 MVar
Sandy Lake	Switched Capacitor	27.6	1	2	1 MVar	2 MVar

Note: All fixed shunt devices are assumed to be auto-switching based on controlled bus voltages.

* If the existing Mackenzie reactor is kept, an SVC with only positive range will be required. If the reactor is not kept, then an SVC with both a positive and negative range will be required. Further studies are recommended to determine which Mackenzie SVC configuration is more desirable.

5.5 Thermal Loading Assessment

Section 4.7.2 of ORTAC requires that elements be loaded within their continuous ratings with all elements in-service, and within their long-term emergency ratings with any one element out of service. Equipment loading was assessed with all elements in-service under peak load conditions and following a relevant contingency as listed in Table 12. The results for the thermal assessment are presented in detail in Appendix D for test cases 3 and 4.

The only pre-contingency thermal limitation was on the line section between Ignace Junction and Ignace DS Junction, for test case 3, with the line loaded at 144% of its continuous rating. Since this line section has a length of 1.1 km, it is recommended to upgrade this line section to achieve continuous rating of 462 A.

Post-contingency thermal limitations were observed for the loss of D26A. Table 34 lists the limiting line sections for this contingency.

Table 34: Limiting Line Segments for Test Cases 3 and 4 for the Loss of D26A

Test Case #	Circuit	Line Section	Circuit Loading (A)	% of LTE Rating
3	29M1	Ignace Junction to Ignace DS Junction	479	119.75
	M2D	Moose Lake to Ignace Junction	680	123.64
4	M2D	Moose Lake to Ignace Junction	590	107.27
	M2D	Ignace Junction to Dryden	557	132.62

The line section between Ignace Junction and Ignace DS Junction was overloaded by 20% of its LTE rating post-contingency. This line section should at least be upgraded to achieve a LTE rating of 479 A.

The line section between Moose Lake and Ignace Junction on M2D was overloaded by 24% and 7% of its LTE rating for the loss of D26A for test cases 3 and 4, respectively. It is recommended to upgrade this line section to achieve their LTE rating of 680 A for test case 3 and 590 A for test case 4.

The line section between Ignace Junction and Dryden on M2D was overloaded by 33% of its LTE rating. It is recommended to upgrade this section to achieve a LTE rating of 557 A.

Although transformer loading results are not included in this report, there are no thermal limitations on all the key transformers monitored in the area.

5.6 Voltage Assessment

Sections 4.2 and 4.3 of ORTAC set the maximum and minimum acceptable system voltages under pre-contingency conditions with all elements in-service, as well as the permissible voltage change limits following a contingency. Voltage assessment was performed with all elements in-service under peak and light load conditions following a relevant contingency listed in Table 12. The detailed results for the voltage assessment are presented in Appendix E for test cases 3 and 4.

Voltages were within their acceptable pre-contingency ranges, under peak or light load conditions, for both test cases 3 and 4.

The 230 kV bus voltages at Mackenzie and Lakehead were above 250 kV for the loss of D26A + F25A and the subsequent cross-trip of M2D. To mitigate this overvoltage concern, it is recommended to either install an additional reactor at Mackenzie or to eliminate the contingency from consideration by separating the circuits from common structures such that the circuits share at most 4 towers.

5.7 Intertie Flows

The pre-contingency intertie flows on the Ontario-to-Manitoba and Ontario-to-Minnesota interfaces were assumed to be zero. The loss of A21L + A22L with B6M cross-tripped or D26A + F25A with B6M cross-tripped, results in a system separation, leaving Ontario load connected radially to the Northwest interties circuits (K21W, K22W and F3M). Table 35 shows the resulting intertie flows following the system separation contingencies for cases 3 and 4. All intertie circuits were well within their thermal capability.

Table 35: Additional Intertie Flows following a Double-Circuit Contingency

Contingency	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line		Loss of AxLs and Cross-Trip B6M + E2R Lines		Loss of D26A + F25A and Cross- Trip M2D	
	Flow In (MW)		Flow In (MW)		Flow In (MW)	
	Test Case 3	Test Case 4	Test Case 3	Test Case 4	Test Case 3	Test Case 4
F3M	92	90	76	70	91	90
K21W	83	84	66	63	90	90
K22W	83	84	66	63	90	90

5.8 Transmission Losses

Table 36 summarizes the impact that the new load has on transmission losses. This table lists the total active and reactive power losses on all circuits in the region west of Marathon before the additional load and for test cases 3 and 4. In both 115 kV test cases, the total load added to the system is 130 MW. For test case 3, the active power losses increased by 56.6 MW, from 35 MW to 91.6 MW, and the reactive power losses increased by 296.3 MVar, from 192 MVar to 488.3 MVar. The active power losses are slightly higher in test case 3 as the resulting path to Pickle Lake has a higher resistance than in test case 4. However, the reactive power losses are higher in test case 4 as the overall impedance to Pickle Lake is higher than in test case 3.

Table 36: Summary of Transmission Losses West of Marathon for the 115 kV Test Cases

Case	Active Power Losses	Reactive Power Losses	Total New Load	Δ MW losses/ Δ load (%)
Reference Case: Summer 2011 Base Case	35 MW	192 MVar	0 MW	N/A
Test Case 3 - 115 kV Valora Junction	91.6 MW	488.3 MVar	130 MW	44%
Test Case 4 - 115 kV Dinorwic Junction	82.7 MW	508.7 MVar	130 MW	37%

– End of Section –

Appendix A: Detailed Diagrams

1. 230 kV Ignace Junction:




Figure 5: Detailed Single Line Diagram – 230 kV Ignace Junction

2. 230 kV Dinorwic Junction:




Figure 6: Detailed Single Line Diagram – 230 kV Dinorwic Junction

3. 115 kV Valora Junction:




Figure 7: Detailed Single Line Diagram – 115 kV Valora Junction

4. 115 kV Dinorwic Junction:




Figure 8: Detailed Single Line Diagram – 115 kV Dinorwic Junction

5. West of Thunder Bay System Overview – 230 kV Test Cases:




Figure 9: West of Thunder Bay System – 230 kV Test Cases

6. West of Thunder Bay System Overview – 115 kV Test Cases:




Figure 10: West of Thunder Bay System – 115 kV Test Cases

– End of Section –

Appendix B: 230 kV Test Cases – Thermal Assessment Results

Table 37: Thermal Loading for Test Case 1 – Ignace Junction with All Elements in-service – Single-Circuit Contingency

Circuit Name	Length (KM)	CONT Rating	LTE Rating	STE Rating	Pre-Cont		Loss of A21L		Loss of D26A		Loss of F25A		Loss of K23D		Loss of 1 Manitou Falls Unit	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	% LTE	(A)	% LTE	(A)	% LTE
B6M BixMU	14.5	440	440	450	238	54.09	385	87.50	179	40.68	237	53.86	244	55.45	242	55.00
B6M MUxST	7.9	430	430	430	195	45.35	341	79.30	136	31.63	193	44.88	201	46.74	198	46.05
B6M STxSH	33.5	470	470	470	194	41.28	340	72.34	134	28.51	192	40.85	200	42.55	197	41.91
B6M SHxIN	18.5	470	470	470	188	40.00	334	71.06	129	27.45	186	39.57	194	41.28	191	40.64
B6M INxKA	32.5	460	460	460	186	40.43	331	71.96	126	27.39	184	40.00	192	41.74	189	41.09
B6M KAxSA	58.9	430	430	430	186	43.26	331	76.98	126	29.30	184	42.79	192	44.65	189	43.95
B6M SAxCA	22.6	620	740	770	181	29.19	323	43.65	122	16.49	180	24.32	187	25.27	184	24.86
B6M CAxML	0.5	620	740	770	181	29.19	323	43.65	122	16.49	180	24.32	187	25.27	184	24.86
M2D MLxIG	76.7	550	550	550	275	50.00	279	50.73	388	70.55	357	64.91	293	53.27	281	51.09
M2D IGxDR	80.4	420	420	420	250	59.52	255	60.71	366	87.14	334	79.52	270	64.29	257	61.19
29M1 IGxIG	1.1	320	400	460	21	6.56	21	5.25	20	5.00	20	5.00	21	5.25	21	5.25
29M1 IGxCL	18	500	500	500	17	3.40	17	3.40	17	3.40	17	3.40	17	3.40	17	3.40
29M1 CLxVA	51	500	500	500	15	3.00	15	3.00	15	3.00	15	3.00	15	3.00	15	3.00
E4D DRxSL	68.2	665	665	665	638	95.94	638	95.94	643	96.69	643	96.69	642	96.54	697	104.81
E4D SLxEF	30.2	665	665	665	629	94.59	628	94.44	633	95.19	633	95.19	633	95.19	688	103.46
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	297	70.71	298	70.95	298	70.95	298	70.95
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	312	74.29	312	74.29	313	74.52	313	74.52
E2R PAXHC	36.1	420	420	420	313	74.52	313	74.52	313	74.52	313	74.52	313	74.52	313	74.52
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	96	22.86	96	22.86	96	22.86	96	22.86
K3D DRxET	12	470	470	470	80	17.02	90	19.15	112	23.83	5	1.06	145	30.85	89	18.94
K3D ETxVB	27.9	470	470	470	87	18.51	96	20.43	119	25.32	4	0.85	152	32.34	95	20.21
K3D VBxRL	81.7	470	470	470	97	20.64	106	22.55	127	27.02	23	4.89	160	34.04	104	22.13
A21L	191.7	880	880	880	451	51.25	0	0.00	275	31.25	418	47.50	459	52.16	457	51.93
A22L	191.7	880	880	880	451	51.25	795	90.34	275	31.25	417	47.39	459	52.16	457	51.93
D26A MAXIG	93.4	880	880	880	589	66.93	550	62.50	0	0.00	773	87.84	641	72.84	597	67.84
D26A IGxDN	40.4	880	880	880	158	17.95	120	13.64	0	0.00	332	37.73	203	23.07	165	18.75
D26A DNxDR	40	880	880	880	148	16.82	110	12.50	0	0.00	325	36.93	198	22.50	156	17.73
K23D KExVE	53.2	880	880	880	100	11.36	130	14.77	178	20.23	77	8.75	0	0.00	111	12.61
K23D VExDR	58.6	880	880	880	87	9.89	118	13.41	175	19.89	88	10.00	0	0.00	100	11.36
F25A	141.6	880	880	880	283	32.16	235	26.70	448	50.91	0	0.00	237	26.93	281	31.93

Table 38: Thermal Loading for Test Case 1 – Ignace Junction with All Elements in-service – Double-Circuit Contingency

Circuit Name	Length (KM)	Cont Rating	LTE Rating	STE Rating	Pre-Cont		Loss of AxLs and Cross-Trip B6M + Pickle Lake Line		Loss of AxLs and Cross-Trip B6M + E2R Lines		Loss of D26A + F25A and Cross-Trip M2D	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	% LTE
B6M BlxMU	14.5	440	440	450	238	54.09	55	12.50	55	12.50	41	9.32
B6M MUxST	7.9	430	430	430	195	45.35	38	8.84	38	8.84	37	8.60
B6M STxSH	33.5	470	470	470	194	41.28	30	6.38	30	6.38	41	8.72
B6M SHxIN	18.5	470	470	470	188	40.00	32	6.81	32	6.81	45	9.57
B6M INxKA	32.5	460	460	460	186	40.43	19	4.13	19	4.13	52	11.30
B6M KAxSA	58.9	430	430	430	186	43.26	19	4.42	19	4.42	52	12.09
B6M SAxCA	22.6	620	740	770	181	29.19	0	0.00	0	0.00	68	9.19
B6M CAxML	0.5	620	740	770	181	29.19	0	0.00	0	0.00	68	9.19
M2D MLxIG	76.7	550	550	550	275	50.00	107	19.45	50	9.09	0	0.00
M2D IGxDR	80.4	420	420	420	250	59.52	77	18.33	12	2.86	0	0.00
29M1 IGxIG	1.1	320	400	460	21	6.56	21	5.25	21	5.25	0	0.00
29M1 IGxCL	18	500	500	500	17	3.40	17	3.40	17	3.40	0	0.00
29M1 CLxVA	51	500	500	500	15	3.00	16	3.20	16	3.20	0	0.00
E4D DRxSL	68.2	665	665	665	638	95.94	643	96.69	54	8.12	641	96.39
E4D SLxEF	30.2	665	665	665	629	94.59	633	95.19	57	8.57	632	95.04
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	0	0.00	298	70.95
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	0	0.00	313	74.52
E2R PAxHC	36.1	420	420	420	313	74.52	313	74.52	0	0.00	313	74.52
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	0	0.00	96	22.86
K3D DRxET	12	470	470	470	80	17.02	135	28.72	92	19.57	177	37.66
K3D ETxVB	27.9	470	470	470	87	18.51	141	30.00	98	20.85	183	38.94
K3D VBxRL	81.7	470	470	470	97	20.64	148	31.49	106	22.55	191	40.64
A21L	191.7	880	880	880	451	51.25	0	0.00	0	0.00	53	6.02
A22L	191.7	880	880	880	451	51.25	0	0.00	0	0.00	53	6.02
D26A MAxIG	93.4	880	880	880	589	66.93	81	9.20	182	20.68	0	0.00
D26A IGxDN	40.4	880	880	880	158	17.95	62	7.05	249	28.30	0	0.00
D26A DNxDR	40	880	880	880	148	16.82	69	7.84	256	29.09	0	0.00
K23D KExVE	53.2	880	880	880	100	11.36	238	27.05	259	29.43	322	36.59
K23D VExDR	58.6	880	880	880	87	9.89	226	25.68	246	27.95	313	35.57
F25A	141.6	880	880	880	283	32.16	83	9.43	152	17.27	0	0.00

Table 39: Thermal Loading for Test Case 2 – Dinorwic Junction with All Elements in-service – Single-Circuit Contingency

Circuit Name	Length (KM)	CONT Rating	LTE Rating	STE Rating	Pre-Cont		Loss of A21L		Loss of D26A		Loss of F25A		Loss of K23D		Loss of 1 Manitou Falls Unit	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	% LTE	(A)	(A)	(A)	(A)
B6M BixMU	14.5	440	440	450	245	55.68	394	89.55	182	41.36	243	55.23	253	57.50	248	56.36
B6M MUxST	7.9	430	430	430	203	47.21	349	81.16	140	32.56	200	46.51	210	48.84	205	47.67
B6M STxSH	33.5	470	470	470	201	42.77	348	74.04	138	29.36	199	42.34	208	44.26	204	43.40
B6M SHxIN	18.5	470	470	470	196	41.70	342	72.77	132	28.09	193	41.06	203	43.19	198	42.13
B6M INxKA	32.5	460	460	460	193	41.96	339	73.70	129	28.04	191	41.52	200	43.48	196	42.61
B6M KAxSA	58.9	430	430	430	193	44.88	339	78.84	129	30.00	191	44.42	200	46.51	196	45.58
B6M SAxCA	22.6	620	740	770	187	30.16	331	44.73	124	16.76	186	25.14	195	26.35	190	25.68
B6M CAxML	0.5	620	740	770	187	30.16	331	44.73	124	16.76	186	25.14	195	26.35	190	25.68
M2D MLxIG	76.7	550	550	550	301	54.73	305	55.45	392	71.27	396	72.00	327	59.45	308	56.00
M2D IGxDR	80.4	420	420	420	278	66.19	281	66.90	371	88.33	374	89.05	304	72.38	285	67.86
29M1 IGxIG	1.1	320	400	460	21	6.56	21	5.25	20	5.00	20	5.00	20	5.00	21	5.25
29M1 IGxCL	18	500	500	500	17	3.40	17	3.40	17	3.40	17	3.40	17	3.40	17	3.40
29M1 CLxVA	51	500	500	500	16	3.20	15	3.00	15	3.00	15	3.00	15	3.00	15	3.00
E4D DRxSL	68.2	665	665	665	632	95.04	641	96.39	642	96.54	644	96.84	646	97.14	693	104.21
E4D SLxEF	30.2	665	665	665	623	93.68	632	95.04	632	95.04	634	95.34	635	95.49	683	102.71
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	297	70.71	297	70.71	297	70.71	297	70.71
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	312	74.29	312	74.29	312	74.29	312	74.29
E2R PAXHC	36.1	420	420	420	313	74.52	313	74.52	313	74.52	312	74.29	312	74.29	312	74.29
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	96	22.86	97	23.10	97	23.10	97	23.10
K3D DRxET	12	470	470	470	89	18.94	98	20.85	111	23.62	3	0.64	174	37.02	98	20.85
K3D ETxVB	27.9	470	470	470	96	20.43	105	22.34	118	25.11	5	1.06	181	38.51	104	22.13
K3D VBxRL	81.7	470	470	470	108	22.98	113	24.04	126	26.81	25	5.32	188	40.00	113	24.04
A21L	191.7	880	880	880	455	51.70	0	0.00	280	31.82	418	47.50	466	52.95	461	52.39
A22L	191.7	880	880	880	455	51.70	803	91.25	280	31.82	418	47.50	466	52.95	461	52.39
D26A MAxIG	93.4	880	880	880	550	62.50	512	58.18	0	0.00	758	86.14	619	70.34	560	63.64
D26A IGxDN	40.4	880	880	880	545	61.93	507	57.61	0	0.00	757	86.02	618	70.23	556	63.18
D26A DNxDR	40	880	880	880	108	12.27	72	8.18	0	0.00	304	34.55	171	19.43	117	13.30
K23D KExVE	53.2	880	880	880	116	13.18	149	16.93	176	20.00	67	7.61	0	0.00	130	14.77
K23D VExDR	58.6	880	880	880	114	12.95	142	16.14	173	19.66	91	10.34	0	0.00	127	14.43
F25A	141.6	880	880	880	314	35.68	266	30.23	455	51.70	0	0.00	255	28.98	312	35.45

Table 40: Thermal Loading for Test Case 2 – Dinorwic Junction with All Elements in-service – Double-Circuit Contingency

Circuit Name	Length (KM)	Cont Rating	LTE Rating	STE Rating	Pre-Cont		Loss of AxLs and Cross-Trip B6M + Pickle Lake Line		Loss of AxLs and Cross-Trip B6M + E2R Lines		Loss of D26A + F25A and Cross-Trip M2D	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	(A)
B6M BlxMU	14.5	440	440	450	245	55.68	55	12.50	55	12.50	9	2.05
B6M MUxST	7.9	430	430	430	203	47.21	38	8.84	38	8.84	8	1.86
B6M STxSH	33.5	470	470	470	201	42.77	30	6.38	30	6.38	8	1.70
B6M SHxIN	18.5	470	470	470	196	41.70	32	6.81	32	6.81	9	1.91
B6M INxKA	32.5	460	460	460	193	41.96	19	4.13	19	4.13	11	2.39
B6M KAxSA	58.9	430	430	430	193	44.88	19	4.42	19	4.42	12	2.79
B6M SAxCA	22.6	620	740	770	187	30.16	0	0.00	0	0.00	8	1.08
B6M CAxML	0.5	620	740	770	187	30.16	0	0.00	0	0.00	8	1.08
M2D MLxIG	76.7	550	550	550	301	54.73	105	19.09	60	10.91	0	0.00
M2D IGxDR	80.4	420	420	420	278	66.19	76	18.10	25	5.95	0	0.00
29M1 IGxIG	1.1	320	400	460	21	6.56	21	5.25	21	5.25	0	0.00
29M1 IGxCL	18	500	500	500	17	3.40	17	3.40	17	3.40	0	0.00
29M1 CLxVA	51	500	500	500	16	3.20	16	3.20	16	3.20	0	0.00
E4D DRxSL	68.2	665	665	665	632	95.04	643	96.69	54	8.12	96	14.44
E4D SLxEF	30.2	665	665	665	623	93.68	633	95.19	57	8.57	94	14.14
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	0	0.00	70	16.67
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	0	0.00	74	17.62
E2R PAxHC	36.1	420	420	420	313	74.52	313	74.52	0	0.00	74	17.62
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	0	0.00	23	5.48
K3D DRxET	12	470	470	470	89	18.94	134	28.51	99	21.06	37	7.87
K3D ETxVB	27.9	470	470	470	96	20.43	140	29.79	105	22.34	39	8.30
K3D VBxRL	81.7	470	470	470	108	22.98	147	31.28	112	23.83	40	8.51
A21L	191.7	880	880	880	455	51.70	0	0.00	0	0.00	6	0.68
A22L	191.7	880	880	880	455	51.70	0	0.00	0	0.00	6	0.68
D26A MAxIG	93.4	880	880	880	550	62.50	81	9.20	145	16.48	0	0.00
D26A IGxDN	40.4	880	880	880	545	61.93	63	7.16	135	15.34	0	0.00
D26A DNxDR	40	880	880	880	108	12.27	70	7.95	295	33.52	0	0.00
K23D KExVE	53.2	880	880	880	116	13.18	232	26.36	276	31.36	36	4.09
K23D VExDR	58.6	880	880	880	114	12.95	223	25.34	267	30.34	35	3.98
F25A	141.6	880	880	880	314	35.68	77	8.75	120	13.64	0	0.00

Appendix C: 230 kV Test Cases - Voltage Assessment Results

Table 41: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Element in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	245	0.00	245	0.00	0	N/A	0	N/A	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	243.5	243.8	0.12	243.8	0.12	239.9	-1.48	239.6	-1.60	240.4	-1.27	240.4	-1.27	241.2	-0.94	241.4	-0.86	243.1	-0.16	243.1	-0.16
Dryden 230 kV	244.4	244.5	0.04	244.7	0.12	239.8	-1.88	237.7	-2.74	240.7	-1.51	240.1	-1.76	241.8	-1.06	240.4	-1.64	243.6	-0.33	243.6	-0.33
Fort Frances 230 kV	244.4	244.5	0.04	244.7	0.12	239.8	-1.88	237.7	-2.74	240.7	-1.51	240.1	-1.76	241.8	-1.06	240.4	-1.64	243.6	-0.33	243.6	-0.33
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Lakehead 230 kV	246.7	243.1	-1.46	242.6	-1.66	246.2	-0.20	246.4	-0.12	247.9	0.49	247.7	0.41	246.4	-0.12	246.4	-0.12	246.5	-0.08	246.5	-0.08
Pickle Lake 115 kV	126.1	126.1	0.00	126.1	0.00	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Dryden 115 kV	124.3	124.2	-0.08	124.4	0.08	121.6	-2.17	123.7	-0.48	122.5	-1.45	123.7	-0.48	122.9	-1.13	123.8	-0.40	123.8	-0.40	123.8	-0.40
Fort Frances 115 kV	118.5	118.6	0.08	118.6	0.08	116.9	-1.35	118.4	-0.08	115.5	-2.53	118.3	-0.17	118.2	-0.25	118.2	-0.25	118.4	-0.08	118.4	-0.08
Mackenzie 115 kV	120.9	119.6	-1.08	120.9	0.00	120.7	-0.17	121	0.08	120.8	-0.08	120.9	0.00	120.7	-0.17	120.8	-0.08	120.8	-0.08	120.8	-0.08
Moose Lake 115 kV	121.1	119.5	-1.32	120.5	-0.50	120.4	-0.58	120.8	-0.25	120.7	-0.33	120.8	-0.25	120.7	-0.33	120.9	-0.17	121	-0.08	120.9	-0.17
Birch 115 kV	124.9	122.8	-1.68	122.6	-1.84	123	-1.52	123.1	-1.44	125.4	0.40	125.3	0.32	124.7	-0.16	124.7	-0.16	124.8	-0.08	124.7	-0.16
Valora Jct 115 kV	123.1	122.2	-0.73	122.7	-0.32	120	-2.52	121.3	-1.46	121	-1.71	121.7	-1.14	122	-0.89	122.5	-0.49	122.7	-0.32	122.7	-0.32
Esker 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.3	126.3	0.00	126.3	0.00	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Neskatanga 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Webequie 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
McFaulds 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	126.3	126.3	0.00	126.3	0.00	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Wapekeka 115 kV	125.6	125.6	0.00	125.6	0.00	0	N/A	0	N/A	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00
North Caribou Lake 115 kV	126.8	126.8	0.00	126.8	0.00	0	N/A	0	N/A	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Muskrat Dam 115 kV	126.5	126.5	0.00	126.5	0.00	0	N/A	0	N/A	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00
Crow River 115 kV	126.1	126.1	0.00	126.1	0.00	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Thierry Mine 115 kV	125.7	125.7	0.00	125.7	0.00	0	N/A	0	N/A	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00
Cat Lake 115 kV	127.3	127.3	0.00	127.3	0.00	0	N/A	0	N/A	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00
Slate Falls 115 kV	128.2	128.2	0.00	128.2	0.00	0	N/A	0	N/A	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	124.1	124	-0.08	124.2	0.08	121.4	-2.18	123.5	-0.48	122.3	-1.45	123.5	-0.48	122.7	-1.13	123.6	-0.40	123.6	-0.40	123.6	-0.40
Perrault Falls 115 kV	123	123	0.00	123	0.00	122	-0.81	122.8	-0.16	122.3	-0.57	122.8	-0.16	122.5	-0.41	122.8	-0.16	122.4	-0.49	122.4	-0.49
Sam Lake 115 kV	122.8	122.7	-0.08	122.8	0.00	120	-2.28	122.2	-0.49	120.9	-1.55	122.2	-0.49	121.3	-1.22	122.2	-0.49	122.3	-0.41	122.3	-0.41

Table 41: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Single Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Balmer 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	120.7	0.00	120.7	0.00	120.8	0.08	120.8	0.08	120.7	0.00	120.8	0.08	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00
Sandy Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Vermillion Bay DS 115 kV	124.1	124.1	0.00	124.2	0.08	121.7	-1.93	123.6	-0.40	122.4	-1.37	123.8	-0.24	122.7	-1.13	123.4	-0.56	123.7	-0.32	123.7	-0.32
Agimak DS 115 kV	122.7	121.8	-0.73	122.4	-0.24	119.7	-2.44	120.9	-1.47	120.7	-1.63	121.4	-1.06	121.6	-0.90	122.1	-0.49	122.3	-0.33	122.3	-0.33
Mattabi CTS 115 kV	123.1	122.2	-0.73	122.7	-0.32	120	-2.52	121.3	-1.46	121	-1.71	121.7	-1.14	122	-0.89	122.5	-0.49	122.7	-0.32	122.7	-0.32
Valora DS 115 kV	123.1	122.2	-0.73	122.7	-0.32	120	-2.52	121.3	-1.46	121	-1.71	121.7	-1.14	122	-0.89	122.5	-0.49	122.7	-0.32	122.7	-0.32
Murillo DS 115 kV	124	121.4	-2.10	121.3	-2.18	122.4	-1.29	122.5	-1.21	124.6	0.48	124.5	0.40	123.8	-0.16	123.8	-0.16	123.9	-0.08	123.9	-0.08
Shabaqua DS 115 kV	123.1	119.6	-2.84	119.6	-2.84	122	-0.89	122.2	-0.73	123.5	0.32	123.4	0.24	122.9	-0.16	122.9	-0.16	123	-0.08	123	-0.08
Sapawe DS 115 kV	121.4	118.9	-2.06	119.7	-1.40	120.8	-0.49	121.1	-0.25	121.1	-0.25	121.2	-0.16	121.1	-0.25	121.2	-0.16	121.3	-0.08	121.3	-0.08
West Coast 115 kV	118.3	118.4	0.08	118.5	0.17	116.7	-1.35	118.2	-0.08	115.3	-2.54	118.2	-0.08	118	-0.25	118.1	-0.17	118.3	0.00	118.2	-0.08
Fort Frances MS 115 kV	118.5	118.6	0.08	118.6	0.08	116.9	-1.35	118.4	-0.08	115.5	-2.53	118.3	-0.17	118.2	-0.25	118.2	-0.25	118.4	-0.08	118.4	-0.08
Burleigh DS 115 kV	118.4	118.5	0.08	118.6	0.17	116.8	-1.35	118.3	-0.08	115.4	-2.53	118.3	-0.08	118.1	-0.25	118.2	-0.17	118.3	-0.08	118.3	-0.08

Table 42: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	0	N/A	0	N/A	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	243.5	243.4	-0.04	243.5	0.00	242.8	-0.29	243.1	-0.16	236.8	-2.75	238.5	-2.05
Dryden 230 kV	244.4	245	0.25	245	0.25	245	0.25	245	0.25	237.7	-2.74	238.9	-2.25
Fort Frances 230 kV	244.4	245	0.25	245	0.25	245	0.25	245	0.25	237.7	-2.74	238.9	-2.25
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	253.4	3.43	253.8	3.59
Lakehead 230 kV	246.7	249	0.93	249	0.93	249	0.93	249	0.93	252.8	2.47	252.7	2.43
Pickle Lake 115 kV	126.1	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Dryden 115 kV	124.3	125	0.56	123.7	-0.48	125	0.56	123.5	-0.64	121.7	-2.09	123.9	-0.32
Fort Frances 115 kV	118.5	117	-1.27	119.3	0.68	116.1	-2.03	118.9	0.34	112.4	-5.15	118.3	-0.17
Mackenzie 115 kV	120.9	121.3	0.33	121.1	0.17	121	0.08	120.8	-0.08	124.8	3.23	121.6	0.58
Moose Lake 115 kV	121.1	121.6	0.41	121.3	0.17	121.3	0.17	121.1	0.00	124.9	3.14	121.9	0.66
Birch 115 kV	124.9	124.8	-0.08	124.8	-0.08	124.8	-0.08	124.8	-0.08	126.4	1.20	126.1	0.96
Valora Jct 115 kV	123.1	124.8	1.38	123.9	0.65	124.7	1.30	123.9	0.65	123.1	0.00	123.1	0.00
Esker 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Musslewhite 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.3	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Neskatanga 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Webequie 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
McFaulds 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	126.3	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Wapekeka 115 kV	125.6	0	N/A	0	N/A	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00
North Caribou Lake 115 kV	126.8	0	N/A	0	N/A	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Muskrat Dam 115 kV	126.5	0	N/A	0	N/A	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00
Crow River 115 kV	126.1	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Thierry Mine 115 kV	125.7	0	N/A	0	N/A	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00
Cat Lake 115 kV	127.3	0	N/A	0	N/A	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00
Slate Falls 115 kV	128.2	0	N/A	0	N/A	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	125.7	0.24	124.7	-0.56	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	124.1	124.8	0.56	123.5	-0.48	124.8	0.56	123.3	-0.64	121.5	-2.10	123.7	-0.32
Perrault Falls 115 kV	123	123.3	0.24	122.8	-0.16	125.6	2.11	124.5	1.22	122	-0.81	122.8	-0.16
Sam Lake 115 kV	122.8	123.5	0.57	122.1	-0.57	123.5	0.57	122	-0.65	120.1	-2.20	122.3	-0.41
Balmer 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	0	N/A	0	N/A	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	120.7	0.00	120.7	0.00	0	N/A	0	N/A	120.7	0.00	120.7	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	0	N/A	0	N/A	120.4	0.00	120.4	0.00

Table 42: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Double Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Sandy Lake 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00
Vermillion Bay DS 115 kV	124.1	124.5	0.32	123.6	-0.40	124.5	0.32	123.6	-0.40	121	-2.50	123.5	-0.48
Agimak DS 115 kV	122.7	124.4	1.39	123.6	0.73	124.4	1.39	123.5	0.65	0	N/A	0	N/A
Mattabi CTS 115 kV	123.1	124.8	1.38	123.9	0.65	124.7	1.30	123.9	0.65	0	N/A	0	N/A
Valora DS 115 kV	123.1	124.7	1.30	123.9	0.65	124.7	1.30	123.9	0.65	0	N/A	0	N/A
Murillo DS 115 kV	124	124.8	0.65	124.8	0.65	124.8	0.65	124.8	0.65	126	1.61	125.5	1.21
Shabaqua DS 115 kV	123.1	125.9	2.27	125.9	2.27	125.9	2.27	125.9	2.27	126.2	2.52	125	1.54
Sapawe DS 115 kV	121.4	127.6	5.11	127.6	5.11	127.6	5.11	127.6	5.11	125.3	3.21	122.6	0.99
West Coast 115 kV	118.3	116.9	-1.18	119.1	0.68	116	-1.94	118.8	0.42	112.2	-5.16	118.1	-0.17
Fort Frances MS 115 kV	118.5	117	-1.27	119.3	0.68	116.1	-2.03	118.9	0.34	112.3	-5.23	118.3	-0.17
Burleigh DS 115 kV	118.4	117	-1.18	119.2	0.68	116.1	-1.94	118.9	0.42	112.3	-5.15	118.2	-0.17

Table 43: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of Dryden Cap				Loss of 1 Neskantanga Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Webequie Cap				Loss of Mackenzie SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	243.5	243	-0.21	242.9	-0.25	240.9	-1.07	239.9	-1.48	243.5	0.00	243.5	0.00	243.5	0.00	243.5	0.00	243.5	0.00	243.5	0.00	241.2	-0.94	240.1	-1.40
Dryden 230 kV	244.4	243.3	-0.45	243.2	-0.49	238.8	-2.29	237	-3.03	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	241.3	-1.27	240	-1.80
Fort Frances 230 kV	244.4	243.3	-0.45	243.2	-0.49	238.8	-2.29	237	-3.03	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	241.3	-1.27	240	-1.80
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	239.5	-2.24	238.1	-2.82
Lakehead 230 kV	246.7	246.7	0.00	246.7	0.00	246.6	-0.04	246.7	0.00	246.7	0.00	246.7	0.00	246.7	0.00	246.7	0.00	246.7	0.00	246.7	0.00	244.7	-0.81	244.5	-0.89
Pickle Lake 115 kV	126.1	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Dryden 115 kV	124.3	123.5	-0.64	123.4	-0.72	122	-1.85	124.1	-0.16	124.3	0.00	124.3	0.00	124.3	0.00	124.3	0.00	124.3	0.00	124.3	0.00	122.8	-1.21	123.9	-0.32
Fort Frances 115 kV	118.5	118.4	-0.08	118.4	-0.08	117.9	-0.51	117.9	-0.51	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	117	-1.27	118	-0.42
Mackenzie 115 kV	120.9	120.8	-0.08	120.8	-0.08	120.7	-0.17	120.9	0.00	121	0.08	121	0.08	120.9	0.00	120.9	0.00	120.9	0.00	120.9	0.00	118.6	-1.90	120.9	0.00
Moose Lake 115 kV	121.1	120.9	-0.17	120.9	-0.17	120.7	-0.33	121	-0.08	121.1	0.00	121.1	0.00	121.1	0.00	121.1	0.00	121.1	0.00	121.1	0.00	118.9	-1.82	121	-0.08
Birch 115 kV	124.9	124.8	-0.08	124.8	-0.08	124.8	-0.08	124.8	-0.08	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	123.8	-0.88	123.9	-0.80
Valora Jct 115 kV	123.1	122.6	-0.41	122.5	-0.49	121.7	-1.14	122.9	-0.16	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	121.1	-1.62	122.7	-0.32
Esker 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.3	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Neskantanga 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Webequie 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	119.4	-0.50	119.3	-0.58	120	0.00	120	0.00
McFaulds 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	126.3	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Wapekeka 115 kV	125.6	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00
North Caribou Lake 115 kV	126.8	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Muskrat Dam 115 kV	126.5	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00
Crow River 115 kV	126.1	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Thierry Mine 115 kV	125.7	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00
Cat Lake 115 kV	127.3	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00
Slate Falls 115 kV	128.2	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Ear Falls 115 kV	125.4	121.6	-3.03	121.4	-3.19	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	124.1	123.3	-0.64	123.2	-0.73	121.7	-1.93	123.9	-0.16	124.1	0.00	124.1	0.00	124.1	0.00	124.1	0.00	124.1	0.00	124.1	0.00	122.6	-1.21	123.7	-0.32
Perrault Falls 115 kV	123	120.1	-2.36	119.8	-2.60	122.1	-0.73	123	0.00	123	0.00	123	0.00	123	0.00	123	0.00	123	0.00	123	0.00	122.4	-0.49	122.8	-0.16
Sam Lake 115 kV	122.8	121.9	-0.73	121.8	-0.81	120.4	-1.95	122.5	-0.24	122.7	-0.08	122.7	-0.08	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00	121.2	-1.30	122.3	-0.41
Balmer 115 kV	120	116	-3.33	115.6	-3.67	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	116.5	-3.32	116.1	-3.65	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	116.8	-3.23	116.4	-3.56	120.7	0.00	120.8	0.08	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.8	0.08
Deer Lake 115 kV	120.4	116.8	-2.99	116.3	-3.41	120.4	0.00	120.5	0.08	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00

Table 43: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of 1 Ear Falls SVC				Loss of Dryden Cap				Loss of 1 Neskotanga Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Webequie Cap				Loss of Mackenzie SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Sandy Lake 115 kV	120	116.4	-3.00	116	-3.33	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Vermillion Bay DS 115 kV	124.1	123.5	-0.48	123.4	-0.56	122.1	-1.61	123.9	-0.16	124.1	0.00	124.1	0.00	124.1	0.00	124.1	0.00	124.1	0.00	124.1	0.00	122.7	-1.13	123.8	-0.24
Agimak DS 115 kV	122.7	122.2	-0.41	122.2	-0.41	121.3	-1.14	122.6	-0.08	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00	120.8	-1.55	122.4	-0.24
Mattabi CTS 115 kV	123.1	122.6	-0.41	122.5	-0.49	121.7	-1.14	122.9	-0.16	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	121.1	-1.62	122.7	-0.32
Valora DS 115 kV	123.1	122.6	-0.41	122.5	-0.49	121.7	-1.14	122.9	-0.16	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	121.1	-1.62	122.7	-0.32
Murillo DS 115 kV	124	124	0.00	124	0.00	124	0.00	124	0.00	124	0.00	124	0.00	124	0.00	124	0.00	124	0.00	124	0.00	122.9	-0.89	123.1	-0.73
Shabaqua DS 115 kV	123.1	123.1	0.00	123.1	0.00	123	-0.08	123.1	0.00	123.2	0.08	123.2	0.08	123.1	0.00	123.1	0.00	123.1	0.00	123.1	0.00	121.8	-1.06	122.4	-0.57
Sapawe DS 115 kV	121.4	121.3	-0.08	121.3	-0.08	121.1	-0.25	121.4	0.00	121.4	0.00	121.4	0.00	121.4	0.00	121.4	0.00	121.4	0.00	121.4	0.00	119.4	-1.65	121.2	-0.16
West Coast 115 kV	118.3	118.2	-0.08	118.2	-0.08	117.8	-0.42	117.7	-0.51	118.3	0.00	118.3	0.00	118.3	0.00	118.3	0.00	118.3	0.00	118.3	0.00	116.8	-1.27	117.9	-0.34
Fort Frances MS 115 kV	118.5	118.4	-0.08	118.3	-0.17	117.9	-0.51	117.9	-0.51	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	117	-1.27	118	-0.42
Burleigh DS 115 kV	118.4	118.3	-0.08	118.3	-0.08	117.9	-0.42	117.8	-0.51	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00	116.9	-1.27	118	-0.34

Table 44: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	239.8	239.8	0.00	239.8	0.00	247.7	3.29	247.4	3.17	239.8	0.00	239.8	0.00
Kenora 230 kV	243.5	245.3	0.74	245.3	0.74	244.2	0.29	244.2	0.29	243.5	0.00	243.5	0.00
Dryden 230 kV	244.9	247.5	1.06	247.5	1.06	246.2	0.53	246.1	0.49	244.9	0.00	244.9	0.00
Fort Frances 230 kV	244.9	247.5	1.06	247.5	1.06	246.2	0.53	246.1	0.49	244.9	0.00	244.9	0.00
Mackenzie 230 kV	241.6	247	2.24	247	2.24	242.6	0.41	242.5	0.37	241.6	0.00	241.6	0.00
Lakehead 230 kV	238.7	240	0.54	240	0.54	238.7	0.00	238.7	0.00	238.7	0.00	238.7	0.00
Pickle Lake 115 kV	120.4	120.4	0.00	120.4	0.00	124	2.99	123.9	2.91	120.4	0.00	120.4	0.00
Dryden 115 kV	124.1	125.4	1.05	125.4	1.05	124.7	0.48	124.7	0.48	124.1	0.00	124.1	0.00
Fort Frances 115 kV	119.1	120.4	1.09	120.4	1.09	119.4	0.25	119.4	0.25	119.1	0.00	119.1	0.00
Mackenzie 115 kV	121.4	123.7	1.89	123.7	1.89	121.8	0.33	121.8	0.33	121.4	0.00	121.4	0.00
Moose Lake 115 kV	121.7	124	1.89	124	1.89	122.1	0.33	122.1	0.33	121.7	0.00	121.7	0.00
Birch 115 kV	121.9	122.4	0.41	122.4	0.41	121.8	-0.08	121.8	-0.08	121.9	0.00	121.9	0.00
Valora Jct 115 kV	124.3	126.2	1.53	126.2	1.53	124.8	0.40	124.8	0.40	124.3	0.00	124.3	0.00
Esker 115 kV	118.7	118.7	0.00	118.7	0.00	120	1.10	120.1	1.18	118.7	0.00	118.7	0.00
Musslewhite 115 kV	118.6	118.6	0.00	118.6	0.00	120	1.18	120	1.18	118.6	0.00	118.6	0.00
King Fisher 115 kV	125.3	125.3	0.00	125.3	0.00	126.5	0.96	126.3	0.80	125.3	0.00	125.3	0.00
Neskatanga 115 kV	121	121	0.00	121	0.00	123	1.65	122.9	1.57	121	0.00	121	0.00
Webequie 115 kV	120.4	120.4	0.00	120.4	0.00	121.4	0.83	121.3	0.75	120.4	0.00	120.4	0.00
McFaulds 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	125.7	125.7	0.00	125.7	0.00	126.9	0.95	126.7	0.80	125.7	0.00	125.7	0.00
Wapekeka 115 kV	126.3	126.3	0.00	126.3	0.00	127.5	0.95	127.3	0.79	126.3	0.00	126.3	0.00
North Caribou Lake 115 kV	127.1	127.1	0.00	127.1	0.00	128.3	0.94	128.1	0.79	127.1	0.00	127.1	0.00
Muskrat Dam 115 kV	127.4	127.4	0.00	127.4	0.00	128.6	0.94	128.4	0.78	127.4	0.00	127.4	0.00
Crow River 115 kV	120.4	120.4	0.00	120.4	0.00	124	2.99	123.9	2.91	120.4	0.00	120.4	0.00
Thierry Mine 115 kV	120.3	120.3	0.00	120.3	0.00	124	3.08	123.9	2.99	120.3	0.00	120.3	0.00
Cat Lake 115 kV	123.1	123.1	0.00	123.1	0.00	126.9	3.09	126.8	3.01	123.1	0.00	123.1	0.00
Slate Falls 115 kV	124.9	124.9	0.00	124.9	0.00	128.7	3.04	128.6	2.96	124.9	0.00	124.9	0.00
Ear Falls 115 kV	122.8	122.9	0.08	122.9	0.08	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00
Domtar Dryden 115 kV	124.1	125.4	1.05	125.4	1.05	124.7	0.48	124.7	0.48	124.1	0.00	124.1	0.00
Perrault Falls 115 kV	122.4	122.9	0.41	122.9	0.41	122.6	0.16	122.6	0.16	122.4	0.00	122.4	0.00
Sam Lake 115 kV	123.6	124.9	1.05	124.9	1.05	124.2	0.49	124.2	0.49	123.6	0.00	123.6	0.00
Balmer 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.6	0.08	120.6	0.08	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	123.8	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00
Deer Lake 115 kV	126	126	0.00	126	0.00	126	0.00	126	0.00	126	0.00	126	0.00

Table 44: HV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Sandy Lake 115 kV	126.1	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Vermillion Bay DS 115 kV	124.2	125.3	0.89	125.3	0.89	124.7	0.40	124.7	0.40	124.2	0.00	124.2	0.00
Agimak DS 115 kV	123.9	125.7	1.45	125.7	1.45	124.4	0.40	124.4	0.40	123.9	0.00	123.9	0.00
Mattabi CTS 115 kV	124.4	126.2	1.45	126.2	1.45	124.9	0.40	124.9	0.40	124.4	0.00	124.4	0.00
Valora DS 115 kV	124.3	126.2	1.53	126.2	1.53	124.8	0.40	124.8	0.40	124.3	0.00	124.3	0.00
Murillo DS 115 kV	121.8	122.4	0.49	122.4	0.49	121.7	-0.08	121.7	-0.08	121.8	0.00	121.8	0.00
Shabaqua DS 115 kV	122.1	123.1	0.82	123.1	0.82	122.1	0.00	122.1	0.00	122.1	0.00	122.1	0.00
Sapawe DS 115 kV	121.9	124	1.72	124	1.72	122.3	0.33	122.3	0.33	121.9	0.00	121.9	0.00
West Coast 115 kV	119	120.3	1.09	120.3	1.09	119.3	0.25	119.3	0.25	119	0.00	119	0.00
Fort Frances MS 115 kV	119.1	120.4	1.09	120.4	1.09	119.4	0.25	119.4	0.25	119.1	0.00	119.1	0.00
Burleigh DS 115 kV	119	120.3	1.09	120.3	1.09	119.3	0.25	119.3	0.25	119	0.00	119	0.00

Table 45: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	25	24.4	-2.40	24.8	-0.80	24.6	-1.60	24.8	-0.80	25.1	0.40	25.1	0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40
Shabaqua DS LV	13.2	12.8	-3.03	12.8	-3.03	13.1	-0.76	13.1	-0.76	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00
Sapawe DS LV	13.7	13.4	-2.19	13.5	-1.46	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00
Mattabi DS LV	4.2	4.2	0.00	4.2	0.00	4.1	-2.38	4.1	-2.38	4.1	-2.38	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Agimak DS LV	26.3	26.1	-0.76	26.6	1.14	25.7	-2.28	26.6	1.14	25.9	-1.52	26.3	0.00	26.1	-0.76	26.5	0.76	26.2	-0.38	26.2	-0.38
Valora DS LV	25.6	25.4	-0.78	25.5	-0.39	24.9	-2.73	25.2	-1.56	25.1	-1.95	25.3	-1.17	25.3	-1.17	25.4	-0.78	25.5	-0.39	25.5	-0.39
Esker LV	13.9	13.9	0.00	13.9	0.00	0	N/A	0	N/A	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	0	N/A	0	N/A	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.9	27.9	0.00	27.9	0.00	0	N/A	0	N/A	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Webequie LV	22.6	22.6	0.00	22.6	0.00	0	N/A	0	N/A	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00
McFaulds LV	46	46	0.00	46	0.00	0	N/A	0	N/A	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00
King Fisher Lake LV	25.2	25.2	0.00	25.2	0.00	0	N/A	0	N/A	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00
Wapekeka LV	27.8	27.8	0.00	27.8	0.00	0	N/A	0	N/A	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24	24	0.00	24	0.00	0	N/A	0	N/A	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00
Muskrat LV	28	28	0.00	28	0.00	0	N/A	0	N/A	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.5	27.5	0.00	27.5	0.00	0	N/A	0	N/A	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Thierry Mine LV	4.5	4.5	0.00	4.5	0.00	0	N/A	0	N/A	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	29.4	0.00	29.4	0.00	0	N/A	0	N/A	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24.7	24.7	0.00	24.7	0.00	0	N/A	0	N/A	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Ear Falls LV	46.3	46.3	0.00	46.3	0.00	0	N/A	0	N/A	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Domtar Dryden LV	13.7	13.7	0.00	13.7	0.00	13.4	-2.19	13.6	-0.73	13.5	-1.46	13.6	-0.73	13.5	-1.46	13.6	-0.73	13.6	-0.73	13.6	-0.73
Perrault Falls LV	11.5	11.5	0.00	11.5	0.00	11.4	-0.87	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00
Sam Lake LV	26.4	26.4	0.00	26.4	0.00	25.8	-2.27	26.7	1.14	26	-1.52	26.5	0.38	26.1	-1.14	26.5	0.38	26.3	-0.38	26.3	-0.38
Balmer LV	44.1	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Sandy Lake LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.2	13.2	0.00	13.3	0.76	13	-1.52	13.4	1.52	13.1	-0.76	13.3	0.76	13.1	-0.76	13.3	0.76	13.2	0.00	13.2	0.00
Vermillion Bay DS LV	15.2	15.2	0.00	15.2	0.00	14.9	-1.97	15.1	-0.66	15	-1.32	15.1	-0.66	15	-1.32	15.1	-0.66	15.1	-0.66	15.1	-0.66
Burleigh DS LV	13.1	13.1	0.00	13.1	0.00	12.9	-1.53	13	-0.76	12.7	-3.05	13	-0.76	13	-0.76	13	-0.76	13	-0.76	13	-0.76
Fort Frances MS1 LV	14.1	14.1	0.00	14.1	0.00	13.9	-1.42	14.1	0.00	13.7	-2.84	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances MS2 LV	12.5	12.5	0.00	12.5	0.00	12.3	-1.60	12.5	0.00	12.1	-3.20	12.5	0.00	12.4	-0.80	12.4	-0.80	12.4	-0.80	12.4	-0.80
Fort Frances L5	14.1	14.2	0.71	14.2	0.71	13.9	-1.42	14.1	0.00	13.8	-2.13	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances L4A	14	14	0.00	14	0.00	13.8	-1.43	14	0.00	13.7	-2.14	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00
Fort Frances L4B	14.8	14.8	0.00	14.9	0.68	14.6	-1.35	14.8	0.00	14.5	-2.03	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00
Fort Frances AB	6.7	6.7	0.00	6.7	0.00	6.6	-1.49	6.7	0.00	6.5	-2.99	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00

Table 46: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	25	25.1	0.40	25.1	0.40	25.1	0.40	25.1	0.40	25.4	1.60	25.2	0.80
Shabaqua DS LV	13.2	13.5	2.27	13.5	2.27	13.5	2.27	13.5	2.27	13.5	2.27	13.4	1.52
Sapawe DS LV	13.7	14.4	5.11	14.4	5.11	14.4	5.11	14.4	5.11	14.2	3.65	13.9	1.46
Mattabi DS LV	4.2	4.3	2.38	4.2	0.00	4.3	2.38	4.2	0.00	0	N/A	0	N/A
Agimak DS LV	26.3	26.7	1.52	26.5	0.76	26.7	1.52	26.5	0.76	0	N/A	0	N/A
Valora DS LV	25.6	25.9	1.17	25.7	0.39	25.9	1.17	25.7	0.39	0	N/A	0	N/A
Esker LV	13.9	0	N/A	0	N/A	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	0	N/A	0	N/A	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatangang LV	27.9	0	N/A	0	N/A	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Webequie LV	22.6	0	N/A	0	N/A	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00
McFaulds LV	46	0	N/A	0	N/A	46	0.00	46	0.00	46	0.00	46	0.00
King Fisher Lake LV	25.2	0	N/A	0	N/A	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00
Wapekeka LV	27.8	0	N/A	0	N/A	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24	0	N/A	0	N/A	24	0.00	24	0.00	24	0.00	24	0.00
Muskrat LV	28	0	N/A	0	N/A	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.5	0	N/A	0	N/A	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Thierry Mine LV	4.5	0	N/A	0	N/A	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	0	N/A	0	N/A	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Ear Falls LV	46.3	0	N/A	0	N/A	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Domtar Dryden LV	13.7	13.8	0.73	13.6	-0.73	13.8	0.73	13.6	-0.73	13.4	-2.19	13.6	-0.73
Perrault Falls LV	11.5	11.6	0.87	11.5	0.00	11.8	2.61	11.7	1.74	11.4	-0.87	11.5	0.00
Sam Lake LV	26.4	26.6	0.76	26.3	-0.38	26.6	0.76	26.5	0.38	25.8	-2.27	26.5	0.38
Balmer LV	44.1	44.1	0.00	44.1	0.00	0	N/A	0	N/A	44.1	0.00	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	0	N/A	0	N/A	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	0	N/A	0	N/A	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	27.8	0.00	27.8	0.00	0	N/A	0	N/A	27.8	0.00	27.8	0.00
Sandy Lake LV	27.5	27.5	0.00	27.5	0.00	0	N/A	0	N/A	27.5	0.00	27.5	0.00
Eton DS LV	13.2	13.3	0.76	13.3	0.76	13.3	0.76	13.3	0.76	12.9	-2.27	13.4	1.52
Vermillion Bay DS LV	15.2	15.2	0.00	15.1	-0.66	15.2	0.00	15.1	-0.66	14.8	-2.63	15.1	-0.66
Burleigh DS LV	13.1	12.9	-1.53	13.1	0.00	12.8	-2.29	13.1	0.00	12.3	-6.11	13	-0.76
Fort Frances MS1 LV	14.1	13.9	-1.42	14.2	0.71	13.8	-2.13	14.2	0.71	13.3	-5.67	14.1	0.00
Fort Frances MS2 LV	12.5	12.3	-1.60	12.5	0.00	12.2	-2.40	12.6	0.80	11.8	-5.60	12.5	0.00
Fort Frances L5	14.1	14	-0.71	14.3	1.42	13.8	-2.13	14.2	0.71	13.3	-5.67	14.1	0.00
Fort Frances L4A	14	13.8	-1.43	14.1	0.71	13.7	-2.14	14.1	0.71	13.3	-5.00	14	0.00
Fort Frances L4B	14.8	14.7	-0.68	14.9	0.68	14.5	-2.03	14.9	0.68	14.1	-4.73	14.8	0.00
Fort Frances AB	6.7	6.6	-1.49	6.8	1.49	6.6	-1.49	6.8	1.49	6.3	-5.97	6.7	0.00

Table 47: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of Dryden Cap				Loss of 1 Neskatanga Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Webequie Cap				Loss of Mackenzie SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	25	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	24.7	-1.20	24.9	-0.40
Shabaqua DS LV	13.2	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13	-1.52	13.1	-0.76
Sapawe DS LV	13.7	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.5	-1.46	13.7	0.00
Mattabi DS LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.1	-2.38	4.2	0.00
Agimak DS LV	26.3	26.2	-0.38	26.2	-0.38	26	-1.14	26.6	1.14	26.3	0.00	26.3	0.00	26.3	0.00	26.3	0.00	26.3	0.00	26.3	0.00	25.9	-1.52	26.6	1.14
Valora DS LV	25.6	25.5	-0.39	25.4	-0.78	25.3	-1.17	25.5	-0.39	25.6	0.00	25.6	0.00	25.6	0.00	25.6	0.00	25.6	0.00	25.6	0.00	25.2	-1.56	25.5	-0.39
Esker LV	13.9	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Webequie LV	22.6	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.4	-0.88	22.4	-0.88	22.6	0.00	22.6	0.00
McFaulds LV	46	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46.1	0.22	46.1	0.22	46	0.00	46	0.00
King Fisher Lake LV	25.2	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00
Wapekeka LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00
Muskkrat LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Thierry Mine LV	4.5	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Ear Falls LV	46.3	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Domtar Dryden LV	13.7	13.6	-0.73	13.6	-0.73	13.4	-2.19	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.5	-1.46	13.6	-0.73
Perrault Falls LV	11.5	11.2	-2.61	11.2	-2.61	11.4	-0.87	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00
Sam Lake LV	26.4	26.2	-0.76	26.4	0.00	25.9	-1.89	26.6	0.76	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.1	-1.14	26.5	0.38
Balmer LV	44.1	42.6	-3.40	43.3	-1.81	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	45.3	-3.41	46.2	-1.49	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27	-3.23	27.2	-2.51	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	26.9	-3.24	27.5	-1.08	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Sandy Lake LV	27.5	27	-1.82	27.2	-1.09	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.2	13.2	0.00	13.3	0.76	13	-1.52	13.3	0.76	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.1	-0.76	13.3	0.76
Vermillion Bay DS LV	15.2	15.1	-0.66	15.1	-0.66	14.9	-1.97	15.2	0.00	15.2	0.00	15.2	0.00	15.2	0.00	15.2	0.00	15.2	0.00	15.2	0.00	15	-1.32	15.1	-0.66
Burleigh DS LV	13.1	13	-0.76	13	-0.76	13	-0.76	13	-0.76	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	12.9	-1.53	13	-0.76
Fort Frances MS1 LV	14.1	14.1	0.00	14.1	0.00	14	-0.71	14	-0.71	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	13.9	-1.42	14	-0.71
Fort Frances MS2 LV	12.5	12.4	-0.80	12.4	-0.80	12.4	-0.80	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.3	-1.60	12.5	0.00
Fort Frances L5	14.1	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	13.9	-1.42	14.1	0.00
Fort Frances L4A	14	14	0.00	14	0.00	13.9	-0.71	13.9	-0.71	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00	13.8	-1.43	14	0.00
Fort Frances L4B	14.8	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.6	-1.35	14.8	0.00
Fort Frances AB	6.7	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.6	-1.49	6.7	0.00

Table 48: LV Voltage Assessment for Test Case 1 – Ignace Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont Volt (kV)	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.9	25	0.40	25	0.40	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Shabaqua DS LV	13.1	13.2	0.76	13.2	0.76	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Sapawe DS LV	13.8	14	1.45	14	1.45	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00
Mattabi DS LV	4.3	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00
Agimak DS LV	26.3	26.7	1.52	26.7	1.52	26.4	0.38	26.4	0.38	26.3	0.00	26.3	0.00
Valora DS LV	25.9	26.3	1.54	26.3	1.54	26	0.39	26	0.39	25.9	0.00	25.9	0.00
Esker LV	13.7	13.7	0.00	13.7	0.00	13.8	0.73	13.9	1.46	13.7	0.00	13.7	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Webequie LV	23.5	23.5	0.00	23.5	0.00	23.7	0.85	23.6	0.43	23.5	0.00	23.5	0.00
McFaulds LV	45.2	45.2	0.00	45.2	0.00	44.9	-0.66	45	-0.44	45.2	0.00	45.2	0.00
King Fisher Lake LV	24.8	24.8	0.00	24.8	0.00	25	0.81	25	0.81	24.8	0.00	24.8	0.00
Wapekeka LV	27.3	27.3	0.00	27.3	0.00	27.6	1.10	27.5	0.73	27.3	0.00	27.3	0.00
North Caribou Lake LV	24.8	24.8	0.00	24.8	0.00	25	0.81	25	0.81	24.8	0.00	24.8	0.00
Muskrat LV	27.6	27.6	0.00	27.6	0.00	27.8	0.72	27.8	0.72	27.6	0.00	27.6	0.00
Crow River LV	27.8	27.8	0.00	27.8	0.00	28.7	3.24	27.9	0.36	27.8	0.00	27.8	0.00
Thierry Mine LV	4.3	4.3	0.00	4.3	0.00	4.5	4.65	4.5	4.65	4.3	0.00	4.3	0.00
Cat Lake LV	29.3	29.3	0.00	29.3	0.00	30.2	3.07	29.4	0.34	29.3	0.00	29.3	0.00
Slate Falls LV	24.4	24.4	0.00	24.4	0.00	25.1	2.87	25.1	2.87	24.4	0.00	24.4	0.00
Ear Falls LV	45.8	45.8	0.00	45.8	0.00	47.3	3.28	47.2	3.06	45.8	0.00	45.8	0.00
Domtar Dryden LV	13.9	14	0.72	14	0.72	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Perrault Falls LV	11.6	11.6	0.00	11.6	0.00	11.6	0.00	11.6	0.00	11.6	0.00	11.6	0.00
Sam Lake LV	26.4	26.7	1.14	26.7	1.14	26.5	0.38	26.5	0.38	26.4	0.00	26.4	0.00
Balmer LV	44.1	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	47	0.21	47	0.21	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Sandy Lake LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Eton DS LV	13.2	13.3	0.76	13.3	0.76	13.3	0.76	13.3	0.76	13.2	0.00	13.2	0.00
Vermillion Bay DS LV	15.2	15.3	0.66	15.3	0.66	15.3	0.66	15.3	0.66	15.2	0.00	15.2	0.00
Burleigh DS LV	13.2	13.3	0.76	13.3	0.76	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00
Fort Frances MS1 LV	14.2	14.4	1.41	14.4	1.41	14.3	0.70	14.3	0.70	14.2	0.00	14.2	0.00
Fort Frances MS2 LV	12.6	12.7	0.79	12.7	0.79	12.6	0.00	12.5	-0.79	12.6	0.00	12.6	0.00
Fort Frances L5	14.4	14.6	1.39	14.6	1.39	14.5	0.69	14.5	0.69	14.4	0.00	14.4	0.00
Fort Frances L4A	14.1	14.3	1.42	14.3	1.42	14.2	0.71	14.2	0.71	14.1	0.00	14.1	0.00
Fort Frances L4B	14.9	15.1	1.34	15.1	1.34	15	0.67	14.9	0.00	14.9	0.00	14.9	0.00
Fort Frances AB	6.9	7	1.45	7	1.45	6.9	0.00	6.9	0.00	6.9	0.00	6.9	0.00

Table 49: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	245	0.00	245	0.00	0	N/A	0	N/A	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	244.3	244.1	-0.08	244.2	-0.04	241.3	-1.23	239.8	-1.84	240.3	-1.64	239.2	-2.09	242.4	-0.78	242.7	-0.65	243.4	-0.37	243.1	-0.49
Dryden 230 kV	242.9	243.6	0.29	243.8	0.37	241.1	-0.74	238	-2.02	238.8	-1.69	236.8	-2.51	239.2	-1.52	236.6	-2.59	242.6	-0.12	241.7	-0.49
Fort Frances 230 kV	242.9	243.6	0.29	243.8	0.37	241.1	-0.74	238	-2.02	238.8	-1.69	236.8	-2.51	239.2	-1.52	236.6	-2.59	242.6	-0.12	241.7	-0.49
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Lakehead 230 kV	246.6	242.8	-1.54	242.3	-1.74	246.1	-0.20	246.3	-0.12	247.8	0.49	247.6	0.41	246.1	-0.20	246.1	-0.20	246.3	-0.12	246.3	-0.12
Pickle Lake 115 kV	126.1	126.1	0.00	126.1	0.00	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Dryden 115 kV	125.1	123.8	-1.04	123.9	-0.96	122.3	-2.24	123.9	-0.96	121.5	-2.88	123.6	-1.20	121.7	-2.72	123.4	-1.36	123.3	-1.44	124.4	-0.56
Fort Frances 115 kV	120.1	120.2	0.08	120.3	0.17	118.8	-1.08	118.9	-1.00	116.9	-2.66	118.4	-1.42	120	-0.08	120.1	0.00	119.9	-0.17	119.9	-0.17
Mackenzie 115 kV	122.8	119.8	-2.44	121.2	-1.30	121.2	-1.30	121.4	-1.14	121	-1.47	121.1	-1.38	120.9	-1.55	121.1	-1.38	121.1	-1.38	121.3	-1.22
Moose Lake 115 kV	122.9	119.7	-2.60	120.8	-1.71	121.1	-1.46	121.3	-1.30	120.9	-1.63	121	-1.55	121	-1.55	121.2	-1.38	121.3	-1.30	121.5	-1.14
Birch 115 kV	124.9	122.6	-1.84	122.6	-1.84	122.9	-1.60	123.1	-1.44	125.3	0.32	125.3	0.32	124.5	-0.32	124.5	-0.32	124.6	-0.24	124.6	-0.24
Valora Jct 115 kV	124.1	121.8	-1.85	122.4	-1.37	120.6	-2.82	121.6	-2.01	120.2	-3.14	121.2	-2.34	121.1	-2.42	122.1	-1.61	122.3	-1.45	122.9	-0.97
Esker 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.3	126.3	0.00	126.3	0.00	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Neskatanga 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Webequie 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
McFaulds 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	126.3	126.3	0.00	126.3	0.00	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Wapekeka 115 kV	125.6	125.6	0.00	125.6	0.00	0	N/A	0	N/A	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00
North Caribou Lake 115 kV	126.8	126.8	0.00	126.8	0.00	0	N/A	0	N/A	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Muskkrat Dam 115 kV	126.5	126.5	0.00	126.5	0.00	0	N/A	0	N/A	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00
Crow River 115 kV	126.1	126.1	0.00	126.1	0.00	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Thierry Mine 115 kV	125.7	125.7	0.00	125.7	0.00	0	N/A	0	N/A	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00
Cat Lake 115 kV	127.3	127.3	0.00	127.3	0.00	0	N/A	0	N/A	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00
Slate Falls 115 kV	128.2	128.2	0.00	128.2	0.00	0	N/A	0	N/A	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	124.9	123.6	-1.04	123.7	-0.96	122	-2.32	123.6	-1.04	121.3	-2.88	123.4	-1.20	121.5	-2.72	123.2	-1.36	123.1	-1.44	124.2	-0.56
Perrault Falls 115 kV	123.3	122.8	-0.41	122.8	-0.41	122.2	-0.89	122.8	-0.41	122	-1.05	122.7	-0.49	122	-1.05	122.7	-0.49	122.2	-0.89	122.6	-0.57
Sam Lake 115 kV	123.5	122.2	-1.05	122.3	-0.97	120.7	-2.27	122.3	-0.97	119.9	-2.91	122	-1.21	120.1	-2.75	121.8	-1.38	121.7	-1.46	122.8	-0.57

Table 49: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Balmer 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	120.7	0.00	120.7	0.00	120.7	0.00	120.8	0.08	120.7	0.00	120.8	0.08	120.7	0.00	120.8	0.08	120.7	0.00	120.8	0.08
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.5	0.08	120.4	0.00	120.5	0.08
Sandy Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Vermillion Bay DS 115 kV	124.4	123.8	-0.48	123.9	-0.40	122.3	-1.69	123.7	-0.56	121.8	-2.09	123.6	-0.64	121.9	-2.01	123.2	-0.96	123.4	-0.80	124.1	-0.24
Agimak DS 115 kV	123.8	121.5	-1.86	122.1	-1.37	120.3	-2.83	121.2	-2.10	119.8	-3.23	120.9	-2.34	120.8	-2.42	121.8	-1.62	122	-1.45	122.6	-0.97
Mattabi CTS 115 kV	124.1	121.8	-1.85	122.4	-1.37	120.6	-2.82	121.6	-2.01	120.2	-3.14	121.2	-2.34	121.1	-2.42	122.1	-1.61	122.3	-1.45	122.9	-0.97
Valora DS 115 kV	124.1	121.8	-1.85	122.4	-1.37	120.6	-2.82	121.6	-2.01	120.2	-3.14	121.2	-2.34	121.1	-2.42	122.1	-1.61	122.3	-1.45	122.9	-0.97
Murillo DS 115 kV	124.2	121.3	-2.33	121.2	-2.42	122.4	-1.45	122.6	-1.29	124.5	0.24	124.4	0.16	123.6	-0.48	123.7	-0.40	123.8	-0.32	123.8	-0.32
Shabaqua DS 115 kV	123.6	119.4	-3.40	119.5	-3.32	122.2	-1.13	122.4	-0.97	123.4	-0.16	123.4	-0.16	122.7	-0.73	122.8	-0.65	123	-0.49	123	-0.49
Sapawe DS 115 kV	123	119	-3.25	119.9	-2.52	121.4	-1.30	121.6	-1.14	121.3	-1.38	121.4	-1.30	121.2	-1.46	121.4	-1.30	121.6	-1.14	121.7	-1.06
West Coast 115 kV	119.9	120	0.08	120.1	0.17	118.6	-1.08	118.8	-0.92	116.7	-2.67	118.3	-1.33	119.8	-0.08	119.9	0.00	119.8	-0.08	119.8	-0.08
Fort Frances MS 115 kV	120.1	120.2	0.08	120.3	0.17	118.7	-1.17	118.9	-1.00	116.9	-2.66	118.4	-1.42	120	-0.08	120	-0.08	119.9	-0.17	119.9	-0.17
Burleigh DS 115 kV	120	120.1	0.08	120.2	0.17	118.7	-1.08	118.9	-0.92	116.8	-2.67	118.4	-1.33	119.9	-0.08	120	0.00	119.9	-0.08	119.9	-0.08

Table 50: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	0	N/A	0	N/A	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	244.3	244.3	0.00	244.6	0.12	243.8	-0.20	244.7	0.16	238.7	-2.29	239.2	-2.09
Dryden 230 kV	242.9	245	0.86	245	0.86	245	0.86	245	0.86	239.4	-1.44	239.5	-1.40
Fort Frances 230 kV	242.9	245	0.86	245	0.86	245	0.86	245	0.86	239.4	-1.44	239.5	-1.40
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	253.9	3.63	255.7	4.37
Lakehead 230 kV	246.6	248.9	0.93	248.9	0.93	248.9	0.93	248.9	0.93	253	2.60	253.3	2.72
Pickle Lake 115 kV	126.1	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Dryden 115 kV	125.1	125.1	0.00	123.7	-1.12	125	-0.08	123.6	-1.20	122.5	-2.08	124.2	-0.72
Fort Frances 115 kV	120.1	118.8	-1.08	120.1	0.00	118	-1.75	119.8	-0.25	114.3	-4.83	119.2	-0.75
Mackenzie 115 kV	122.8	121.7	-0.90	121.6	-0.98	121.5	-1.06	121.4	-1.14	125.1	1.87	121.3	-1.22
Moose Lake 115 kV	122.9	122.2	-0.57	122	-0.73	122.1	-0.65	121.8	-0.90	125.3	1.95	121.8	-0.90
Birch 115 kV	124.9	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	126.4	1.20	126.4	1.20
Valora Jct 115 kV	124.1	125.1	0.81	124.3	0.16	125.1	0.81	124.2	0.08	122.7	-1.13	122.7	-1.13
Esker 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Musslewhite 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.3	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Neskatanga 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Webequie 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
McFaulds 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	126.3	0	N/A	0	N/A	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Wapekeka 115 kV	125.6	0	N/A	0	N/A	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00
North Caribou Lake 115 kV	126.8	0	N/A	0	N/A	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Muskrat Dam 115 kV	126.5	0	N/A	0	N/A	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00
Crow River 115 kV	126.1	0	N/A	0	N/A	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Thierry Mine 115 kV	125.7	0	N/A	0	N/A	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00
Cat Lake 115 kV	127.3	0	N/A	0	N/A	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00
Slate Falls 115 kV	128.2	0	N/A	0	N/A	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	125.7	0.24	124.7	-0.56	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	124.9	124.9	0.00	123.5	-1.12	124.8	-0.08	123.3	-1.28	122.3	-2.08	124	-0.72
Perrault Falls 115 kV	123.3	123.3	0.00	122.8	-0.41	125.6	1.87	124.5	0.97	122.3	-0.81	122.9	-0.32
Sam Lake 115 kV	123.5	123.6	0.08	122.2	-1.05	123.4	-0.08	122	-1.21	120.9	-2.11	122.6	-0.73
Balmer 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	0	N/A	0	N/A	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	120.7	0.00	120.7	0.00	0	N/A	0	N/A	120.7	0.00	120.7	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	0	N/A	0	N/A	120.4	0.00	120.4	0.00

Table 50: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Sandy Lake 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00
Vermillion Bay DS 115 kV	124.4	124.7	0.24	123.8	-0.48	124.6	0.16	123.7	-0.56	121.9	-2.01	123.8	-0.48
Agimak DS 115 kV	123.8	124.8	0.81	124	0.16	124.7	0.73	123.9	0.08	0	N/A	0	N/A
Mattabi CTS 115 kV	124.1	125.1	0.81	124.3	0.16	125.1	0.81	124.2	0.08	0	N/A	0	N/A
Valora DS 115 kV	124.1	125.1	0.81	124.3	0.16	125.1	0.81	124.2	0.08	0	N/A	0	N/A
Murillo DS 115 kV	124.2	124.7	0.40	124.7	0.40	124.7	0.40	124.7	0.40	126.1	1.53	125.8	1.29
Shabaqua DS 115 kV	123.6	125.8	1.78	125.8	1.78	125.8	1.78	125.8	1.78	126.3	2.18	125.2	1.29
Sapawe DS 115 kV	123	127.5	3.66	127.5	3.66	127.5	3.66	127.5	3.66	125.7	2.20	122.6	-0.33
West Coast 115 kV	119.9	118.6	-1.08	119.9	0.00	117.9	-1.67	119.7	-0.17	114.2	-4.75	119.1	-0.67
Fort Frances MS 115 kV	120.1	118.8	-1.08	120.1	0.00	118	-1.75	119.8	-0.25	114.3	-4.83	119.2	-0.75
Burleigh DS 115 kV	120	118.7	-1.08	120	0.00	118	-1.67	119.8	-0.17	114.3	-4.75	119.2	-0.67

Table 51: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of Dryden Cap				Loss of 1 Neskantanga Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Webequie Cap				Loss of Mackenzie SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	244.3	243.1	-0.49	243	-0.53	241.3	-1.23	240.3	-1.64	243.7	-0.25	243.7	-0.25	243.7	-0.25	243.7	-0.25	243.7	-0.25	243.7	-0.25	240.7	-1.47	239.8	-1.84
Dryden 230 kV	242.9	242.1	-0.33	241.6	-0.54	238	-2.02	236.3	-2.72	243.4	0.21	243.4	0.21	243.4	0.21	243.4	0.21	243.4	0.21	243.4	0.21	239.1	-1.56	237.6	-2.18
Fort Frances 230 kV	242.9	242.1	-0.33	241.6	-0.54	238	-2.02	236.3	-2.72	243.4	0.21	243.4	0.21	243.4	0.21	243.4	0.21	243.4	0.21	243.4	0.21	239.1	-1.56	237.6	-2.18
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	237.7	-2.98	237	-3.27
Lakehead 230 kV	246.6	246.5	-0.04	246.5	-0.04	246.4	-0.08	246.5	-0.04	246.5	-0.04	246.5	-0.04	246.5	-0.04	246.5	-0.04	246.5	-0.04	246.5	-0.04	243.8	-1.14	243.9	-1.09
Pickle Lake 115 kV	126.1	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Dryden 115 kV	125.1	122.8	-1.84	124.1	-0.80	121.5	-2.88	123.7	-1.12	123.8	-1.04	123.8	-1.04	123.8	-1.04	123.8	-1.04	123.8	-1.04	123.8	-1.04	121.7	-2.72	124.1	-0.80
Fort Frances 115 kV	120.1	119.9	-0.17	119.9	-0.17	119.5	-0.50	119.6	-0.42	120	-0.08	120	-0.08	120	-0.08	120	-0.08	120	-0.08	120	-0.08	118	-1.75	118.2	-1.58
Mackenzie 115 kV	122.8	121.1	-1.38	121.3	-1.22	121	-1.47	121.2	-1.30	121.2	-1.30	121.2	-1.30	121.2	-1.30	121.2	-1.30	121.2	-1.30	121.2	-1.30	117.9	-3.99	120.7	-1.71
Moose Lake 115 kV	122.9	121.3	-1.30	121.5	-1.14	121.1	-1.46	121.4	-1.22	121.5	-1.14	121.5	-1.14	121.5	-1.14	121.5	-1.14	121.5	-1.14	121.5	-1.14	118.3	-3.74	120.9	-1.63
Birch 115 kV	124.9	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	124.7	-0.16	123.3	-1.28	123.6	-1.04
Valora Jct 115 kV	124.1	122.1	-1.61	122.9	-0.97	121.4	-2.18	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	119.9	-3.38	122.5	-1.29
Esker 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120.1	0.08	120	0.00	120	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.3	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Neskantanga 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Webequie 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	119.3	-0.58	119.3	-0.58	120	0.00	120	0.00
McFaulds 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	126.3	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00
Wapekeka 115 kV	125.6	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00	125.6	0.00
North Caribou Lake 115 kV	126.8	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Muskrat Dam 115 kV	126.5	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00	126.5	0.00
Crow River 115 kV	126.1	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Thierry Mine 115 kV	125.7	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00	125.7	0.00
Cat Lake 115 kV	127.3	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00	127.3	0.00
Slate Falls 115 kV	128.2	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Ear Falls 115 kV	125.4	120.9	-3.59	122.1	-2.63	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	124.9	122.6	-1.84	123.9	-0.80	121.3	-2.88	123.5	-1.12	123.6	-1.04	123.6	-1.04	123.6	-1.04	123.6	-1.04	123.6	-1.04	123.6	-1.04	121.5	-2.72	123.9	-0.80
Perrault Falls 115 kV	123.3	119.2	-3.33	120.7	-2.11	121.9	-1.14	122.8	-0.41	122.8	-0.41	122.8	-0.41	122.8	-0.41	122.8	-0.41	122.8	-0.41	122.8	-0.41	122	-1.05	122.9	-0.32
Sam Lake 115 kV	123.5	121.2	-1.86	122.6	-0.73	119.9	-2.91	122.1	-1.13	122.3	-0.97	122.3	-0.97	122.3	-0.97	122.3	-0.97	122.3	-0.97	122.2	-1.05	120.1	-2.75	122.6	-0.73
Balmer 115 kV	120	115	-4.17	116.6	-2.83	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	115.6	-4.07	117.2	-2.74	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	115.9	-3.98	117.6	-2.57	120.7	0.00	120.8	0.08	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.8	0.08
Deer Lake 115 kV	120.4	115.9	-3.74	117.7	-2.24	120.4	0.00	120.5	0.08	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00

Table 51: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of 1 Ear Falls SVC				Loss of Dryden Cap				Loss of 1 Neskatanga Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Webequie Cap				Loss of Mackenzie SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Sandy Lake 115 kV	120	115.6	-3.67	117.4	-2.17	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Vermillion Bay DS 115 kV	124.4	123	-1.13	124	-0.32	121.9	-2.01	123.7	-0.56	123.8	-0.48	123.8	-0.48	123.8	-0.48	123.8	-0.48	123.8	-0.48	123.8	-0.48	121.9	-2.01	123.9	-0.40
Agimak DS 115 kV	123.8	121.8	-1.62	122.6	-0.97	121.1	-2.18	122.3	-1.21	122.4	-1.13	122.4	-1.13	122.4	-1.13	122.4	-1.13	122.4	-1.13	122.4	-1.13	119.6	-3.39	122.1	-1.37
Mattabi CTS 115 kV	124.1	122.1	-1.61	122.9	-0.97	121.4	-2.18	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	119.9	-3.38	122.5	-1.29
Valora DS 115 kV	124.1	122.1	-1.61	122.9	-0.97	121.4	-2.18	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	122.7	-1.13	119.9	-3.38	122.5	-1.29
Murillo DS 115 kV	124.2	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	123.9	-0.24	122.4	-1.45	122.8	-1.13
Shabaqua DS 115 kV	123.6	123.1	-0.40	123.1	-0.40	123	-0.49	123.1	-0.40	123.1	-0.40	123.1	-0.40	123.1	-0.40	123.1	-0.40	123.1	-0.40	123.1	-0.40	121.1	-2.02	122.1	-1.21
Sapawe DS 115 kV	123	121.6	-1.14	121.7	-1.06	121.4	-1.30	121.7	-1.06	121.7	-1.06	121.7	-1.06	121.7	-1.06	121.7	-1.06	121.7	-1.06	121.7	-1.06	118.7	-3.50	121	-1.63
West Coast 115 kV	119.9	119.7	-0.17	119.8	-0.08	119.3	-0.50	119.5	-0.33	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	117.8	-1.75	118	-1.58
Fort Frances MS 115 kV	120.1	119.9	-0.17	119.9	-0.17	119.5	-0.50	119.6	-0.42	120	-0.08	120	-0.08	120	-0.08	120	-0.08	120	-0.08	120	-0.08	118	-1.75	118.2	-1.58
Burleigh DS 115 kV	120	119.8	-0.17	119.9	-0.08	119.4	-0.50	119.6	-0.33	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	117.9	-1.75	118.1	-1.58

Table 52: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Pickle Lake 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Kenora 230 kV	245.4	247.4	0.81	247.4	0.81	245.4	0.00	245.4	0.00	245.4	0.00	245.4	0.00
Dryden 230 kV	246.7	250	1.34	250	1.34	246.7	0.00	246.7	0.00	246.7	0.00	246.7	0.00
Fort Frances 230 kV	246.7	250	1.34	250	1.34	246.7	0.00	246.7	0.00	246.7	0.00	246.7	0.00
Mackenzie 230 kV	242.4	248.8	2.64	248.8	2.64	242.4	0.00	242.4	0.00	242.4	0.00	242.4	0.00
Lakehead 230 kV	238	240.4	1.01	240.4	1.01	238	0.00	238	0.00	238	0.00	238	0.00
Pickle Lake 115 kV	125.4	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Dryden 115 kV	124.9	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00
Fort Frances 115 kV	120	121.2	1.00	121.2	1.00	120	0.00	120	0.00	120	0.00	120	0.00
Mackenzie 115 kV	122	121.5	-0.41	121.5	-0.41	122	0.00	122	0.00	122	0.00	122	0.00
Moose Lake 115 kV	122.4	121.9	-0.41	121.9	-0.41	122.4	0.00	122.4	0.00	122.4	0.00	122.4	0.00
Birch 115 kV	122.8	122.5	-0.24	122.5	-0.24	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00
Valora Jct 115 kV	125	124.8	-0.16	124.8	-0.16	125	0.00	125	0.00	125	0.00	125	0.00
Esker 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Neskatanga 115 kV	123.9	123.9	0.00	123.9	0.00	123.9	0.00	123.9	0.00	123.9	0.00	123.9	0.00
Webequie 115 kV	121.8	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00
McFaulds 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Kingfisher Lake 115 kV	128.3	128.3	0.00	128.3	0.00	128.3	0.00	128.3	0.00	128.3	0.00	128.3	0.00
Wapekeka 115 kV	128.9	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00
North Caribou Lake 115 kV	129.7	129.7	0.00	129.7	0.00	129.7	0.00	129.7	0.00	129.7	0.00	129.7	0.00
Muskkrat Dam 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Crow River 115 kV	125.4	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Thierry Mine 115 kV	125.4	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Cat Lake 115 kV	128.3	128.3	0.00	128.3	0.00	128.3	0.00	128.3	0.00	128.3	0.00	128.3	0.00
Slate Falls 115 kV	130.2	130.2	0.00	130.2	0.00	130.2	0.00	130.2	0.00	130.2	0.00	130.2	0.00
Ear Falls 115 kV	122.8	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00
Domtar Dryden 115 kV	124.9	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00
Perrault Falls 115 kV	122.7	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00
Sam Lake 115 kV	124.4	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00
Balmer 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	123.8	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00
Deer Lake 115 kV	126	126	0.00	126	0.00	126	0.00	126	0.00	126	0.00	126	0.00

Table 52: HV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Sandy Lake 115 kV	126.1	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00
Vermillion Bay DS 115 kV	125	125.1	0.08	125.1	0.08	125	0.00	125	0.00	125	0.00	125	0.00
Agimak DS 115 kV	124.6	124.3	-0.24	124.3	-0.24	124.6	0.00	124.6	0.00	124.6	0.00	124.6	0.00
Mattabi CTS 115 kV	125	124.8	-0.16	124.8	-0.16	125	0.00	125	0.00	125	0.00	125	0.00
Valora DS 115 kV	125	124.8	-0.16	124.8	-0.16	125	0.00	125	0.00	125	0.00	125	0.00
Murillo DS 115 kV	122.6	122.3	-0.24	122.3	-0.24	122.6	0.00	122.6	0.00	122.6	0.00	122.6	0.00
Shabaqua DS 115 kV	122.9	122.6	-0.24	122.6	-0.24	122.9	0.00	122.9	0.00	122.9	0.00	122.9	0.00
Sapawe DS 115 kV	122.7	122.2	-0.41	122.2	-0.41	122.7	0.00	122.7	0.00	122.7	0.00	122.7	0.00
West Coast 115 kV	120	121.1	0.92	121.1	0.92	120	0.00	120	0.00	120	0.00	120	0.00
Fort Frances MS 115 kV	120	121.2	1.00	121.2	1.00	120	0.00	120	0.00	120	0.00	120	0.00
Burleigh DS 115 kV	120	121.2	1.00	121.2	1.00	120	0.00	120	0.00	120	0.00	120	0.00

Table 53: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.9	24.3	-2.41	24.9	0.00	24.6	-1.20	24.9	0.00	25	0.40	24.8	-0.40	24.8	-0.40	24.8	-0.40	24.9	0.00	24.9	0.00
Shabaqua DS LV	13.2	12.8	-3.03	12.8	-3.03	13.1	-0.76	13.1	-0.76	13.2	0.00	13.1	-0.76	13.1	-0.76	13.1	-0.76	13.2	0.00	13.2	0.00
Sapawe DS LV	13.9	13.4	-3.60	13.5	-2.88	13.7	-1.44	13.7	-1.44	13.7	-1.44	13.7	-1.44	13.7	-1.44	13.7	-1.44	13.7	-1.44	13.7	-1.44
Mattabi DS LV	4.2	4.2	0.00	4.2	0.00	4.1	-2.38	4.2	0.00	4.1	-2.38	4.1	-2.38	4.1	-2.38	4.2	0.00	4.2	0.00	4.2	0.00
Agimak DS LV	26.2	26	-0.76	26.5	1.15	25.8	-1.53	26.3	0.38	25.7	-1.91	25.9	-1.15	25.9	-1.15	26.4	0.76	26.2	0.00	26.3	0.38
Valora DS LV	25.8	25.3	-1.94	25.4	-1.55	25	-3.10	25.2	-2.33	25	-3.10	25.2	-2.33	25.2	-2.33	25.4	-1.55	25.4	-1.55	25.5	-1.16
Esker LV	13.9	13.9	0.00	13.9	0.00	0	N/A	0	N/A	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	0	N/A	0	N/A	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.9	27.9	0.00	27.9	0.00	0	N/A	0	N/A	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Webequie LV	22.6	22.6	0.00	22.6	0.00	0	N/A	0	N/A	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00
McFaulds LV	46	46	0.00	46	0.00	0	N/A	0	N/A	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00
King Fisher Lake LV	25.2	25.2	0.00	25.2	0.00	0	N/A	0	N/A	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00
Wapekeka LV	27.8	27.8	0.00	27.8	0.00	0	N/A	0	N/A	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24	24	0.00	24	0.00	0	N/A	0	N/A	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00
Muskrat LV	28	28	0.00	28	0.00	0	N/A	0	N/A	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.5	27.5	0.00	27.5	0.00	0	N/A	0	N/A	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Thierry Mine LV	4.5	4.5	0.00	4.5	0.00	0	N/A	0	N/A	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	29.4	0.00	29.4	0.00	0	N/A	0	N/A	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24.7	24.7	0.00	24.7	0.00	0	N/A	0	N/A	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Ear Falls LV	46.3	46.3	0.00	46.3	0.00	0	N/A	0	N/A	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Domtar Dryden LV	13.8	13.6	-1.45	13.6	-1.45	13.5	-2.17	13.6	-1.45	13.4	-2.90	13.4	-2.90	13.4	-2.90	13.6	-1.45	13.6	-1.45	13.7	-0.72
Perrault Falls LV	11.6	11.5	-0.86	11.5	-0.86	11.5	-0.86	11.5	-0.86	11.4	-1.72	11.4	-1.72	11.4	-1.72	11.5	-0.86	11.4	-1.72	11.5	-0.86
Sam Lake LV	26.4	26.3	-0.38	26.3	-0.38	26	-1.52	26.5	0.38	25.8	-2.27	25.8	-2.27	25.8	-2.27	26.6	0.76	26.2	-0.76	26.6	0.76
Balmer LV	44.1	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Sandy Lake LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Eton DS LV	13.2	13.2	0.00	13.2	0.00	13	-1.52	13.3	0.76	13	-1.52	13	-1.52	13	-1.52	13.3	0.76	13.1	-0.76	13.4	1.52
Vermillion Bay DS LV	15.2	15.1	-0.66	15.2	0.00	15	-1.32	15.1	-0.66	14.9	-1.97	14.9	-1.97	14.9	-1.97	15.1	-0.66	15.1	-0.66	15.2	0.00
Burleigh DS LV	13.2	13.3	0.76	13.3	0.76	13.1	-0.76	13.1	-0.76	12.9	-2.27	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00
Fort Frances MS1 LV	14.3	14.3	0.00	14.3	0.00	14.1	-1.40	14.2	-0.70	13.9	-2.80	14.3	0.00	14.3	0.00	14.3	0.00	14.3	0.00	14.3	0.00
Fort Frances MS2 LV	12.5	12.5	0.00	12.5	0.00	12.3	-1.60	12.5	0.00	12.1	-3.20	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00
Fort Frances L5	14.4	14.4	0.00	14.4	0.00	14.2	-1.39	14.2	-1.39	13.9	-3.47	14.3	-0.69	14.3	-0.69	14.4	0.00	14.3	-0.69	14.3	-0.69
Fort Frances L4A	14.2	14.2	0.00	14.2	0.00	14	-1.41	14.1	-0.70	13.8	-2.82	14.2	0.00	14.2	0.00	14.2	0.00	14.2	0.00	14.2	0.00
Fort Frances L4B	15	15	0.00	15.1	0.67	14.9	-0.67	14.9	-0.67	14.6	-2.67	15	0.00	15	0.00	15	0.00	15	0.00	15	0.00
Fort Frances AB	6.8	6.8	0.00	6.8	0.00	6.7	-1.47	6.8	0.00	6.6	-2.94	6.8	0.00	6.8	0.00	6.8	0.00	6.8	0.00	6.8	0.00

Table 54: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.9	25	0.40	25	0.40	25	0.40	25	0.40	25.3	1.61	25.1	0.80
Shabaqua DS LV	13.2	13.5	2.27	13.5	2.27	13.5	2.27	13.5	2.27	13.5	2.27	13.4	1.52
Sapawe DS LV	13.9	14.4	3.60	14.4	3.60	14.4	3.60	14.4	3.60	14.2	2.16	13.9	0.00
Mattabi DS LV	4.2	4.3	2.38	4.3	2.38	4.3	2.38	4.3	2.38	0	N/A	0	N/A
Agimak DS LV	26.2	26.8	2.29	26.6	1.53	26.7	1.91	26.6	1.53	0	N/A	0	N/A
Valora DS LV	25.8	26	0.78	25.8	0.00	26	0.78	25.8	0.00	0	N/A	0	N/A
Esker LV	13.9	0	N/A	0	N/A	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	0	N/A	0	N/A	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanganga LV	27.9	0	N/A	0	N/A	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Webequie LV	22.6	0	N/A	0	N/A	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00
McFaulds LV	46	0	N/A	0	N/A	46	0.00	46	0.00	46	0.00	46	0.00
King Fisher Lake LV	25.2	0	N/A	0	N/A	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00
Wapekeka LV	27.8	0	N/A	0	N/A	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24	0	N/A	0	N/A	24	0.00	24	0.00	24	0.00	24	0.00
Muskrat LV	28	0	N/A	0	N/A	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.5	0	N/A	0	N/A	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Thierry Mine LV	4.5	0	N/A	0	N/A	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	0	N/A	0	N/A	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Ear Falls LV	46.3	0	N/A	0	N/A	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Domtar Dryden LV	13.8	13.8	0.00	13.6	-1.45	13.8	0.00	13.6	-1.45	13.5	-2.17	13.7	-0.72
Perrault Falls LV	11.6	11.6	0.00	11.5	-0.86	11.8	1.72	11.7	0.86	11.5	-0.86	11.5	-0.86
Sam Lake LV	26.4	26.6	0.76	26.5	0.38	26.6	0.76	26.5	0.38	26	-1.52	26.6	0.76
Balmer LV	44.1	44.1	0.00	44.1	0.00	0	N/A	0	N/A	44.1	0.00	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	0	N/A	0	N/A	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	0	N/A	0	N/A	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	27.8	0.00	27.8	0.00	0	N/A	0	N/A	27.8	0.00	27.8	0.00
Sandy Lake LV	27.8	27.8	0.00	27.8	0.00	0	N/A	0	N/A	27.9	0.36	27.8	0.00
Eton DS LV	13.2	13.3	0.76	13.3	0.76	13.3	0.76	13.3	0.76	13	-1.52	13.3	0.76
Vermillion Bay DS LV	15.2	15.3	0.66	15.1	-0.66	15.2	0.00	15.1	-0.66	14.9	-1.97	15.1	-0.66
Burleigh DS LV	13.2	13.1	-0.76	13.2	0.00	13	-1.52	13.2	0.00	12.6	-4.55	13.1	-0.76
Fort Frances MS1 LV	14.3	14.1	-1.40	14.3	0.00	14	-2.10	14.3	0.00	13.6	-4.90	14.2	-0.70
Fort Frances MS2 LV	12.5	12.3	-1.60	12.5	0.00	12.2	-2.40	12.5	0.00	11.9	-4.80	12.5	0.00
Fort Frances L5	14.4	14.2	-1.39	14.4	0.00	14.1	-2.08	14.3	-0.69	13.6	-5.56	14.2	-1.39
Fort Frances L4A	14.2	14.1	-0.70	14.2	0.00	14	-1.41	14.2	0.00	13.5	-4.93	14.1	-0.70
Fort Frances L4B	15	14.9	-0.67	15	0.00	14.8	-1.33	15	0.00	14.3	-4.67	14.9	-0.67
Fort Frances AB	6.8	6.7	-1.47	6.8	0.00	6.7	-1.47	6.8	0.00	6.5	-4.41	6.8	0.00

Table 55: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of Dryden Cap				Loss of 1 Neskatanga Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Webequie Cap				Loss of Mackenzie SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	25	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.9	-0.40	24.6	-1.60	25	0.00
Shabaqua DS LV	13.2	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13	-1.52	13.1	-0.76
Sapawe DS LV	13.7	13.7	0.00	13.8	0.73	13.7	0.00	13.7	0.00	13.8	0.73	13.8	0.73	13.8	0.73	13.8	0.73	13.8	0.73	13.8	0.73	13.4	-2.19	13.7	0.00
Mattabi DS LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.1	-2.38	4.2	0.00
Agimak DS LV	26.3	26.1	-0.76	26.6	1.14	25.9	-1.52	26.6	1.14	26.2	-0.38	26.2	-0.38	26.2	-0.38	26.2	-0.38	26.2	-0.38	26.2	-0.38	25.6	-2.66	26.5	0.76
Valora DS LV	25.6	25.4	-0.78	25.5	-0.39	25.2	-1.56	25.5	-0.39	25.5	-0.39	25.5	-0.39	25.5	-0.39	25.5	-0.39	25.5	-0.39	25.5	-0.39	24.9	-2.73	25.4	-0.78
Esker LV	13.9	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Webequie LV	22.6	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.6	0.00	22.4	-0.88	22.4	-0.88	22.6	0.00	22.6	0.00
McFaulds LV	46	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46	0.00	46.1	0.22	46.1	0.22	46	0.00	46	0.00
King Fisher Lake LV	25.2	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00	25.2	0.00
Wapekeka LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00	24	0.00
Muskkrat LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Thierry Mine LV	4.5	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Ear Falls LV	46.3	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Domtar Dryden LV	13.7	13.5	-1.46	13.7	0.00	13.4	-2.19	13.6	-0.73	13.6	-0.73	13.6	-0.73	13.6	-0.73	13.6	-0.73	13.6	-0.73	13.6	-0.73	13.4	-2.19	13.7	0.00
Perrault Falls LV	11.5	11.2	-2.61	11.3	-1.74	11.4	-0.87	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.5	0.00	11.4	-0.87	11.5	0.00
Sam Lake LV	26.4	26.1	-1.14	26.6	0.76	25.8	-2.27	26.7	1.14	26.3	-0.38	26.3	-0.38	26.3	-0.38	26.3	-0.38	26.3	-0.38	26.3	-0.38	25.8	-2.27	26.6	0.76
Balmer LV	44.1	42.2	-4.31	43.7	-0.91	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	44.9	-4.26	46.7	-0.43	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	26.8	-3.94	27.5	-1.43	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	26.7	-3.96	27.5	-1.08	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Sandy Lake LV	27.5	27.2	-1.09	28	1.82	27.9	1.45	27.8	1.09	27.8	1.09	27.8	1.09	27.8	1.09	27.8	1.09	27.8	1.09	27.8	1.09	27.9	1.45	27.8	1.09
Eton DS LV	13.2	13.1	-0.76	13.3	0.76	13	-1.52	13.4	1.52	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13	-1.52	13.3	0.76
Vermillion Bay DS LV	15.2	15	-1.32	15.2	0.00	14.9	-1.97	15.1	-0.66	15.1	-0.66	15.1	-0.66	15.1	-0.66	15.1	-0.66	15.1	-0.66	15.1	-0.66	14.9	-1.97	15.2	0.00
Burleigh DS LV	13.1	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13	-0.76	13	-0.76
Fort Frances MS1 LV	14.1	14.3	1.42	14.3	1.42	14.2	0.71	14.2	0.71	14.3	1.42	14.3	1.42	14.3	1.42	14.3	1.42	14.3	1.42	14.3	1.42	14	-0.71	14.1	0.00
Fort Frances MS2 LV	12.5	12.4	-0.80	12.4	-0.80	12.4	-0.80	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.2	-2.40	12.4	-0.80
Fort Frances L5	14.1	14.3	1.42	14.3	1.42	14.3	1.42	14.3	1.42	14.4	2.13	14.4	2.13	14.4	2.13	14.4	2.13	14.4	2.13	14.4	2.13	14.1	0.00	14.1	0.00
Fort Frances L4A	14	14.2	1.43	14.2	1.43	14.1	0.71	14.2	1.43	14.2	1.43	14.2	1.43	14.2	1.43	14.2	1.43	14.2	1.43	14.2	1.43	14	0.00	14	0.00
Fort Frances L4B	14.8	15	1.35	15	1.35	15	1.35	15	1.35	15	1.35	15	1.35	15	1.35	15	1.35	15	1.35	15	1.35	14.8	0.00	14.8	0.00
Fort Frances AB	6.7	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.8	1.49	6.7	0.00	6.7	0.00

Table 56: LV Voltage Assessment for Test Case 2 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont Volt (kV)	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	25.1	24.9	-0.80	24.9	-0.80	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00
Shabaqua DS LV	13.2	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00
Sapawe DS LV	13.9	13.8	-0.72	13.8	-0.72	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Mattabi DS LV	4.3	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00
Agimak DS LV	26.4	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00
Valora DS LV	26	26	0.00	26	0.00	26	0.00	26	0.00	26	0.00	26	0.00
Esker LV	13.7	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Webequie LV	23.7	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00
McFaulds LV	44.9	44.9	0.00	44.9	0.00	44.9	0.00	44.9	0.00	44.9	0.00	44.9	0.00
King Fisher Lake LV	25	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00	25	0.00
Wapekeka LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
North Caribou Lake LV	25.3	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00
Muskrat LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Crow River LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Thierry Mine LV	4.5	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00	4.5	0.00
Cat Lake LV	29.4	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	25.4	25.4	0.00	25.4	0.00	25.4	0.00	25.4	0.00	25.4	0.00	25.4	0.00
Ear Falls LV	47.8	47.8	0.00	47.8	0.00	47.8	0.00	47.8	0.00	47.8	0.00	47.8	0.00
Domtar Dryden LV	13.9	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Perrault Falls LV	11.7	11.7	0.00	11.7	0.00	11.7	0.00	11.7	0.00	11.7	0.00	11.7	0.00
Sam Lake LV	26.3	26.4	0.38	26.4	0.38	26.3	0.00	26.3	0.00	26.3	0.00	26.3	0.00
Balmer LV	44.1	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Sandy Lake LV	27.6	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00
Eton DS LV	13.2	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00
Vermillion Bay DS LV	15.3	15.3	0.00	15.3	0.00	15.3	0.00	15.3	0.00	15.3	0.00	15.3	0.00
Burleigh DS LV	13.3	13.4	0.75	13.4	0.75	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00
Fort Frances MS1 LV	14.3	14.5	1.40	14.5	1.40	14.3	0.00	14.3	0.00	14.3	0.00	14.3	0.00
Fort Frances MS2 LV	12.6	12.6	0.00	12.6	0.00	12.6	0.00	12.6	0.00	12.6	0.00	12.6	0.00
Fort Frances L5	14.5	14.7	1.38	14.7	1.38	14.5	0.00	14.5	0.00	14.5	0.00	14.5	0.00
Fort Frances L4A	14.3	14.4	0.70	14.4	0.70	14.3	0.00	14.3	0.00	14.3	0.00	14.3	0.00
Fort Frances L4B	15	15.2	1.33	15.2	1.33	15	0.00	15	0.00	15	0.00	15	0.00
Fort Frances AB	7	7	0.00	7	0.00	7	0.00	7	0.00	7	0.00	7	0.00

Appendix D: 115 kV Test Cases – Thermal Assessment Results

Table 57: Thermal Loading for Test Case 3 – Valora Junction with All Elements in-service – Single-Circuit Contingency

Circuit Name	Length (KM)	CONT Rating	LTE Rating	STE Rating	Pre-Cont		Loss of A21L		Loss of D26A		Loss of F25A		Loss of K23D		Loss of 1 Manitou Falls Unit	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	% LTE	(A)	% LTE	(A)	% LTE
B6M BixMU	14.5	440	440	450	239	54.32	356	80.91	260	59.09	238	54.09	243	55.23	242	55.00
B6M MUxST	7.9	430	430	430	197	45.81	313	72.79	217	50.47	195	45.35	201	46.74	200	46.51
B6M STxSH	33.5	470	470	470	195	41.49	311	66.17	215	45.74	194	41.28	199	42.34	198	42.13
B6M SHxIN	18.5	470	470	470	190	40.43	305	64.89	210	44.68	188	40.00	193	41.06	192	40.85
B6M INxKA	32.5	460	460	460	187	40.65	302	65.65	207	45.00	185	40.22	191	41.52	189	41.09
B6M KAxSA	58.9	430	430	430	187	43.49	302	70.23	207	48.14	185	43.02	190	44.19	189	43.95
B6M SAxCA	22.6	620	740	770	180	29.03	294	39.73	200	27.03	179	24.19	184	24.86	183	24.73
B6M CAxML	0.5	620	740	770	180	29.03	294	39.73	200	27.03	179	24.19	184	24.86	183	24.73
M2D MLxIG	76.7	550	550	550	456	82.91	456	82.91	680	123.64	546	99.27	471	85.64	463	84.18
M2D IGxDN	40.4	420	420	420	48	11.43	49	11.67	199	47.38	81	19.29	40	9.52	45	10.71
M2D DNxDR	40	420	420	420	48	11.43	49	11.67	199	47.38	81	19.29	40	9.52	45	10.71
29M1 IGxIG	1.1	320	400	460	462	144.38	461	115.25	479	119.75	470	117.50	466	116.50	463	115.75
29M1 IGxCL	18	500	500	500	461	92.20	460	92.00	478	95.60	469	93.80	464	92.80	462	92.40
29M1 CLxVA	51	500	500	500	454	90.80	453	90.60	472	94.40	463	92.60	458	91.60	455	91.00
E4D DRxSL	68.2	470	470	665	364	77.45	363	77.23	364	77.45	368	78.30	369	78.51	390	82.98
E4D SLxEF	30.2	470	470	665	354	75.32	353	75.11	354	75.32	357	75.96	359	76.38	380	80.85
E4D#2 DRxEF	98.4	470	470	470	363	77.23	362	77.02	362	77.02	367	78.09	368	78.30	389	82.77
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	298	70.95	298	70.95	298	70.95	298	70.95
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	312	74.29	312	74.29	313	74.52	313	74.52
E2R PAxHC	36.1	420	420	420	313	74.52	313	74.52	313	74.52	313	74.52	313	74.52	313	74.52
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	96	22.86	96	22.86	96	22.86	96	22.86
K3D DRxET	12	470	470	470	72	15.32	82	17.45	158	33.62	11	2.34	113	24.04	80	17.02
K3D ETxVB	27.9	470	470	470	78	16.60	89	18.94	164	34.89	3	0.64	119	25.32	86	18.30
K3D VBxRL	81.7	470	470	470	88	18.72	98	20.85	172	36.60	20	4.26	127	27.02	96	20.43
A21L	191.7	880	880	880	390	44.32	0	0.00	364	41.36	356	40.45	395	44.89	394	44.77
A22L	191.7	880	880	880	390	44.32	666	75.68	364	41.36	356	40.45	394	44.77	394	44.77
D26A MAXIG	93.4	880	880	880	361	41.02	322	36.59	0	0.00	539	61.25	390	44.32	367	41.70
D26A IGxDR	80.4	880	880	880	353	40.11	315	35.80	0	0.00	534	60.68	389	44.20	361	41.02
K23D KExVE	53.2	880	880	880	58	6.59	89	10.11	289	32.84	111	12.61	0	0.00	69	7.84
K23D VExDR	58.6	880	880	880	62	7.05	89	10.11	297	33.75	131	14.89	0	0.00	73	8.30
F25A	141.6	880	880	880	282	32.05	234	26.59	492	55.91	0	0.00	254	28.86	279	31.70

Table 58: Thermal Loading for Test Case 3 – Valora Junction with All Elements in-service – Double-Circuit Contingency

Circuit Name	Length (KM)	Cont Rating	LTE Rating	STE Rating	Pre-Cont		Loss of AxLs and Cross-Trip B6M + Pickle Lake Line		Loss of AxLs and Cross-Trip B6M + E2R Lines		Loss of D26A + F25A and Cross-Trip M2D	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	% LTE
B6M BlxMU	14.5	440	440	450	239	54.32	56	12.73	56	12.73	22	5.00
B6M MUxST	7.9	430	430	430	197	45.81	37	8.60	37	8.60	31	7.21
B6M STxSH	33.5	470	470	470	195	41.49	29	6.17	29	6.17	32	6.81
B6M SHxIN	18.5	470	470	470	190	40.43	31	6.60	31	6.60	38	8.09
B6M INxKA	32.5	460	460	460	187	40.65	19	4.13	19	4.13	41	8.91
B6M KAxSA	58.9	430	430	430	187	43.49	19	4.42	19	4.42	41	9.53
B6M SAxCA	22.6	620	740	770	180	29.03	0	0.00	0	0.00	52	7.03
B6M CAxML	0.5	620	740	770	180	29.03	0	0.00	0	0.00	52	7.03
M2D MLxIG	76.7	550	550	550	456	82.91	101	18.36	225	40.91	0	0.00
M2D IGxDN	40.4	420	420	420	48	11.43	72	17.14	235	55.95	0	0.00
M2D DNxDR	40	420	420	420	48	11.43	72	17.14	235	55.95	0	0.00
29M1 IGxIG	1.1	320	400	460	462	144.38	21	5.25	454	113.50	0	0.00
29M1 IGxCL	18	500	500	500	461	92.20	17	3.40	453	90.60	0	0.00
29M1 CLxVA	51	500	500	500	454	90.80	16	3.20	446	89.20	0	0.00
E4D DRxSL	68.2	470	470	665	364	77.45	364	77.45	48	10.21	363	77.23
E4D SLxEF	30.2	470	470	665	354	75.32	354	75.32	27	5.74	353	75.11
E4D#2 DRxEF	98.4	470	470	470	363	77.23	363	77.23	48	10.21	362	77.02
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	0	0.00	298	70.95
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	0	0.00	313	74.52
E2R PAxHC	36.1	420	420	420	313	74.52	313	74.52	0	0.00	313	74.52
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	0	0.00	96	22.86
K3D DRxET	12	470	470	470	72	15.32	133	28.30	73	15.53	180	38.30
K3D ETxVB	27.9	470	470	470	78	16.60	140	29.79	79	16.81	186	39.57
K3D VBxRL	81.7	470	470	470	88	18.72	148	31.49	87	18.51	193	41.06
A21L	191.7	880	880	880	390	44.32	0	0.00	0	0.00	50	5.68
A22L	191.7	880	880	880	390	44.32	0	0.00	0	0.00	50	5.68
D26A MAxIG	93.4	880	880	880	361	41.02	80	9.09	60	6.82	0	0.00
D26A IGxDR	80.4	880	880	880	353	40.11	75	8.52	25	2.84	0	0.00
K23D KExVE	53.2	880	880	880	58	6.59	272	30.91	192	21.82	355	40.34
K23D VExDR	58.6	880	880	880	62	7.05	260	29.55	176	20.00	355	40.34
F25A	141.6	880	880	880	282	32.05	108	12.27	92	10.45	0	0.00

Table 59: Thermal Loading for Test Case 4 – Dinorwic Junction with All Elements in-service – Single-Circuit Contingency

Circuit Name	Length (KM)	CONT Rating	LTE Rating	STE Rating	Pre-Cont		Loss of A21L		Loss of D26A		Loss of F25A		Loss of K23D		Loss of 1 Manitou Falls Unit	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	% LTE	(A)	(A)	(A)	(A)
B6M BixMU	14.5	440	440	450	226	51.36	344	78.18	248	56.36	224	50.91	229	52.05	228	51.82
B6M MUxST	7.9	430	430	430	184	42.79	300	69.77	205	47.67	182	42.33	187	43.49	186	43.26
B6M STxSH	33.5	470	470	470	182	38.72	299	63.62	204	43.40	180	38.30	185	39.36	185	39.36
B6M SHxIN	18.5	470	470	470	177	37.66	293	62.34	198	42.13	174	37.02	180	38.30	179	38.09
B6M INxKA	32.5	460	460	460	173	37.61	290	63.04	195	42.39	172	37.39	176	38.26	176	38.26
B6M KAxSA	58.9	430	430	430	173	40.23	290	67.44	195	45.35	172	40.00	176	40.93	176	40.93
B6M SAxCA	22.6	620	740	770	167	26.94	281	37.97	189	25.54	166	22.43	170	22.97	169	22.84
B6M CAxML	0.5	620	740	770	167	26.94	281	37.97	189	25.54	166	22.43	170	22.97	169	22.84
M2D MLxIG	76.7	550	550	550	352	64.00	352	64.00	590	107.27	444	80.73	362	65.82	359	65.27
M2D IGxDN	40.4	420	420	420	331	78.81	331	78.81	557	132.62	419	99.76	340	80.95	337	80.24
M2D DNxDR	40	420	420	420	173	41.19	173	41.19	297	70.71	200	47.62	183	43.57	173	41.19
29M1 IGxIG	1.1	320	400	460	29	9.06	29	7.25	67	16.75	42	10.50	24	6.00	30	7.50
29M1 IGxCL	18	500	500	500	25	5.00	25	5.00	63	12.60	38	7.60	20	4.00	26	5.20
29M1 CLxVA	51	500	500	500	24	4.80	25	5.00	64	12.80	39	7.80	19	3.80	26	5.20
E4D DRxSL	68.2	470	470	665	369	78.51	369	78.51	366	77.87	369	78.51	362	77.02	394	83.83
E4D SLxEF	30.2	470	470	665	359	76.38	359	76.38	356	75.74	358	76.17	352	74.89	383	81.49
E4D#2 DRxEF	98.4	470	470	470	368	78.30	368	78.30	365	77.66	368	78.30	361	76.81	393	83.62
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	298	70.95	297	70.71	298	70.95	298	70.95
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	313	74.52	312	74.29	312	74.29	313	74.52
E2R PAxHC	36.1	420	420	420	313	74.52	313	74.52	313	74.52	313	74.52	313	74.52	313	74.52
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	96	22.86	96	22.86	96	22.86	96	22.86
K3D DRxET	12	470	470	470	75	15.96	86	18.30	167	35.53	10	2.13	112	23.83	83	17.66
K3D ETxVB	27.9	470	470	470	82	17.45	92	19.57	173	36.81	5	1.06	119	25.32	90	19.15
K3D VBxRL	81.7	470	470	470	91	19.36	100	21.28	181	38.51	22	4.68	128	27.23	98	20.85
A21L	191.7	880	880	880	393	44.66	0	0.00	367	41.70	357	40.57	397	45.11	397	45.11
A22L	191.7	880	880	880	393	44.66	670	76.14	367	41.70	357	40.57	397	45.11	397	45.11
D26A MAXIG	93.4	880	880	880	391	44.43	352	40.00	0	0.00	583	66.25	420	47.73	398	45.23
D26A IGxDR	80.4	880	880	880	377	42.84	338	38.41	0	0.00	573	65.11	407	46.25	384	43.64
K23D KExVE	53.2	880	880	880	65	7.39	93	10.57	306	34.77	126	14.32	0	0.00	75	8.52
K23D VExDR	58.6	880	880	880	51	5.80	82	9.32	297	33.75	129	14.66	0	0.00	62	7.05
F25A	141.6	880	880	880	303	34.43	254	28.86	535	60.80	0	0.00	277	31.48	300	34.09

Table 60: Thermal Loading for Test Case 4 – Dinorwic Junction with All Elements in-service – Double-Circuit Contingency

Circuit Name	Length (KM)	Cont Rating	LTE Rating	STE Rating	Pre-Cont		Loss of AxLs and Cross-Trip B6M + Pickle Lake Line		Loss of AxLs and Cross-Trip B6M + E2R Lines		Loss of D26A + F25A and Cross-Trip M2D	
		(A)	(A)	(A)	(A)	% Cont	(A)	% LTE	(A)	% LTE	(A)	(A)
B6M BlxMU	14.5	440	440	450	226	51.36	56	12.73	56	12.73	18	4.09
B6M MUxST	7.9	430	430	430	184	42.79	37	8.60	37	8.60	33	7.67
B6M STxSH	33.5	470	470	470	182	38.72	29	6.17	29	6.17	32	6.81
B6M SHxIN	18.5	470	470	470	177	37.66	31	6.60	31	6.60	39	8.30
B6M INxKA	32.5	460	460	460	173	37.61	19	4.13	19	4.13	40	8.70
B6M KAxSA	58.9	430	430	430	173	40.23	19	4.42	19	4.42	40	9.30
B6M SAxCA	22.6	620	740	770	167	26.94	0	0.00	0	0.00	49	6.62
B6M CAxML	0.5	620	740	770	167	26.94	0	0.00	0	0.00	50	6.76
M2D MLxIG	76.7	550	550	550	352	64.00	99	18.00	127	23.09	0	0.00
M2D IGxDN	40.4	420	420	420	331	78.81	73	17.38	117	27.86	0	0.00
M2D DNxDR	40	420	420	420	173	41.19	73	17.38	282	67.14	0	0.00
29M1 IGxIG	1.1	320	400	460	29	9.06	21	5.25	20	5.00	0	0.00
29M1 IGxCL	18	500	500	500	25	5.00	17	3.40	17	3.40	0	0.00
29M1 CLxVA	51	500	500	500	24	4.80	16	3.20	15	3.00	0	0.00
E4D DRxSL	68.2	470	470	665	369	78.51	368	78.30	52	11.06	363	77.23
E4D SLxEF	30.2	470	470	665	359	76.38	358	76.17	30	6.38	353	75.11
E4D#2 DRxEF	98.4	470	470	470	368	78.30	367	78.09	52	11.06	362	77.02
E2R#2 EFxRL	66.5	420	420	420	298	70.95	298	70.95	0	0.00	298	70.95
E2R EFxPA	25.9	420	420	420	313	74.52	313	74.52	6	1.43	313	74.52
E2R PAxHC	36.1	420	420	420	313	74.52	313	74.52	0	0.00	313	74.52
E2R HCxRL	4.511	420	420	420	96	22.86	96	22.86	0	0.00	96	22.86
K3D DRxET	12	470	470	470	75	15.96	133	28.30	73	15.53	178	37.87
K3D ETxVB	27.9	470	470	470	82	17.45	139	29.57	79	16.81	185	39.36
K3D VBxRL	81.7	470	470	470	91	19.36	147	31.28	88	18.72	193	41.06
A21L	191.7	880	880	880	393	44.66	0	0.00	0	0.00	54	6.14
A22L	191.7	880	880	880	393	44.66	0	0.00	0	0.00	54	6.14
D26A MAxIG	93.4	880	880	880	391	44.43	86	9.77	48	5.45	0	0.00
D26A IGxDR	80.4	880	880	880	377	42.84	69	7.84	43	4.89	0	0.00
K23D KExVE	53.2	880	880	880	65	7.39	272	30.91	179	20.34	371	42.16
K23D VExDR	58.6	880	880	880	51	5.80	260	29.55	169	19.20	355	40.34
F25A	141.6	880	880	880	303	34.43	103	11.70	79	8.98	0	0.00

Appendix E: 115 kV Test Cases – Voltage Assessment Results

Table 61: HV Voltage Assessment for Test Case 3 – Valora Junction with All Element in-service – Single Circuit Contingency

Bus Name	Pre-Cont Volt (kV)	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	242.8	243.2	0.16	243.3	0.21	236.1	-2.76	235.1	-3.17	239.3	-1.44	238.9	-1.61	241.4	-0.58	241.6	-0.49	242.6	-0.08	242.2	-0.25
Dryden 230 kV	242.2	242.6	0.17	242.8	0.25	233.3	-3.67	227.7	-5.99	238.3	-1.61	236.2	-2.48	239.3	-1.20	235.8	-2.64	241.8	-0.17	240.6	-0.66
Fort Frances 230 kV	242.2	242.6	0.17	242.8	0.25	233.3	-3.67	227.7	-5.99	238.3	-1.61	236.2	-2.48	239.3	-1.20	235.8	-2.64	241.8	-0.17	240.6	-0.66
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Lakehead 230 kV	247.2	244.2	-1.21	244.4	-1.13	247.8	0.24	247.7	0.20	248.2	0.40	248.1	0.36	247	-0.08	247.1	-0.04	247.1	-0.04	247.1	-0.04
Pickle Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	123.5	123.5	0.00	123.7	0.16	118.8	-3.81	123.5	0.00	121.9	-1.30	123.6	0.08	122.3	-0.97	123.4	-0.08	123.3	-0.16	124	0.40
Fort Frances 115 kV	118.3	118.4	0.08	118.5	0.17	115.6	-2.28	118.4	0.08	115.1	-2.70	117.8	-0.42	118.1	-0.17	118.2	-0.08	118.3	0.00	118.2	-0.08
Mackenzie 115 kV	122.3	121.4	-0.74	122.8	0.41	121.2	-0.90	122.9	0.49	122.1	-0.16	122.2	-0.08	122.1	-0.16	122.2	-0.08	122.2	-0.08	122.3	0.00
Moose Lake 115 kV	121.7	120.6	-0.90	121.8	0.08	119.8	-1.56	121.4	-0.25	121.2	-0.41	121.4	-0.25	121.5	-0.16	121.6	-0.08	121.6	-0.08	121.7	0.00
Birch 115 kV	123.1	121.3	-1.46	121.5	-1.30	123.2	0.08	123.3	0.16	123.5	0.32	123.5	0.32	122.9	-0.16	123	-0.08	123	-0.08	123	-0.08
Valora Jct 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Esker 115 kV	118.6	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Musslewhite 115 kV	118.5	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00
King Fisher 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Neskatanga 115 kV	123.3	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00
Wunnumin 115 kV	128.9	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00
Nibinamik 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Kingfisher Lake 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Wapekeka 115 kV	127.2	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00
North Caribou Lake 115 kV	128.4	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00
Muskrat Dam 115 kV	128.1	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00
Crow River 115 kV	119.8	119.9	0.08	119.9	0.08	116.7	-2.59	119.9	0.08	119.7	-0.08	119.9	0.08	119.9	0.08	120	0.17	119.9	0.08	120	0.17
Thierry Mine 115 kV	120.1	120.1	0.00	120.1	0.00	117	-2.58	120.2	0.08	120	-0.08	120.2	0.08	120.1	0.00	120.2	0.08	120.1	0.00	120.3	0.17
Cat Lake 115 kV	121.9	121.9	0.00	121.9	0.00	118.9	-2.46	122	0.08	121.8	-0.08	122	0.08	121.9	0.00	122	0.08	121.9	0.00	122	0.08
Slate Falls 115 kV	123.3	123.4	0.08	123.4	0.08	120.4	-2.35	123.4	0.08	123.3	0.00	123.4	0.08	123.4	0.08	123.4	0.08	123.4	0.08	123.4	0.08
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	122.8	-2.07	125.5	0.08	125.4	0.00	125.4	0.00	125.4	0.00	125.5	0.08	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	123.3	123.3	0.00	123.5	0.16	118.6	-3.81	123.3	0.00	121.7	-1.30	123.4	0.08	122.1	-0.97	123.2	-0.08	123.1	-0.16	123.8	0.41
Perrault Falls 115 kV	124.3	124.3	0.00	124.3	0.00	120.9	-2.74	124.3	0.00	123.7	-0.48	124.3	0.00	123.9	-0.32	124.3	0.00	124.1	-0.16	124.4	0.08
Sam Lake 115 kV	121.9	122	0.08	122.1	0.16	117.1	-3.94	121.9	0.00	120.3	-1.31	122.1	0.16	120.7	-0.98	121.9	0.00	121.7	-0.16	122.5	0.49
Balmer 115 kV	120	120	0.00	120	0.00	117.2	-2.33	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00

Table 61: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Single Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	117.7	-2.32	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	120.7	0.00	120.7	0.00	118.1	-2.15	120.8	0.08	120.7	0.00	120.8	0.08	120.7	0.00	120.8	0.08	120.7	0.00	120.7	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	118	-1.99	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00
Sandy Lake 115 kV	120	120	0.00	120	0.00	117.7	-1.92	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Vermillion Bay DS 115 kV	123.6	123.7	0.08	123.8	0.16	119	-3.72	123.3	-0.24	122	-1.29	123.7	0.08	122.5	-0.89	123.4	-0.16	123.4	-0.16	123.9	0.24
Agimak DS 115 kV	119.8	119.5	-0.25	119.9	0.08	116.8	-2.50	118.4	-1.17	118.9	-0.75	119.3	-0.42	119.4	-0.33	119.7	-0.08	119.7	-0.08	119.9	0.08
Mattabi CTS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Valora DS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Murillo DS 115 kV	122.4	120.2	-1.80	120.5	-1.55	122.4	0.00	122.5	0.08	122.8	0.33	122.8	0.33	122.3	-0.08	122.3	-0.08	122.3	-0.08	122.4	0.00
Shabaqua DS 115 kV	122	119.1	-2.38	119.6	-1.97	121.4	-0.49	121.9	-0.08	122.3	0.25	122.3	0.25	121.9	-0.08	121.9	-0.08	121.9	-0.08	122	0.00
Sapawe DS 115 kV	121.7	119.8	-1.56	120.9	-0.66	120	-1.40	121.4	-0.25	121.4	-0.25	121.5	-0.16	121.5	-0.16	121.6	-0.08	121.6	-0.08	121.7	0.00
West Coast 115 kV	118.2	118.3	0.08	118.4	0.17	115.5	-2.28	118.2	0.00	115	-2.71	117.7	-0.42	118	-0.17	118.1	-0.08	118.1	-0.08	118.1	-0.08
Fort Frances MS 115 kV	118.3	118.4	0.08	118.5	0.17	115.6	-2.28	118.4	0.08	115.1	-2.70	117.8	-0.42	118.1	-0.17	118.2	-0.08	118.3	0.00	118.2	-0.08
Burleigh DS 115 kV	118.3	118.4	0.08	118.5	0.17	115.6	-2.28	118.3	0.00	115.1	-2.70	117.8	-0.42	118.1	-0.17	118.2	-0.08	118.2	-0.08	118.2	-0.08

Table 62: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	242.8	242.4	-0.16	243	0.08	244.4	0.66	245	0.91	231.7	-4.57	238.7	-1.69
Dryden 230 kV	242.2	243.9	0.70	244.3	0.87	246.6	1.82	247.7	2.27	228.3	-5.74	233.9	-3.43
Fort Frances 230 kV	242.2	243.9	0.70	244.3	0.87	246.6	1.82	247.7	2.27	228.3	-5.74	233.9	-3.43
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	251.4	2.61	252.1	2.90
Lakehead 230 kV	247.2	247.4	0.08	247.5	0.12	247.4	0.08	247.5	0.12	251.3	1.66	251.3	1.66
Pickle Lake 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	123.5	124.2	0.57	124.3	0.65	125.2	1.38	124.3	0.65	116.7	-5.51	124.1	0.49
Fort Frances 115 kV	118.3	116.1	-1.86	119.1	0.68	117.2	-0.93	118.3	0.00	112.1	-5.24	119.6	1.10
Mackenzie 115 kV	122.3	123.1	0.65	123.1	0.65	123	0.57	122.9	0.49	125.6	2.70	122.6	0.25
Moose Lake 115 kV	121.7	123.3	1.31	123.4	1.40	122.8	0.90	122.7	0.82	125.6	3.20	122.7	0.82
Birch 115 kV	123.1	121.8	-1.06	121.9	-0.97	121.8	-1.06	121.9	-0.97	123.6	0.41	123.4	0.24
Valora Jct 115 kV	120	125.2	4.33	125.3	4.42	120	0.00	120	0.00	0	N/A	0	N/A
Esker 115 kV	118.6	0	N/A	0	N/A	118.6	0.00	118.6	0.00	0	N/A	0	N/A
Musslewhite 115 kV	118.5	0	N/A	0	N/A	118.5	0.00	118.5	0.00	0	N/A	0	N/A
King Fisher 115 kV	127.9	0	N/A	0	N/A	127.9	0.00	127.9	0.00	0	N/A	0	N/A
Neskatanga 115 kV	123.3	0	N/A	0	N/A	123.3	0.00	123.3	0.00	0	N/A	0	N/A
Wunnumin 115 kV	128.9	0	N/A	0	N/A	128.9	0.00	128.9	0.00	0	N/A	0	N/A
Nibinamik 115 kV	130	0	N/A	0	N/A	130	0.00	130	0.00	0	N/A	0	N/A
Kingfisher Lake 115 kV	127.9	0	N/A	0	N/A	127.9	0.00	127.9	0.00	0	N/A	0	N/A
Wapekeka 115 kV	127.2	0	N/A	0	N/A	127.2	0.00	127.2	0.00	0	N/A	0	N/A
North Caribou Lake 115 kV	128.4	0	N/A	0	N/A	128.4	0.00	128.4	0.00	0	N/A	0	N/A
Muskrat Dam 115 kV	128.1	0	N/A	0	N/A	128.1	0.00	128.1	0.00	0	N/A	0	N/A
Crow River 115 kV	119.8	119.9	0.08	119.9	0.08	120	0.17	120	0.17	113.8	-5.01	119.9	0.08
Thierry Mine 115 kV	120.1	120.1	0.00	120.1	0.00	120.2	0.08	120.2	0.08	114.1	-5.00	120.1	0.00
Cat Lake 115 kV	121.9	121.9	0.00	121.9	0.00	122.5	0.49	122.3	0.33	116.1	-4.76	121.9	0.00
Slate Falls 115 kV	123.3	123.4	0.08	123.4	0.08	124.2	0.73	123.9	0.49	117.8	-4.46	123.4	0.08
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	126.9	1.20	126.2	0.64	120.6	-3.83	125.4	0.00
Domtar Dryden 115 kV	123.3	124	0.57	124.1	0.65	125	1.38	124.1	0.65	116.5	-5.52	123.9	0.49
Perrault Falls 115 kV	124.3	124.5	0.16	124.6	0.24	126.5	1.77	125.8	1.21	118.7	-4.51	124.5	0.16
Sam Lake 115 kV	121.9	122.6	0.57	122.8	0.74	123.7	1.48	122.7	0.66	114.9	-5.74	122.6	0.57
Balmer 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	114.7	-4.42	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	0	N/A	0	N/A	115.2	-4.40	120.5	0.00
Pikangikum 115 kV	120.7	120.7	0.00	120.7	0.00	0	N/A	0	N/A	115.4	-4.39	120.7	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	0	N/A	0	N/A	115.2	-4.32	120.4	0.00
Sandy Lake 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	114.9	-4.25	120	0.00

Table 62: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Double Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	123.6	123.9	0.24	124.2	0.49	125	1.13	124.4	0.65	116.8	-5.50	124.1	0.40
Agimak DS 115 kV	119.8	124.9	4.26	125	4.34	121	1.00	120.7	0.75	0	N/A	0	N/A
Mattabi CTS 115 kV	120	125.2	4.33	125.3	4.42	120	0.00	120	0.00	0	N/A	0	N/A
Valora DS 115 kV	120	125.2	4.33	125.3	4.42	120	0.00	120	0.00	0	N/A	0	N/A
Murillo DS 115 kV	122.4	121.7	-0.57	121.9	-0.41	121.7	-0.57	121.9	-0.41	123.5	0.90	123.1	0.57
Shabaqua DS 115 kV	122	122.8	0.66	123	0.82	122.8	0.66	123	0.82	124.4	1.97	123.4	1.15
Sapawe DS 115 kV	121.7	124.5	2.30	124.6	2.38	124.5	2.30	124.6	2.38	125.6	3.20	123.1	1.15
West Coast 115 kV	118.2	116	-1.86	118.9	0.59	117	-1.02	118.2	0.00	112	-5.25	119.4	1.02
Fort Frances MS 115 kV	118.3	116.1	-1.86	119.1	0.68	117.2	-0.93	118.3	0.00	112.1	-5.24	119.6	1.10
Burleigh DS 115 kV	118.3	116.1	-1.86	119	0.59	117.1	-1.01	118.3	0.00	112.1	-5.24	119.5	1.01

Table 63: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of 1 Pickle Lake SVC				Loss of Mackenzie SVC				Loss of 1 Valora SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	242.8	241.1	-0.70	241.1	-0.70	242.8	0.00	242.8	0.00	242.1	-0.29	241.5	-0.54	242.8	0.00	242.8	0.00
Dryden 230 kV	242.2	238.9	-1.36	237.8	-1.82	242.2	0.00	242.2	0.00	241.2	-0.41	239.9	-0.95	242.2	0.00	242.2	0.00
Fort Frances 230 kV	242.2	238.9	-1.36	237.8	-1.82	242.2	0.00	242.2	0.00	241.2	-0.41	239.9	-0.95	242.2	0.00	242.2	0.00
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	243.1	-0.78	242.3	-1.10	245	0.00	245	0.00
Lakehead 230 kV	247.2	247.2	0.00	247.2	0.00	247.2	0.00	247.2	0.00	246.5	-0.28	246.4	-0.32	247.2	0.00	247.2	0.00
Pickle Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	123.5	121	-2.02	123.5	0.00	123.5	0.00	123.5	0.00	123	-0.40	123.8	0.24	123.5	0.00	123.5	0.00
Fort Frances 115 kV	118.3	117.9	-0.34	118.2	-0.08	118.3	0.00	118.3	0.00	117.8	-0.42	117.8	-0.42	118.3	0.00	118.3	0.00
Mackenzie 115 kV	122.3	122.1	-0.16	122.3	0.00	122.3	0.00	122.3	0.00	121.5	-0.65	122.6	0.25	122.3	0.00	122.3	0.00
Moose Lake 115 kV	121.7	121.4	-0.25	121.7	0.00	121.7	0.00	121.7	0.00	121	-0.58	122	0.25	121.7	0.00	121.7	0.00
Birch 115 kV	123.1	123	-0.08	123.1	0.00	123.1	0.00	123.1	0.00	122.7	-0.32	122.8	-0.24	123.1	0.00	123.1	0.00
Valora Jct 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Esker 115 kV	118.6	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Musslewhite 115 kV	118.5	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00
King Fisher 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Neskatanga 115 kV	123.3	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00
Wunnumin 115 kV	128.9	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00
Nibinamik 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Kingfisher Lake 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Wapekeka 115 kV	127.2	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00
North Caribou Lake 115 kV	128.4	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00
Muskrat Dam 115 kV	128.1	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00
Crow River 115 kV	119.8	111	-7.35	114.3	-4.59	119.8	0.00	119.8	0.00	119.7	-0.08	119.9	0.08	119.8	0.00	119.8	0.00
Thierry Mine 115 kV	120.1	111.3	-7.33	114.5	-4.66	120.1	0.00	120.1	0.00	120	-0.08	120.1	0.00	120.1	0.00	120.1	0.00
Cat Lake 115 kV	121.9	113.4	-6.97	116.5	-4.43	121.9	0.00	121.9	0.00	121.8	-0.08	121.9	0.00	121.9	0.00	121.9	0.00
Slate Falls 115 kV	123.3	115.2	-6.57	118.2	-4.14	123.3	0.00	123.3	0.00	123.2	-0.08	123.4	0.08	123.3	0.00	123.3	0.00
Ear Falls 115 kV	125.4	118.4	-5.58	121	-3.51	125.4	0.00	125.4	0.00	125.3	-0.08	125.4	0.00	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	123.3	120.7	-2.11	123.2	-0.08	123.3	0.00	123.3	0.00	122.8	-0.41	123.6	0.24	123.3	0.00	123.3	0.00
Perrault Falls 115 kV	124.3	118.6	-4.59	121.2	-2.49	124.3	0.00	124.3	0.00	124.1	-0.16	124.4	0.08	124.3	0.00	124.3	0.00
Sam Lake 115 kV	121.9	119.3	-2.13	121.9	0.00	121.9	0.00	121.9	0.00	121.5	-0.33	122.2	0.25	121.9	0.00	121.9	0.00
Balmer 115 kV	120	112.1	-6.58	115.1	-4.08	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	112.7	-6.47	115.7	-3.98	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.7	112.7	-6.63	115.8	-4.06	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00	120.7	0.00
Deer Lake 115 kV	120.4	112.3	-6.73	115.7	-3.90	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00
Sandy Lake 115 kV	120	112	-6.67	115.3	-3.92	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00

Table 63: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of 1 Pickle Lake SVC				Loss of Mackenzie SVC				Loss of 1 Valora SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	123.6	121.6	-1.62	123.4	-0.16	123.6	0.00	123.6	0.00	123.2	-0.32	123.7	0.08	123.6	0.00	123.6	0.00
Agimak DS 115 kV	119.8	119.1	-0.58	119.8	0.00	119.8	0.00	119.8	0.00	119.5	-0.25	120	0.17	119.8	0.00	119.8	0.00
Mattabi CTS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Valora DS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Murillo DS 115 kV	122.4	122.4	0.00	122.4	0.00	122.4	0.00	122.4	0.00	122	-0.33	122.2	-0.16	122.4	0.00	122.4	0.00
Shabaqua DS 115 kV	122	121.9	-0.08	122	0.00	122	0.00	122	0.00	121.6	-0.33	121.9	-0.08	122	0.00	122	0.00
Sapawe DS 115 kV	121.7	121.5	-0.16	121.7	0.00	121.7	0.00	121.7	0.00	121.1	-0.49	121.9	0.16	121.7	0.00	121.7	0.00
West Coast 115 kV	118.2	117.8	-0.34	118	-0.17	118.2	0.00	118.2	0.00	117.7	-0.42	117.6	-0.51	118.2	0.00	118.2	0.00
Fort Frances MS 115 kV	118.3	117.9	-0.34	118.2	-0.08	118.3	0.00	118.3	0.00	117.8	-0.42	117.7	-0.51	118.3	0.00	118.3	0.00
Burleigh DS 115 kV	118.3	117.9	-0.34	118.1	-0.17	118.3	0.00	118.3	0.00	117.8	-0.42	117.7	-0.51	118.3	0.00	118.3	0.00

Table 64: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	241.9	244.5	1.07	245	1.28	242	0.04	242	0.04	241.9	0.00	241.9	0.00
Dryden 230 kV	242	246.1	1.69	247.6	2.31	242.1	0.04	242.1	0.04	242	0.00	242	0.00
Fort Frances 230 kV	242	246.1	1.69	247.6	2.31	242.1	0.04	242.1	0.04	242	0.00	242	0.00
Mackenzie 230 kV	238.3	244.9	2.77	245.9	3.19	238.3	0.00	238.3	0.00	238.3	0.00	238.3	0.00
Lakehead 230 kV	236.4	238.7	0.97	238.8	1.02	236.5	0.04	236.5	0.04	236.4	0.00	236.4	0.00
Pickle Lake 115 kV	120	120	0.00	120	0.00	120.6	0.50	120.6	0.50	120	0.00	120	0.00
Dryden 115 kV	124.9	126.9	1.60	124.5	-0.32	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00
Fort Frances 115 kV	118.6	120.3	1.43	120.5	1.60	118.6	0.00	118.7	0.08	118.6	0.00	118.6	0.00
Mackenzie 115 kV	123.2	126.3	2.52	123.4	0.16	123.3	0.08	123.3	0.08	123.2	0.00	123.2	0.00
Moose Lake 115 kV	123.2	126.1	2.35	123.4	0.16	123.2	0.00	123.2	0.00	123.2	0.00	123.2	0.00
Birch 115 kV	121.9	123.1	0.98	123	0.90	121.9	0.00	121.9	0.00	121.9	0.00	121.9	0.00
Valora Jct 115 kV	120.5	122.6	1.74	120.5	0.00	120.8	0.25	120.8	0.25	120.5	0.00	120.5	0.00
Esker 115 kV	120.1	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.8	126.8	0.00	126.8	0.00	126.9	0.08	126.9	0.08	126.8	0.00	126.8	0.00
Neskatanga 115 kV	124.4	124.4	0.00	124.4	0.00	124.8	0.32	124.8	0.32	124.4	0.00	124.4	0.00
Wunnumin 115 kV	128.2	128.2	0.00	128.2	0.00	128.3	0.08	128.2	0.00	128.2	0.00	128.2	0.00
Nibinamik 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Kingfisher Lake 115 kV	127.2	127.2	0.00	127.2	0.00	127.3	0.08	127.3	0.08	127.2	0.00	127.2	0.00
Wapekeka 115 kV	127.8	127.8	0.00	127.8	0.00	127.9	0.08	127.9	0.08	127.8	0.00	127.8	0.00
North Caribou Lake 115 kV	128.6	128.6	0.00	128.6	0.00	128.7	0.08	128.7	0.08	128.6	0.00	128.6	0.00
Muskrat Dam 115 kV	128.9	128.9	0.00	128.9	0.00	129	0.08	129	0.08	128.9	0.00	128.9	0.00
Crow River 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Thierry Mine 115 kV	119.9	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00
Cat Lake 115 kV	121.8	122.3	0.41	121.7	-0.08	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00
Slate Falls 115 kV	122.9	123.7	0.65	122.7	-0.16	122.9	0.00	122.9	0.00	122.9	0.00	122.9	0.00
Ear Falls 115 kV	123	124.6	1.30	122.8	-0.16	123	0.00	123	0.00	123	0.00	123	0.00
Domtar Dryden 115 kV	124.9	126.8	1.52	124.5	-0.32	124.9	0.00	124.9	0.00	124.9	0.00	124.9	0.00
Perrault Falls 115 kV	123.5	125.3	1.46	123.2	-0.24	123.5	0.00	123.5	0.00	123.5	0.00	123.5	0.00
Sam Lake 115 kV	124.3	126.4	1.69	124	-0.24	124.4	0.08	124.4	0.08	124.3	0.00	124.3	0.00
Balmer 115 kV	120.2	122	1.50	120	-0.17	120.2	0.00	120.2	0.00	120.2	0.00	120.2	0.00
Red Lake 115 kV	120.7	122.5	1.49	120.5	-0.17	120.8	0.08	120.8	0.08	120.7	0.00	120.7	0.00
Pikangikum 115 kV	124	125.8	1.45	123.7	-0.24	124	0.00	124	0.00	124	0.00	124	0.00
Deer Lake 115 kV	126.2	128.1	1.51	126	-0.16	126.2	0.00	126.2	0.00	126.2	0.00	126.2	0.00
Sandy Lake 115 kV	126.3	128.2	1.50	126.1	-0.16	126.3	0.00	126.3	0.00	126.3	0.00	126.3	0.00

Table 64: HV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	125.1	126.8	1.36	125.1	0.00	125.1	0.00	125.1	0.00	125.1	0.00	125.1	0.00
Agimak DS 115 kV	122.3	124.6	1.88	122.2	-0.08	122.4	0.08	122.4	0.08	122.3	0.00	122.3	0.00
Mattabi CTS 115 kV	120.6	122.6	1.66	120.5	-0.08	120.8	0.17	120.8	0.17	120.6	0.00	120.6	0.00
Valora DS 115 kV	120.5	122.6	1.74	120.5	0.00	120.8	0.25	120.8	0.25	120.5	0.00	120.5	0.00
Murillo DS 115 kV	121.8	123.2	1.15	122.9	0.90	121.9	0.08	121.9	0.08	121.8	0.00	121.8	0.00
Shabaqua DS 115 kV	122.4	124.2	1.47	123.3	0.74	122.5	0.08	122.5	0.08	122.4	0.00	122.4	0.00
Sapawe DS 115 kV	123.2	126	2.27	123.5	0.24	123.3	0.08	123.3	0.08	123.2	0.00	123.2	0.00
West Coast 115 kV	118.5	120.2	1.43	120.5	1.69	118.6	0.08	118.6	0.08	118.5	0.00	118.5	0.00
Fort Frances MS 115 kV	118.6	120.3	1.43	120.5	1.60	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Burleigh DS 115 kV	118.6	120.3	1.43	120.5	1.60	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00

Table 65: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.8	24.3	-2.02	24.8	0.00	24.8	0.00	25	0.81	24.9	0.40	24.9	0.40	24.8	0.00	24.9	0.40	24.8	0.00	24.9	0.40
Shabaqua DS LV	13.1	12.7	-3.05	12.8	-2.29	13	-0.76	13.1	0.00	13.1	0.00	13.1	0.00	13	-0.76	13.1	0.00	13.1	0.00	13.1	0.00
Sapawe DS LV	13.8	13.5	-2.17	13.7	-0.72	13.6	-1.45	13.7	-0.72	13.7	-0.72	13.7	-0.72	13.7	-0.72	13.7	-0.72	13.8	0.00	13.8	0.00
Mattabi DS LV	4.1	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00
Agimak DS LV	26.4	26.3	-0.38	26.4	0.00	25.7	-2.65	26.4	0.00	26.2	-0.76	26.2	-0.76	26.3	-0.38	26.3	-0.38	26.4	0.00	26.4	0.00
Valora DS LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Esker LV	13.8	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Wunnumin LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Nibinamik LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
King Fisher Lake LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Wapekeka LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24.4	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00
Muskrat LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.8	27.8	0.00	27.8	0.00	27.3	-1.80	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Thierry Mine LV	4.4	4.4	0.00	4.4	0.00	4.3	-2.27	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00
Cat Lake LV	29.2	29.2	0.00	29.2	0.00	28.7	-1.71	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.3	0.34	29.2	0.00	29.2	0.00
Slate Falls LV	23.7	23.7	0.00	23.7	0.00	23.3	-1.69	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.8	0.42	23.7	0.00	23.7	0.00
Ear Falls LV	45.3	45.3	0.00	45.3	0.00	44.7	-1.32	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00
Domtar Dryden LV	13.7	13.7	0.00	13.7	0.00	13.2	-3.65	13.7	0.00	13.5	-1.46	13.6	-0.73	13.5	-1.46	13.6	-0.73	13.7	0.00	13.7	0.00
Perrault Falls LV	11.7	11.7	0.00	11.7	0.00	11.4	-2.56	11.7	0.00	11.6	-0.85	11.7	0.00	11.6	-0.85	11.7	0.00	11.7	0.00	11.7	0.00
Sam Lake LV	26.4	26.4	0.00	26.5	0.38	25.4	-3.79	26.6	0.76	26	-1.52	26.5	0.38	26.1	-1.14	26.4	0.00	26.4	0.00	26.4	0.00
Balmer LV	44.1	44.1	0.00	44.1	0.00	43.4	-1.59	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	46.2	-1.49	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	27.5	-1.43	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	27.8	0.00	27.8	0.00	27.5	-1.08	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Sandy Lake LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.2	13.2	0.00	13.3	0.76	12.7	-3.79	13.3	0.76	13.1	-0.76	13.3	0.76	13.1	-0.76	13.3	0.76	13.2	0.00	13.2	0.00
Vermillion Bay DS LV	15.2	15.2	0.00	15.2	0.00	14.6	-3.95	15.2	0.00	15	-1.32	15.1	-0.66	15	-1.32	15.1	-0.66	15.2	0.00	15.2	0.00
Burleigh DS LV	13	13	0.00	13.1	0.77	12.7	-2.31	13.1	0.77	12.6	-3.08	13	0.00	13	0.00	13	0.00	13	0.00	13	0.00
Fort Frances MS1 LV	14.1	14.1	0.00	14.1	0.00	13.7	-2.84	14.1	0.00	13.7	-2.84	14	-0.71	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances MS2 LV	12.4	12.4	0.00	12.5	0.81	12.1	-2.42	12.5	0.81	12.1	-2.42	12.5	0.81	12.4	0.00	12.4	0.00	12.4	0.00	12.4	0.00
Fort Frances L5	14.1	14.1	0.00	14.1	0.00	13.8	-2.13	14.2	0.71	13.7	-2.84	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances L4A	14	14	0.00	14	0.00	13.7	-2.14	14	0.00	13.6	-2.86	13.9	-0.71	14	0.00	14	0.00	14	0.00	14	0.00
Fort Frances L4B	14.8	14.8	0.00	14.8	0.00	14.5	-2.03	14.8	0.00	14.4	-2.70	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00
Fort Frances AB	6.7	6.7	0.00	6.7	0.00	6.5	-2.99	6.7	0.00	6.5	-2.99	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00

Table 66: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.8	24.6	-0.81	24.8	0.00	24.6	-0.81	24.8	0.00	25	0.81	24.9	0.40
Shabaqua DS LV	13.1	13.2	0.76	13.2	0.76	13.2	0.76	13.2	0.76	13.3	1.53	13.2	0.76
Sapawe DS LV	13.8	14.1	2.17	14.1	2.17	14.1	2.17	14.1	2.17	14.2	2.90	13.9	0.72
Mattabi DS LV	4.1	4.3	4.88	4.3	4.88	4.1	0.00	4.1	0.00	0	N/A	0	N/A
Agimak DS LV	26.4	27.6	4.55	26.8	1.52	26.7	1.14	26.5	0.38	0	N/A	0	N/A
Valora DS LV	24.9	26.1	4.82	26	4.42	24.9	0.00	24.9	0.00	0	N/A	0	N/A
Esker LV	13.8	0	N/A	0	N/A	13.8	0.00	13.8	0.00	0	N/A	0	N/A
Musselwhite LV	4.2	0	N/A	0	N/A	4.2	0.00	4.2	0.00	0	N/A	0	N/A
Neskatanga LV	27.7	0	N/A	0	N/A	27.7	0.00	27.7	0.00	0	N/A	0	N/A
Wunnumin LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	0	N/A	0	N/A
Nibinamik LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	0	N/A	0	N/A
King Fisher Lake LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	0	N/A	0	N/A
Wapekeka LV	27.8	0	N/A	0	N/A	27.8	0.00	27.8	0.00	0	N/A	0	N/A
North Caribou Lake LV	24.4	0	N/A	0	N/A	24.4	0.00	24.4	0.00	0	N/A	0	N/A
Muskrat LV	28	0	N/A	0	N/A	28	0.00	28	0.00	0	N/A	0	N/A
Crow River LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	26.8	-3.60	27.8	0.00
Thierry Mine LV	4.4	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.2	-4.55	4.4	0.00
Cat Lake LV	29.2	29.2	0.00	29.2	0.00	29.4	0.68	29.3	0.34	28.2	-3.42	29.4	0.68
Slate Falls LV	23.7	23.7	0.00	23.7	0.00	24	1.27	23.8	0.42	23	-2.95	23.7	0.00
Ear Falls LV	45.3	45.3	0.00	45.3	0.00	46.1	1.77	45.6	0.66	44.1	-2.65	45.3	0.00
Domtar Dryden LV	13.7	13.8	0.73	13.7	0.00	13.9	1.46	13.7	0.00	13	-5.11	13.7	0.00
Perrault Falls LV	11.7	11.7	0.00	11.7	0.00	12	2.56	11.8	0.85	11.2	-4.27	11.7	0.00
Sam Lake LV	26.4	26.6	0.76	26.4	0.00	26.9	1.89	26.4	0.00	25	-5.30	26.7	1.14
Balmer LV	44.1	44.1	0.00	44.1	0.00	0	N/A	0	N/A	42.7	-3.17	44.1	0.00
Red Lake LV	46.9	46.9	0.00	46.9	0.00	0	N/A	0	N/A	45.4	-3.20	46.9	0.00
Pikangikum LV	27.9	27.9	0.00	27.9	0.00	0	N/A	0	N/A	27.1	-2.87	27.9	0.00
Deer Lake LV	27.8	27.8	0.00	27.8	0.00	0	N/A	0	N/A	27	-2.88	27.8	0.00
Sandy Lake LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27	-1.82	27.8	1.09
Eton DS LV	13.2	13.3	0.76	13.2	0.00	13.4	1.52	13.3	0.76	12.6	-4.55	13.4	1.52
Vermillion Bay DS LV	15.2	15.2	0.00	15.2	0.00	15.4	1.32	15.2	0.00	14.4	-5.26	15.2	0.00
Burleigh DS LV	13	12.8	-1.54	13.1	0.77	12.9	-0.77	13	0.00	12.3	-5.38	13.2	1.54
Fort Frances MS1 LV	14.1	13.8	-2.13	14.1	0.00	13.9	-1.42	14.1	0.00	13.3	-5.67	14.2	0.71
Fort Frances MS2 LV	12.4	12.2	-1.61	12.6	1.61	12.3	-0.81	12.5	0.81	11.8	-4.84	12.5	0.81
Fort Frances L5	14.1	13.8	-2.13	14.2	0.71	14	-0.71	14.1	0.00	13.3	-5.67	14.3	1.42
Fort Frances L4A	14	13.7	-2.14	14	0.00	13.9	-0.71	14	0.00	13.3	-5.00	14.1	0.71
Fort Frances L4B	14.8	14.5	-2.03	14.9	0.68	14.7	-0.68	14.8	0.00	14.1	-4.73	14.9	0.68
Fort Frances AB	6.7	6.6	-1.49	6.7	0.00	6.6	-1.49	6.7	0.00	6.3	-5.97	6.8	1.49

Table 67: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of 1 Pickle Lake SVC				Loss of Mackenzie SVC				Loss of 1 Valora SVC			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.8	24.8	0.00	24.9	0.40	24.8	0.00	24.8	0.00	24.7	-0.40	24.9	0.40	24.8	0.00	24.8	0.00
Shabaqua DS LV	13.1	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13	-0.76	13	-0.76	13.1	0.00	13.1	0.00
Sapawe DS LV	13.8	13.7	-0.72	13.8	0.00	13.8	0.00	13.8	0.00	13.7	-0.72	13.8	0.00	13.8	0.00	13.8	0.00
Mattabi DS LV	4.1	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00
Agimak DS LV	26.4	26.2	-0.38	26.3	0.00	26.3	0.00	26.3	0.00	26.3	0.00	26.4	0.38	26.3	0.00	26.3	0.00
Valora DS LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Esker LV	13.8	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Wunnumin LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Nibinamik LV	24.7	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00
King Fisher Lake LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Wapekeka LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
North Caribou Lake LV	24.4	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00
Muskrat LV	28	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00	28	0.00
Crow River LV	27.8	25.7	-7.55	27.5	-1.08	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Thierry Mine LV	4.4	4	-9.09	4.2	-4.55	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00
Cat Lake LV	29.2	27.1	-7.19	29.1	-0.34	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00
Slate Falls LV	23.7	22.1	-6.75	22.7	-4.22	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00
Ear Falls LV	45.3	42.8	-5.52	43.7	-3.53	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00
Domtar Dryden LV	13.7	13.3	-2.21	13.6	0.00	13.6	0.00	13.6	0.00	13.5	-0.74	13.6	0.00	13.6	0.00	13.6	0.00
Perrault Falls LV	11.7	11.1	-5.13	11.4	-2.56	11.7	0.00	11.7	0.00	11.6	-0.85	11.7	0.00	11.7	0.00	11.7	0.00
Sam Lake LV	26.4	25.9	-1.89	26.6	0.76	26.4	0.00	26.4	0.00	26.3	-0.38	26.5	0.38	26.4	0.00	26.4	0.00
Balmer LV	44.1	41.2	-6.58	44	-0.23	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00	44.1	0.00
Red Lake LV	46.9	43.8	-6.61	46.6	-0.64	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00	46.9	0.00
Pikangikum LV	27.9	26	-6.81	27.7	-0.72	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00	27.9	0.00
Deer Lake LV	27.8	25.9	-6.83	27.7	-0.36	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Sandy Lake LV	27.5	25.9	-5.82	27.7	0.73	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.2	13	-2.26	13.4	0.75	13.3	0.00	13.3	0.00	13.2	-0.75	13.3	0.00	13.3	0.00	13.3	0.00
Vermillion Bay DS LV	15.2	14.9	-1.32	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00
Burleigh DS LV	13	13	0.00	13	0.00	13	0.00	13	0.00	13	0.00	13	0.00	13	0.00	13	0.00
Fort Frances MS1 LV	14.1	14	-0.71	14.1	0.00	14.1	0.00	14.1	0.00	14	-0.71	14	-0.71	14.1	0.00	14.1	0.00
Fort Frances MS2 LV	12.4	12.4	0.00	12.5	0.81	12.4	0.00	12.4	0.00	12.4	0.00	12.5	0.81	12.4	0.00	12.4	0.00
Fort Frances L5	14.1	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances L4A	14	14	0.00	14	0.00	14	0.00	14	0.00	13.9	-0.71	13.9	-0.71	14	0.00	14	0.00
Fort Frances L4B	14.8	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.7	-0.68	14.8	0.00	14.8	0.00
Fort Frances AB	6.7	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00

Table 68: LV Voltage Assessment for Test Case 3 – Valora Junction with All Elements in-service) – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont Volt (kV)	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	25.1	25.4	1.20	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00
Shabaqua DS LV	13.2	13.4	1.52	13.3	0.76	13.2	0.00	13.2	0.00	13.2	0.00	13.2	0.00
Sapawe DS LV	13.9	14.2	2.16	14	0.72	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Mattabi DS LV	4.1	4.2	2.44	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00
Agimak DS LV	26.6	27.1	1.88	26.2	-1.50	26.6	0.00	26.6	0.00	26.6	0.00	26.6	0.00
Valora DS LV	25.1	25.5	1.59	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00
Esker LV	13.9	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Wunnumin LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Nibinamik LV	25.3	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00
King Fisher Lake LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Wapekeka LV	27.3	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00
North Caribou Lake LV	25.1	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00
Muskrat LV	27.5	27.5	0.00	27.5	0.00	27.6	0.36	27.5	0.00	27.5	0.00	27.5	0.00
Crow River LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Thierry Mine LV	4.3	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00
Cat Lake LV	29.4	29.5	0.34	29.3	-0.34	29.4	0.00	29.4	0.00	29.4	0.00	29.4	0.00
Slate Falls LV	24	24.1	0.42	23.9	-0.42	24	0.00	24	0.00	24	0.00	24	0.00
Ear Falls LV	44.7	45.3	1.34	44.6	-0.22	44.7	0.00	44.7	0.00	44.7	0.00	44.7	0.00
Domtar Dryden LV	13.9	14.2	2.16	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Perrault Falls LV	11.8	11.9	0.85	11.7	-0.85	11.8	0.00	11.8	0.00	11.8	0.00	11.8	0.00
Sam Lake LV	26.5	27	1.89	26.3	-0.75	26.6	0.38	26.6	0.38	26.5	0.00	26.5	0.00
Balmer LV	43.3	43.9	1.39	43.2	-0.23	43.3	0.00	43.3	0.00	43.3	0.00	43.3	0.00
Red Lake LV	46.4	47.1	1.51	46.4	0.00	46.5	0.22	46.5	0.22	46.4	0.00	46.4	0.00
Pikangikum LV	27.5	28	1.82	27.5	0.00	27.6	0.36	27.6	0.36	27.5	0.00	27.5	0.00
Deer Lake LV	27.4	27.8	1.46	27.3	-0.36	27.4	0.00	27.4	0.00	27.4	0.00	27.4	0.00
Sandy Lake LV	27.7	28.1	1.44	27.2	-1.81	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Eton DS LV	13.4	13.6	1.49	13.3	-0.75	13.4	0.00	13.4	0.00	13.4	0.00	13.4	0.00
Vermillion Bay DS LV	15.3	15.5	1.31	15.3	0.00	15.3	0.00	15.3	0.00	15.3	0.00	15.3	0.00
Burleigh DS LV	13.1	13.3	1.53	13.4	2.29	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Fort Frances MS1 LV	14.2	14.4	1.41	14.4	1.41	14.2	0.00	14.2	0.00	14.2	0.00	14.2	0.00
Fort Frances MS2 LV	12.5	12.7	1.60	12.6	0.80	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00
Fort Frances L5	14.4	14.6	1.39	14.6	1.39	14.4	0.00	14.4	0.00	14.4	0.00	14.4	0.00
Fort Frances L4A	14.1	14.3	1.42	14.3	1.42	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances L4B	14.9	15.1	1.34	15.1	1.34	14.9	0.00	14.9	0.00	14.9	0.00	14.9	0.00
Fort Frances AB	6.9	7	1.45	7	1.45	6.9	0.00	6.9	0.00	6.9	0.00	6.9	0.00

Table 69: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	244.4	244.6	0.08	244.7	0.12	239.3	-2.09	238.6	-2.37	242.6	-0.74	240.9	-1.43	242.3	-0.86	241.7	-1.10	244.4	0.00	244.4	0.00
Dryden 230 kV	245	245	0.00	245	0.00	239	-2.45	238.5	-2.65	243.8	-0.49	242.1	-1.18	245	0.00	245	0.00	245	0.00	245	0.00
Fort Frances 230 kV	245	245	0.00	245	0.00	239	-2.45	238.5	-2.65	243.8	-0.49	242.1	-1.18	245	0.00	245	0.00	245	0.00	245	0.00
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Lakehead 230 kV	247.2	244.2	-1.21	244.4	-1.13	248	0.32	247.7	0.20	248.3	0.44	248.1	0.36	247	-0.08	247	-0.08	247	-0.08	247	-0.08
Pickle Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	123.5	123.4	-0.08	123.4	-0.08	124.1	0.49	123.8	0.24	122.8	-0.57	123.5	0.00	123.3	-0.16	124.6	0.89	123.4	-0.08	123.4	-0.08
Fort Frances 115 kV	118.6	118.7	0.08	118.7	0.08	117.7	-0.76	117.3	-1.10	116.2	-2.02	118.3	-0.25	118.2	-0.34	118.3	-0.25	118.6	0.00	118.6	0.00
Mackenzie 115 kV	122.3	121.3	-0.82	122.7	0.33	123.1	0.65	123	0.57	122.2	-0.08	122.2	-0.08	122.2	-0.08	122.3	0.00	122.2	-0.08	122.2	-0.08
Moose Lake 115 kV	121.8	120.7	-0.90	121.8	0.00	121.8	0.00	121.6	-0.16	121.6	-0.16	121.6	-0.16	121.8	0.00	121.9	0.08	121.8	0.00	121.8	0.00
Birch 115 kV	123	121.3	-1.38	121.5	-1.22	123.4	0.33	123.3	0.24	123.6	0.49	123.5	0.41	123	0.00	123	0.00	123	0.00	123	0.00
Valora Jct 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Esker 115 kV	118.6	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Musslewhite 115 kV	118.5	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00
King Fisher 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Neskatanga 115 kV	123.3	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00
Wunnumin 115 kV	128.9	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00
Nibinamik 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Kingfisher Lake 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Wapekeka 115 kV	127.2	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00
North Caribou Lake 115 kV	128.4	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00
Muskkrat Dam 115 kV	128.1	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00
Crow River 115 kV	119.9	119.9	0.00	119.9	0.00	120	0.08	119.8	-0.08	119.7	-0.17	120	0.08	119.9	0.00	120	0.08	119.9	0.00	119.9	0.00
Thierry Mine 115 kV	120.1	120.1	0.00	120.1	0.00	120.3	0.17	120	-0.08	120	-0.08	120.3	0.17	120.1	0.00	120.3	0.17	120.1	0.00	120.1	0.00
Cat Lake 115 kV	122	122	0.00	122	0.00	122.1	0.08	121.9	-0.08	121.8	-0.16	122	0.00	122	0.00	122	0.00	122	0.00	122	0.00
Slate Falls 115 kV	123.4	123.4	0.00	123.4	0.00	123.5	0.08	123.3	-0.08	123.2	-0.16	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	123.3	123.2	-0.08	123.2	-0.08	123.9	0.49	123.6	0.24	122.6	-0.57	123.3	0.00	123.1	-0.16	124.4	0.89	123.2	-0.08	123.2	-0.08
Perrault Falls 115 kV	124.3	124.3	0.00	124.3	0.00	124.5	0.16	124.3	0.00	124	-0.24	124.3	0.00	124.2	-0.08	124.7	0.32	124.2	-0.08	124.2	-0.08
Sam Lake 115 kV	121.9	121.8	-0.08	121.9	0.00	122.5	0.49	122.2	0.25	121.3	-0.49	122	0.08	121.7	-0.16	123.1	0.98	121.8	-0.08	121.8	-0.08
Balmer 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.8	120.8	0.00	120.8	0.00	120.8	0.00	120.7	-0.08	120.7	-0.08	120.8	0.00	120.8	0.00	120.8	0.00	120.8	0.00	120.8	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00
Sandy Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00

Table 69: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	123.4	123.4	0.00	123.4	0.00	123.7	0.24	123.4	0.00	122.7	-0.57	123.5	0.08	123	-0.32	124.3	0.73	123.4	0.00	123.4	0.00
Agimak DS 115 kV	119.3	119	-0.25	119.2	-0.08	117.8	-1.26	117.6	-1.42	118.5	-0.67	118.7	-0.50	119.1	-0.17	119.5	0.17	119.2	-0.08	119.2	-0.08
Mattabi CTS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Valora DS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Murillo DS 115 kV	122.5	120.3	-1.80	120.6	-1.55	122.7	0.16	122.6	0.08	123	0.41	122.9	0.33	122.4	-0.08	122.4	-0.08	122.4	-0.08	122.4	-0.08
Shabaqua DS 115 kV	122.2	119.3	-2.37	119.8	-1.96	122.3	0.08	122.1	-0.08	122.5	0.25	122.4	0.16	122.1	-0.08	122.1	-0.08	122.1	-0.08	122.1	-0.08
Sapawe DS 115 kV	121.9	120	-1.56	121	-0.74	121.9	0.00	121.6	-0.25	121.7	-0.16	121.7	-0.16	121.8	-0.08	121.9	0.00	121.8	-0.08	121.8	-0.08
West Coast 115 kV	118.4	118.5	0.08	118.6	0.17	117.6	-0.68	117.2	-1.01	116.1	-1.94	118.1	-0.25	118.1	-0.25	118.1	-0.25	118.4	0.00	118.4	0.00
Fort Frances MS 115 kV	118.6	118.7	0.08	118.7	0.08	117.7	-0.76	117.3	-1.10	116.2	-2.02	118.3	-0.25	118.2	-0.34	118.3	-0.25	118.6	0.00	118.6	0.00
Burleigh DS 115 kV	118.5	118.6	0.08	118.7	0.17	117.7	-0.68	117.3	-1.01	116.2	-1.94	118.2	-0.25	118.2	-0.25	118.2	-0.25	118.5	0.00	118.5	0.00

Table 70: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	244.4	243.4	-0.41	244	-0.16	244.4	0.00	244.5	0.04	240.2	-1.72	239.9	-1.84
Dryden 230 kV	245	245	0.00	245.6	0.24	245	0.00	245	0.00	245	0.00	245	0.00
Fort Frances 230 kV	245	245	0.00	245.6	0.24	245	0.00	245	0.00	245	0.00	245	0.00
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	251.7	2.73	253	3.27
Lakehead 230 kV	247.2	247.3	0.04	247.4	0.08	247.3	0.04	247.4	0.08	251.3	1.66	251.5	1.74
Pickle Lake 115 kV	120	0	N/A	0	N/A	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	123.5	124.5	0.81	123.6	0.08	123.6	0.08	123.6	0.08	124.2	0.57	124.4	0.73
Fort Frances 115 kV	118.6	116.3	-1.94	119.2	0.51	117.3	-1.10	119.4	0.67	112.9	-4.81	119.4	0.67
Mackenzie 115 kV	122.3	123.4	0.90	123.3	0.82	122.7	0.33	122.7	0.33	125.8	2.86	123.3	0.82
Moose Lake 115 kV	121.8	123.8	1.64	123.6	1.48	122.6	0.66	122.6	0.66	125.9	3.37	123.5	1.40
Birch 115 kV	123	121.7	-1.06	121.8	-0.98	121.7	-1.06	121.8	-0.98	123.6	0.49	123.6	0.49
Valora Jct 115 kV	120	125.6	4.67	125.1	4.25	121.1	0.92	121.2	1.00	0	N/A	0	N/A
Esker 115 kV	118.6	0	N/A	0	N/A	118.6	0.00	118.6	0.00	0	N/A	0	N/A
Musslewhite 115 kV	118.5	0	N/A	0	N/A	118.5	0.00	118.5	0.00	0	N/A	0	N/A
King Fisher 115 kV	127.9	0	N/A	0	N/A	127.9	0.00	127.9	0.00	0	N/A	0	N/A
Neskatanga 115 kV	123.3	0	N/A	0	N/A	123.3	0.00	123.3	0.00	0	N/A	0	N/A
Wunnumin 115 kV	128.9	0	N/A	0	N/A	128.9	0.00	128.9	0.00	0	N/A	0	N/A
Nibinamik 115 kV	130	0	N/A	0	N/A	130	0.00	130	0.00	0	N/A	0	N/A
Kingfisher Lake 115 kV	127.9	0	N/A	0	N/A	127.9	0.00	127.9	0.00	0	N/A	0	N/A
Wapekeka 115 kV	127.2	0	N/A	0	N/A	127.2	0.00	127.2	0.00	0	N/A	0	N/A
North Caribou Lake 115 kV	128.4	0	N/A	0	N/A	128.4	0.00	128.4	0.00	0	N/A	0	N/A
Muskrat Dam 115 kV	128.1	0	N/A	0	N/A	128.1	0.00	128.1	0.00	0	N/A	0	N/A
Crow River 115 kV	119.9	119.9	0.00	119.9	0.00	120	0.08	120	0.08	119.9	0.00	119.9	0.00
Thierry Mine 115 kV	120.1	120.1	0.00	120.1	0.00	120.2	0.08	120.2	0.08	120.1	0.00	120.1	0.00
Cat Lake 115 kV	122	122	0.00	122	0.00	122.2	0.16	122.2	0.16	121.9	-0.08	122	0.00
Slate Falls 115 kV	123.4	123.4	0.00	123.4	0.00	123.7	0.24	123.7	0.24	123.4	0.00	123.4	0.00
Ear Falls 115 kV	125.4	125.4	0.00	125.4	0.00	125.7	0.24	125.7	0.24	125.4	0.00	125.4	0.00
Domtar Dryden 115 kV	123.3	124.3	0.81	123.4	0.08	123.4	0.08	123.4	0.08	124	0.57	124.2	0.73
Perrault Falls 115 kV	124.3	124.6	0.24	124.3	0.00	125.3	0.80	125.4	0.88	124.5	0.16	124.6	0.24
Sam Lake 115 kV	121.9	123	0.90	122	0.08	122	0.08	122.1	0.16	122.7	0.66	122.9	0.82
Balmer 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00
Red Lake 115 kV	120.5	120.5	0.00	120.5	0.00	0	N/A	0	N/A	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.8	120.8	0.00	120.8	0.00	0	N/A	0	N/A	120.7	-0.08	120.8	0.00
Deer Lake 115 kV	120.4	120.4	0.00	120.4	0.00	0	N/A	0	N/A	120.4	0.00	120.4	0.00
Sandy Lake 115 kV	120	120	0.00	120	0.00	0	N/A	0	N/A	120	0.00	120	0.00

Table 70: HV Voltage Assessment for Test Case 4 – Valora Junction with All Elements in-service – Double Circuit Contingency (Continued)

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	123.4	123.9	0.41	123.4	0.00	123.5	0.08	123.6	0.16	123	-0.32	123.8	0.32
Agimak DS 115 kV	119.3	125.3	5.03	124.7	4.53	120.8	1.26	120.8	1.26	0	N/A	0	N/A
Mattabi CTS 115 kV	120	125.7	4.75	125.1	4.25	121.1	0.92	121.2	1.00	0	N/A	0	N/A
Valora DS 115 kV	120	125.6	4.67	125.1	4.25	121.1	0.92	121.2	1.00	0	N/A	0	N/A
Murillo DS 115 kV	122.5	121.7	-0.65	121.8	-0.57	121.7	-0.65	121.8	-0.57	123.5	0.82	123.3	0.65
Shabaqua DS 115 kV	122.2	122.8	0.49	122.9	0.57	122.8	0.49	122.9	0.57	124.5	1.88	123.8	1.31
Sapawe DS 115 kV	121.9	124.4	2.05	124.6	2.21	124.4	2.05	124.6	2.21	125.9	3.28	123.8	1.56
West Coast 115 kV	118.4	116.2	-1.86	119.1	0.59	117.2	-1.01	119.3	0.76	112.7	-4.81	119.2	0.68
Fort Frances MS 115 kV	118.6	116.3	-1.94	119.2	0.51	117.3	-1.10	119.4	0.67	112.8	-4.89	119.4	0.67
Burleigh DS 115 kV	118.5	116.2	-1.94	119.2	0.59	117.3	-1.01	119.4	0.76	112.8	-4.81	119.3	0.68

Table 71: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of Dryden Cap				Loss of 1 Pickle Lake SVC				Loss of Mackenzie SVC				Loss of Valora Cap			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	244.4	244.2	-0.08	244.2	-0.08	241.4	-1.23	240.5	-1.60	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00	244.4	0.00
Dryden 230 kV	245	245	0.00	244.6	-0.16	238.8	-2.53	235.8	-3.76	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Fort Frances 230 kV	245	245	0.00	244.6	-0.16	238.8	-2.53	235.8	-3.76	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Mackenzie 230 kV	245	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00	245	0.00
Lakehead 230 kV	247.2	247.2	0.00	247.2	0.00	247.1	-0.04	247.2	0.00	247.2	0.00	247.2	0.00	247.2	0.00	247.2	0.00	247.2	0.00	247.2	0.00
Pickle Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	123.5	122.5	-0.81	123.7	0.16	121	-2.02	123.9	0.32	123.5	0.00	123.5	0.00	123.5	0.00	123.5	0.00	123.4	-0.08	123.4	-0.08
Fort Frances 115 kV	118.6	118.5	-0.08	118.5	-0.08	117.9	-0.59	118	-0.51	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Mackenzie 115 kV	122.3	122.2	-0.08	122.3	0.00	122.1	-0.16	122.3	0.00	122.3	0.00	122.3	0.00	122.3	0.00	122.3	0.00	122.2	-0.08	122.2	-0.08
Moose Lake 115 kV	121.8	121.8	0.00	121.9	0.08	121.6	-0.16	121.9	0.08	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00	121.7	-0.08	121.7	-0.08
Birch 115 kV	123	123	0.00	123	0.00	123	0.00	123.1	0.08	123	0.00	123	0.00	123	0.00	123	0.00	123	0.00	123	0.00
Valora Jct 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	118.9	-0.92	119	-0.83
Esker 115 kV	118.6	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Musslewhite 115 kV	118.5	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00
King Fisher 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Neskatanga 115 kV	123.3	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00
Wunnumin 115 kV	128.9	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00
Nibinamik 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Kingfisher Lake 115 kV	127.9	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00	127.9	0.00
Wapekeka 115 kV	127.2	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00
North Caribou Lake 115 kV	128.4	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00	128.4	0.00
Muskrat Dam 115 kV	128.1	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00	128.1	0.00
Crow River 115 kV	119.9	113.1	-5.67	114.1	-4.84	119.2	-0.58	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00
Thierry Mine 115 kV	120.1	113.3	-5.66	114.4	-4.75	119.5	-0.50	120.2	0.08	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00
Cat Lake 115 kV	122	115.3	-5.49	116.4	-4.59	121.3	-0.57	122	0.00	122	0.00	122	0.00	122	0.00	122	0.00	121.9	-0.08	121.9	-0.08
Slate Falls 115 kV	123.4	117	-5.19	118.1	-4.29	122.8	-0.49	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00
Ear Falls 115 kV	125.4	120.2	-4.15	121.3	-3.27	124.9	-0.40	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	125.4	0.00	45.3	-63.88	45.3	-63.88
Domtar Dryden 115 kV	123.3	122.3	-0.81	123.5	0.16	120.8	-2.03	123.7	0.32	123.3	0.00	123.3	0.00	123.3	0.00	123.3	0.00	123.2	-0.08	123.2	-0.08
Perrault Falls 115 kV	124.3	120.2	-3.30	121.2	-2.49	123.1	-0.97	124.4	0.08	124.3	0.00	124.3	0.00	124.3	0.00	124.3	0.00	124.3	0.00	124.3	0.00
Sam Lake 115 kV	121.9	120.9	-0.82	122.2	0.25	119.4	-2.05	122.3	0.33	121.9	0.00	121.9	0.00	121.9	0.00	121.9	0.00	121.9	0.00	121.8	-0.08
Balmer 115 kV	120	113.9	-5.08	115	-4.17	119.5	-0.42	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	114.5	-4.98	115.5	-4.15	120	-0.41	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	120.8	114.6	-5.13	115.7	-4.22	120.4	-0.33	120.8	0.00	120.8	0.00	120.8	0.00	120.8	0.00	120.8	0.00	120.7	-0.08	120.7	-0.08
Deer Lake 115 kV	120.4	114.3	-5.07	115.5	-4.07	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00	120.4	0.00
Sandy Lake 115 kV	120	114	-5.00	115.2	-4.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00

Table 71: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of 1 Ear Falls				Loss of Dryden Cap				Loss of 1 Pickle Lake SVC				Loss of Mackenzie SVC				Loss of Valora Cap			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	123.4	122.7	-0.57	123.6	0.16	121.3	-1.70	124	0.49	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00	123.4	0.00
Agimak DS 115 kV	119.3	119	-0.25	119.3	0.00	118.6	-0.59	119.4	0.08	119.3	0.00	119.3	0.00	119.3	0.00	119.3	0.00	118.7	-0.50	118.7	-0.50
Mattabi CTS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	118.9	-0.92	119	-0.83
Valora DS 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	118.9	-0.92	119	-0.83
Murillo DS 115 kV	122.5	122.4	-0.08	122.5	0.00	122.4	-0.08	122.5	0.00	122.5	0.00	122.5	0.00	122.5	0.00	122.5	0.00	122.4	-0.08	122.4	-0.08
Shabaqua DS 115 kV	122.2	122.2	0.00	122.2	0.00	122.1	-0.08	122.2	0.00	122.2	0.00	122.2	0.00	122.2	0.00	122.2	0.00	122.2	0.00	122.2	0.00
Sapawe DS 115 kV	121.9	121.8	-0.08	121.9	0.00	121.7	-0.16	121.9	0.00	121.9	0.00	121.9	0.00	121.9	0.00	121.9	0.00	121.8	-0.08	121.8	-0.08
West Coast 115 kV	118.4	118.4	0.00	118.4	0.00	117.7	-0.59	117.9	-0.42	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00
Fort Frances MS 115 kV	118.6	118.5	-0.08	118.5	-0.08	117.9	-0.59	118	-0.51	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00	118.6	0.00
Burleigh DS 115 kV	118.5	118.5	0.00	118.5	0.00	117.8	-0.59	118	-0.42	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00

Table 72: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Kenora 230 kV	244.8	246.9	0.86	247.2	0.98	244.8	0.00	244.8	0.00	244.8	0.00	244.8	0.00
Dryden 230 kV	245	248.1	1.27	248.9	1.59	245	0.00	245	0.00	245	0.00	245	0.00
Fort Frances 230 kV	245	248.1	1.27	248.9	1.59	245	0.00	245	0.00	245	0.00	245	0.00
Mackenzie 230 kV	242.7	248.7	2.47	249.3	2.72	242.7	0.00	242.7	0.00	242.7	0.00	242.7	0.00
Lakehead 230 kV	238.3	240.3	0.84	240.4	0.88	238.3	0.00	238.3	0.00	238.3	0.00	238.3	0.00
Pickle Lake 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Dryden 115 kV	124.4	125.9	1.21	124.8	0.32	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00
Fort Frances 115 kV	118.5	119.9	1.18	120.1	1.35	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00
Mackenzie 115 kV	120.9	123.4	2.07	122.1	0.99	120.9	0.00	120.9	0.00	120.9	0.00	120.9	0.00
Moose Lake 115 kV	121.4	123.6	1.81	122.5	0.91	121.4	0.00	121.4	0.00	121.4	0.00	121.4	0.00
Birch 115 kV	121.3	122.4	0.91	122.4	0.91	121.3	0.00	121.3	0.00	121.3	0.00	121.3	0.00
Valora Jct 115 kV	123.2	125.1	1.54	124	0.65	123.2	0.00	123.2	0.00	123.2	0.00	123.2	0.00
Esker 115 kV	120.1	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00	120.1	0.00
Musslewhite 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
King Fisher 115 kV	126.8	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00	126.8	0.00
Neskatanga 115 kV	124.4	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00
Wunnumin 115 kV	128.2	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00	128.2	0.00
Nibinamik 115 kV	130	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00	130	0.00
Kingfisher Lake 115 kV	127.2	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00	127.2	0.00
Wapekeka 115 kV	127.8	127.8	0.00	127.8	0.00	127.8	0.00	127.8	0.00	127.8	0.00	127.8	0.00
North Caribou Lake 115 kV	128.6	128.6	0.00	128.6	0.00	128.6	0.00	128.6	0.00	128.6	0.00	128.6	0.00
Muskrat Dam 115 kV	128.9	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00	128.9	0.00
Crow River 115 kV	120	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00	120	0.00
Thierry Mine 115 kV	119.9	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00	119.9	0.00
Cat Lake 115 kV	121.8	122.1	0.25	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00	121.8	0.00
Slate Falls 115 kV	122.8	123.3	0.41	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00
Ear Falls 115 kV	122.8	123.8	0.81	122.9	0.08	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00
Domtar Dryden 115 kV	124.4	125.9	1.21	124.7	0.24	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00
Perrault Falls 115 kV	123.2	124.4	0.97	123.4	0.16	123.2	0.00	123.2	0.00	123.2	0.00	123.2	0.00
Sam Lake 115 kV	123.9	125.4	1.21	124.2	0.24	123.9	0.00	123.9	0.00	123.9	0.00	123.9	0.00
Balmer 115 kV	120	121.1	0.92	120.1	0.08	120	0.00	120	0.00	120	0.00	120	0.00
Red Lake 115 kV	120.5	121.6	0.91	120.6	0.08	120.5	0.00	120.5	0.00	120.5	0.00	120.5	0.00
Pikangikum 115 kV	123.8	124.9	0.89	123.9	0.08	123.8	0.00	123.8	0.00	123.8	0.00	123.8	0.00
Deer Lake 115 kV	126	127.2	0.95	126.1	0.08	126	0.00	126	0.00	126	0.00	126	0.00
Sandy Lake 115 kV	126.1	127.3	0.95	126.2	0.08	126.1	0.00	126.1	0.00	126.1	0.00	126.1	0.00

Table 72: HV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions (Continued)

Bus Name	Pre-Cont	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Vermillion Bay DS 115 kV	124.4	125.7	1.05	124.9	0.40	124.4	0.00	124.4	0.00	124.4	0.00	124.4	0.00
Agimak DS 115 kV	122.8	124.7	1.55	123.5	0.57	122.8	0.00	122.8	0.00	122.8	0.00	122.8	0.00
Mattabi CTS 115 kV	123.2	125.1	1.54	124	0.65	123.2	0.00	123.2	0.00	123.2	0.00	123.2	0.00
Valora DS 115 kV	123.2	125.1	1.54	124	0.65	123.2	0.00	123.2	0.00	123.2	0.00	123.2	0.00
Murillo DS 115 kV	121.2	122.3	0.91	122.2	0.83	121.2	0.00	121.2	0.00	121.2	0.00	121.2	0.00
Shabaqua DS 115 kV	121.5	123	1.23	122.6	0.91	121.5	0.00	121.5	0.00	121.5	0.00	121.5	0.00
Sapawe DS 115 kV	121.6	123.7	1.73	122.7	0.90	121.6	0.00	121.6	0.00	121.6	0.00	121.6	0.00
West Coast 115 kV	118.4	119.8	1.18	120	1.35	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00
Fort Frances MS 115 kV	118.5	119.9	1.18	120.1	1.35	118.5	0.00	118.5	0.00	118.5	0.00	118.5	0.00
Burleigh DS 115 kV	118.4	119.9	1.27	120	1.35	118.4	0.00	118.4	0.00	118.4	0.00	118.4	0.00

Table 73: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Single Circuit Contingency

Bus Name	Pre-Cont	Loss of A21L				Loss of D26A				Loss of F25A				Loss of K23D				Loss of 1 Manitou Falls Unit			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.9	24.4	-2.01	24.9	0.00	24.9	0.00	24.9	0.00	25	0.40	25	0.40	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Shabaqua DS LV	13.1	12.8	-2.29	12.8	-2.29	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Sapawe DS LV	13.8	13.6	-1.45	13.7	-0.72	13.8	0.00	13.7	-0.72	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00
Mattabi DS LV	4.1	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00
Agimak DS LV	26.2	26.1	-0.38	26.2	0.00	26.5	1.15	26.5	1.15	26.1	-0.38	26.4	0.76	26.2	0.00	26.3	0.38	26.2	0.00	26.2	0.00
Valora DS LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Esker LV	13.9	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Wunnumin LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Nibinamik LV	24.6	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00
King Fisher Lake LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Wapekeka LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
North Caribou Lake LV	24.4	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00
Muskrat LV	27.3	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00
Crow River LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Thierry Mine LV	4.4	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00
Cat Lake LV	29.2	29.2	0.00	29.2	0.00	29.3	0.34	29.2	0.00	29.2	0.00	29.3	0.34	29.2	0.00	29.5	1.03	29.2	0.00	29.2	0.00
Slate Falls LV	23.7	23.7	0.00	23.7	0.00	23.8	0.42	23.7	0.00	23.7	0.00	23.8	0.42	23.7	0.00	23.8	0.42	23.7	0.00	23.7	0.00
Ear Falls LV	45.3	45.3	0.00	45.3	0.00	45.4	0.22	45.3	0.00	45.3	0.00	45.4	0.22	45.3	0.00	45.4	0.22	45.3	0.00	45.3	0.00
Domtar Dryden LV	13.6	13.6	0.00	13.6	0.00	13.7	0.74	13.6	0.00	13.5	-0.74	13.6	0.00	13.6	0.00	13.7	0.74	13.6	0.00	13.6	0.00
Perrault Falls LV	11.7	11.6	-0.85	11.7	0.00	11.7	0.00	11.7	0.00	11.6	-0.85	11.7	0.00	11.6	-0.85	11.7	0.00	11.6	-0.85	11.6	-0.85
Sam Lake LV	26.4	26.4	0.00	26.4	0.00	26.6	0.76	26.5	0.38	26.3	-0.38	26.4	0.00	26.4	0.00	26.7	1.14	26.4	0.00	26.4	0.00
Balmer LV	43.2	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00
Red Lake LV	46.3	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Pikangikum LV	27.3	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.2	-0.37	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00
Deer Lake LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Sandy Lake LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.3	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00	13.2	-0.75	13.3	0.00	13.2	-0.75	13.4	0.75	13.3	0.00	13.3	0.00
Vermillion Bay DS LV	15.1	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00	15	-0.66	15.1	0.00	15	-0.66	15.2	0.66	15.1	0.00	15.1	0.00
Burleigh DS LV	13.1	13.1	0.00	13.1	0.00	13	-0.76	12.9	-1.53	12.8	-2.29	13.1	0.00	13	-0.76	13	-0.76	13.1	0.00	13.1	0.00
Fort Frances MS1 LV	14.1	14.1	0.00	14.1	0.00	14	-0.71	14	-0.71	13.8	-2.13	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances MS2 LV	12.5	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.2	-2.40	12.5	0.00	12.4	-0.80	12.4	-0.80	12.5	0.00	12.5	0.00
Fort Frances L5	14.2	14.2	0.00	14.2	0.00	14.1	-0.70	14	-1.41	13.8	-2.82	14.1	-0.70	14.1	-0.70	14.1	-0.70	14.2	0.00	14.2	0.00
Fort Frances L4A	14	14	0.00	14	0.00	13.9	-0.71	13.9	-0.71	13.7	-2.14	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00
Fort Frances L4B	14.8	14.9	0.68	14.9	0.68	14.7	-0.68	14.7	-0.68	14.6	-1.35	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00
Fort Frances AB	6.7	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.6	-1.49	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00

Table 74: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Double Circuit Contingency

Bus Name	Pre-Cont	Loss of AxLs and Cross-Trip B6M + Pickle Lake Line				Loss of AxLs and Cross-Trip B6M + E2R Lines				Loss of D26A + F25A and Cross-Trip M2D			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
	Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.9	24.7	-0.80	24.9	0.00	24.7	-0.80	24.9	0.00	25.1	0.80	25.1	0.80
Shabaqua DS LV	13.1	13.1	0.00	13.2	0.76	13.1	0.00	13.2	0.76	13.3	1.53	13.3	1.53
Sapawe DS LV	13.8	14.1	2.17	14.1	2.17	14.1	2.17	14.1	2.17	14.2	2.90	14	1.45
Mattabi DS LV	4.1	4.3	4.88	4.3	4.88	4.1	0.00	4.1	0.00	0	N/A	0	N/A
Agimak DS LV	26.2	27.5	4.96	26.7	1.91	26.6	1.53	26.6	1.53	0	N/A	0	N/A
Valora DS LV	24.9	26.1	4.82	26	4.42	25.2	1.20	25.2	1.20	0	N/A	0	N/A
Esker LV	13.9	0	N/A	0	N/A	13.9	0.00	13.9	0.00	0	N/A	0	N/A
Musselwhite LV	4.2	0	N/A	0	N/A	4.2	0.00	4.2	0.00	0	N/A	0	N/A
Neskatanga LV	27.7	0	N/A	0	N/A	27.7	0.00	27.7	0.00	0	N/A	0	N/A
Wunnumin LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	0	N/A	0	N/A
Nibinamik LV	24.6	0	N/A	0	N/A	24.6	0.00	24.6	0.00	0	N/A	0	N/A
King Fisher Lake LV	24.7	0	N/A	0	N/A	24.7	0.00	24.7	0.00	0	N/A	0	N/A
Wapekeka LV	27.5	0	N/A	0	N/A	27.5	0.00	27.5	0.00	0	N/A	0	N/A
North Caribou Lake LV	24.4	0	N/A	0	N/A	24.4	0.00	24.4	0.00	0	N/A	0	N/A
Muskrat LV	27.3	0	N/A	0	N/A	27.3	0.00	27.3	0.00	0	N/A	0	N/A
Crow River LV	27.8	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Thierry Mine LV	4.4	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00
Cat Lake LV	29.2	29.2	0.00	29.2	0.00	29.3	0.34	29.3	0.34	29.2	0.00	29.2	0.00
Slate Falls LV	23.7	23.7	0.00	23.7	0.00	23.8	0.42	23.8	0.42	23.7	0.00	23.7	0.00
Ear Falls LV	45.3	45.3	0.00	45.3	0.00	45.5	0.44	45.5	0.44	45.3	0.00	45.3	0.00
Domtar Dryden LV	13.6	13.7	0.74	13.6	0.00	13.6	0.00	13.6	0.00	13.7	0.74	13.7	0.74
Perrault Falls LV	11.7	11.7	0.00	11.7	0.00	11.8	0.85	11.8	0.85	11.7	0.00	11.7	0.00
Sam Lake LV	26.4	26.7	1.14	26.5	0.38	26.5	0.38	26.5	0.38	26.6	0.76	26.7	1.14
Balmer LV	43.2	43.2	0.00	43.2	0.00	0	N/A	0	N/A	43.2	0.00	43.2	0.00
Red Lake LV	46.3	46.3	0.00	46.3	0.00	0	N/A	0	N/A	46.3	0.00	46.3	0.00
Pikangikum LV	27.3	27.3	0.00	27.3	0.00	0	N/A	0	N/A	27.3	0.00	27.3	0.00
Deer Lake LV	27.5	27.5	0.00	27.5	0.00	0	N/A	0	N/A	27.5	0.00	27.5	0.00
Sandy Lake LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.3	13.4	0.75	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00
Vermillion Bay DS LV	15.1	15.2	0.66	15.1	0.00	15.1	0.00	15.1	0.00	15	-0.66	15.1	0.00
Burleigh DS LV	13.1	12.8	-2.29	13.1	0.00	12.9	-1.53	13.2	0.76	12.4	-5.34	13.2	0.76
Fort Frances MS1 LV	14.1	13.8	-2.13	14.2	0.71	14	-0.71	14.2	0.71	13.4	-4.96	14.2	0.71
Fort Frances MS2 LV	12.5	12.2	-2.40	12.5	0.00	12.3	-1.60	12.6	0.80	11.8	-5.60	12.5	0.00
Fort Frances L5	14.2	13.9	-2.11	14.2	0.00	14	-1.41	14.3	0.70	13.4	-5.63	14.3	0.70
Fort Frances L4A	14	13.8	-1.43	14.1	0.71	13.9	-0.71	14.1	0.71	13.3	-5.00	14.1	0.71
Fort Frances L4B	14.8	14.6	-1.35	14.9	0.68	14.7	-0.68	15	1.35	14.1	-4.73	14.9	0.68
Fort Frances AB	6.7	6.6	-1.49	6.8	1.49	6.7	0.00	6.8	1.49	6.4	-4.48	6.8	1.49

Table 75: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Peak Load Conditions

Bus Name	Pre-Cont	Loss of 1 Ear Falls SVC				Loss of Dryden Cap				Loss of 1 Pickle Lake SVC				Loss of 1 Mackenzie SVC				Loss of Valora Cap			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)
Murillo DS LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Shabaqua DS LV	13.1	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Sapawe DS LV	13.8	13.8	0.00	13.8	0.00	13.7	-0.72	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00
Mattabi DS LV	4.1	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00	4.1	0.00
Agimak DS LV	26.2	26.2	0.00	26.2	0.00	26.1	-0.38	26.6	1.53	26.2	0.00	26.2	0.00	26.2	0.00	26.2	0.00	26.1	-0.38	26.4	0.76
Valora DS LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.7	-0.80	24.7	-0.80
Esker LV	13.9	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Wunnumin LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Nibinamik LV	24.6	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00	24.6	0.00
King Fisher Lake LV	24.7	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00	24.7	0.00
Wapekeka LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
North Caribou Lake LV	24.4	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00	24.4	0.00
Muskrat LV	27.3	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00
Crow River LV	27.8	26.2	-5.76	27.4	-1.44	27.7	-0.36	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00	27.8	0.00
Thierry Mine LV	4.4	4.1	-6.82	4.2	-4.55	4.3	-2.27	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00	4.4	0.00
Cat Lake LV	29.2	27.6	-5.48	29	-0.68	29.1	-0.34	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00
Slate Falls LV	23.7	22.5	-5.06	22.7	-4.22	23.6	-0.42	23.8	0.42	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00	23.7	0.00
Ear Falls LV	45.3	43.3	-4.42	43.7	-3.53	45.2	-0.22	45.4	0.22	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00	45.3	0.00
Domtar Dryden LV	13.6	13.5	-0.74	13.6	0.00	13.3	-2.21	13.6	0.00	13.6	0.00	13.6	0.00	13.6	0.00	13.6	0.00	13.6	0.00	13.6	0.00
Perrault Falls LV	11.7	11.2	-4.27	11.4	-2.56	11.5	-1.71	11.7	0.00	11.7	0.00	11.7	0.00	11.7	0.00	11.7	0.00	11.6	-0.85	11.6	-0.85
Sam Lake LV	26.4	26.2	-0.76	26.5	0.38	25.9	-1.89	26.7	1.14	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00
Balmer LV	43.2	41	-5.09	43.5	0.69	43	-0.46	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00
Red Lake LV	46.3	44	-4.97	46	-0.65	46.1	-0.43	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00	46.3	0.00
Pikangikum LV	27.3	25.8	-5.49	27.4	0.37	27.2	-0.37	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00
Deer Lake LV	27.5	26	-5.45	27.3	-0.73	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Sandy Lake LV	27.5	26.4	-4.00	27.3	-0.73	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Eton DS LV	13.3	13.2	-0.75	13.4	0.75	13	-2.26	13.4	0.75	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00
Vermillion Bay DS LV	15.1	15	-0.66	15.1	0.00	14.8	-1.99	15.2	0.66	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00	15.1	0.00
Burleigh DS LV	13.1	13.1	0.00	13.1	0.00	13	-0.76	13	-0.76	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Fort Frances MS1 LV	14.1	14.1	0.00	14.1	0.00	14	-0.71	14	-0.71	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances MS2 LV	12.5	12.5	0.00	12.5	0.00	12.4	-0.80	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00
Fort Frances L5	14.2	14.2	0.00	14.2	0.00	14.1	-0.70	14.1	-0.70	14.2	0.00	14.2	0.00	14.2	0.00	14.2	0.00	14.2	0.00	14.2	0.00
Fort Frances L4A	14	14	0.00	14	0.00	13.9	-0.71	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00	14	0.00
Fort Frances L4B	14.8	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00
Fort Frances AB	6.7	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00	6.7	0.00

Table 76: LV Voltage Assessment for Test Case 4 – Dinorwic Junction with All Elements in-service – Loss of Reactive Devices under Light Load Conditions

Bus Name	Pre-Cont Volt (kV)	Loss of Mackenzie Reactor				Loss of 1 Pickle Lake SVC				Loss of 1 Kingfisher Reactor			
		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC		Pre-ULTC		Post-ULTC	
		Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %	Volt (kV)	V _{ch} %
Murillo DS LV	24.9	25.2	1.20	25.2	1.20	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Shabaqua DS LV	13.1	13.2	0.76	13.2	0.76	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Sapawe DS LV	13.7	14	2.19	13.9	1.46	13.7	0.00	13.7	0.00	13.7	0.00	13.7	0.00
Mattabi DS LV	4.2	4.3	2.38	4.3	2.38	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Agimak DS LV	26.4	26.8	1.52	26.5	0.38	26.4	0.00	26.4	0.00	26.4	0.00	26.4	0.00
Valora DS LV	25.6	26	1.56	25.8	0.78	25.6	0.00	25.6	0.00	25.6	0.00	25.6	0.00
Esker LV	13.8	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00	13.8	0.00
Musselwhite LV	4.2	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00	4.2	0.00
Neskatanga LV	27.7	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00	27.7	0.00
Wunnumin LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Nibinamik LV	25.3	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00	25.3	0.00
King Fisher Lake LV	24.9	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00	24.9	0.00
Wapekeka LV	27.6	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00
North Caribou Lake LV	25.1	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00	25.1	0.00
Muskrat LV	27.5	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Crow River LV	27.4	27.4	0.00	27.4	0.00	27.4	0.00	27.4	0.00	27.4	0.00	27.4	0.00
Thierry Mine LV	4.3	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00	4.3	0.00
Cat Lake LV	29.2	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00	29.2	0.00
Slate Falls LV	23.9	24	0.42	23.9	0.00	23.9	0.00	23.9	0.00	23.9	0.00	23.9	0.00
Ear Falls LV	44.6	45	0.90	44.6	0.00	44.6	0.00	44.6	0.00	44.6	0.00	44.6	0.00
Domtar Dryden LV	13.9	14	0.72	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00	13.9	0.00
Perrault Falls LV	11.7	11.9	1.71	11.8	0.85	11.7	0.00	11.7	0.00	11.7	0.00	11.7	0.00
Sam Lake LV	26.5	26.8	1.13	26.3	-0.75	26.5	0.00	26.5	0.00	26.5	0.00	26.5	0.00
Balmer LV	43.2	43.6	0.93	43.3	0.23	43.2	0.00	43.2	0.00	43.2	0.00	43.2	0.00
Red Lake LV	46.4	46.8	0.86	46.4	0.00	46.4	0.00	46.4	0.00	46.4	0.00	46.4	0.00
Pikangikum LV	27.5	27.8	1.09	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00	27.5	0.00
Deer Lake LV	27.3	27.6	1.10	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00	27.3	0.00
Sandy Lake LV	27.6	27.9	1.09	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00	27.6	0.00
Eton DS LV	13.3	13.5	1.50	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00	13.3	0.00
Vermillion Bay DS LV	15.2	15.4	1.32	15.3	0.66	15.2	0.00	15.2	0.00	15.2	0.00	15.2	0.00
Burleigh DS LV	13.1	13.3	1.53	13.3	1.53	13.1	0.00	13.1	0.00	13.1	0.00	13.1	0.00
Fort Frances MS1 LV	14.1	14.3	1.42	14.3	1.42	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances MS2 LV	12.5	12.7	1.60	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00	12.5	0.00
Fort Frances L5	14.3	14.5	1.40	14.5	1.40	14.3	0.00	14.3	0.00	14.3	0.00	14.3	0.00
Fort Frances L4A	14.1	14.2	0.71	14.3	1.42	14.1	0.00	14.1	0.00	14.1	0.00	14.1	0.00
Fort Frances L4B	14.8	15	1.35	15	1.35	14.8	0.00	14.8	0.00	14.8	0.00	14.8	0.00
Fort Frances AB	6.9	7	1.45	7	1.45	6.9	0.00	6.9	0.00	6.9	0.00	6.9	0.00

References

Document Name	Document ID
Ontario Resource and Transmission Assessment Criteria	IESO_REQ_0041
An Assessment of the Westward Transfer Capability of Various Options for Reinforcing the East-West Tie	IESO_REQ_0748

– End of Document –