



Preliminary Connection Guidance for Long-Term 2 Procurement

Independent Electricity System Operator
April 16, 2024

Table of Contents

Disclaimer	3
Executive Summary	4
1. Introduction	8
2. Zonal Probabilistic Limitations	10
2.1 Objective	10
2.2 Assumptions and Methodology	10
2.3 Results	11
3. Area Congestion Limitations	12
3.1 Objective	12
3.2 Assumptions and Methodology	12
3.3 Results	13
4. Inverter Based Resource Limitations	17
4.1 Objectives	17
4.2 Assumptions and Methodology	17
4.3 Results	18
4.3.1 Sub-Synchronous Resonance	18
4.3.2 Sub-Synchronous Control Interactions	19
4.4 Other Considerations	20
5. Circuit Congestion Limitations	21
5.1 Objective	21
5.2 Assumptions and Methodology	21
5.3 Results	21
5.4 Other Considerations	23
6. Short-Circuit & Protection Limitations (HONI transmission system only)	24
6.1 Objective	24

6.2 Assumptions and Methodology	24
6.3 Results	24
6.4 Constraints Due to Protection	25
7. Distribution Asset Limitations (only HONI stations)	27
8. General Considerations	28
9. Conclusions	30
10. References	31
11. Appendix A: Circuits with Restrictions	32



Disclaimer

This document and the information contained herein is provided for informational purposes only. The IESO has prepared this document based on information currently available to the IESO, including information provided by Hydro One Networks Inc., and reasonable assumptions associated therewith. The IESO undertakes no obligation to revise or update the information contained in this document, as a result of new information, future events or otherwise. The IESO and Hydro One Networks Inc. provide no guarantee, representation, or warranty, express or implied, with respect to any statement or information contained herein and disclaim any liability in connection therewith. In the event there is any conflict or inconsistency between this document and the IESO market rules, any IESO contract, any legislation or regulation, or any request for proposals or other procurement document, the terms in the market rules, or the subject contract, legislation, regulation, or procurement document, as applicable, govern.

Executive Summary

This document is intended to provide preliminary connection guidance information to potential proponents in the Long-Term 2 Request for Proposal (LT2 RFP), to help inform project siting decisions that minimize the risk of energy curtailments and the risk of negative reliability effects on the Ontario power grid. The deliverability process and preliminary guidance provided in this document are intended only for the procurement of energy under the LT2 RFP.

The deliverability process for the LT2 RFP is being developed to include the following two steps:

1. Provide early **preliminary connection guidance information** ahead of proposal submission to help proponents select project locations that will more likely contribute to addressing emerging energy reliability needs (this document);
2. Conduct an **evaluation stage deliverability test** for projects submitted to the LT2 RFP as part of the proposal evaluation stage to assess whether submitted projects can contribute effectively to addressing emerging reliability needs. The evaluation stage deliverability test methodology will be based on principles and criteria similar to those used in this document.

The IESO, with support from Hydro One Networks Inc. (HONI), has developed a set of preliminary connection guidance information, which considers both system congestion and system reliability factors.

To identify system congestion limitations, the IESO has used probabilistic resource assessments on a zonal basis, and load-flow assessments on an area (multi-zonal, zonal, sub-zonal) and circuit basis. Details about the assumptions used in each congestion-type assessment are presented in Sections 2, 3 and 5 of this document.

To mitigate the risk of undesirable system performance that could result from connecting large amounts of inverter-based resources (IBR) to certain parts of the grid, the IESO has determined limits of IBR that could connect to those parts of the system. Details about IBR assessment are presented in Section 4 of this document.

Section 6 presents details about equipment-type limitations, which include short-circuit limitations and protection adequacy limitations, as identified by HONI.

Finally, distribution related limitations are presented in Section 7 of this document. They include available capacity at HONI's stations that supply distribution systems.

Some locations could be subject to multiple types of limitations. Where multiple limitations apply to a particular location, the most constraining limitation should be used.

Table 1 summarizes the preliminary limits identified in this document, indicating the maximum new generation that could connect into an area. The values in **bold** indicate the most constraining limitation for a particular area.

Table 1 | Area Limitations Summary

Zone	IBR Limit¹ (MW)	Area Congestion Limit (MW)^{2,3}	Short Circuit Limited Stations (50 km radius)
Northwest	N/A	West of Wawa TS = 600	N/A
Northeast	N/A	East of Widdifield SS = 150 West of Mississagi TS = 1,350	N/A
Northern Ontario (Northwest + Northeast)	1,200	North, West and East of Hanmer TS = 1,600	N/A
Essa		East of Minden TS = 250	N/A
Ottawa		See East limits	N/A
East	East of Toronto = 1,400	East of Dobbin TS = 325 East of St. Lawrence TS = 250 East of Hinchinbrooke SS = 750 East of Lennox TS = 750 East of Bowmanville SS = 2,100	Lennox TS
Toronto	N/A	N/A	Cherrywood TS Clarington TS Richview TS Manby TS
Niagara ⁴		See Southwest limits	Beck 2 TS
Southwest	West of Toronto = 2,650	West of Detweiler TS = 500 West of Middleport TS = 1,000 West of Nanticoke TS = 1,000 West of Milton SS = 1,000	Trafalgar TS Burlington TS Richview TS Manby TS Owen Sound TS
Bruce ⁴		See West and Southwest Limits	N/A
West		West of Buchanan TS = 800 West of Chatham SS = 600	N/A

¹ Limitations in this column strictly apply to inverter-based resources.

² Area congestion limits are valid for new resources with capacity factors below 50%. The limits could be further reduced for new resources with a capacity factor above 50%.

³ Area congestion limits are approximations based on maximum generation that could be injected into the station mentioned as the area limit.

⁴ Zonal probabilistic limits for certain technologies in Bruce and Niagara zones are more restrictive – see section 2 of the document.

Figure 1 | Overall Northern Ontario Limitations Map





Figure 2 | Overall Southern Ontario Limitations Map



In addition to the zonal and area limitations above, to minimize local energy congestion or local reliability effects, the amount of generation that can connect directly to a circuit is limited, in general, as follows:

- 30 MW per 115 kV circuit in both Northern and Southern Ontario;
- 100 MW per 230 kV circuit in Northern Ontario and 230 kV radial circuit in Southern Ontario;
- 150 MW per 230 kV network circuit in Southern Ontario.

However, there are circuits that would need to be avoided, as well as circuits with available capacity below the bright-line thresholds mentioned above. Those circuits are listed in Appendix A of this document.

Section 8 of this document lists the main considerations that should be taken into account by the users of this guidance. The most notable of them include the following:

- The assessments did not consider projects that will be successful in LT1 RFP, as those projects were not known at the time the analysis was performed. LT1 projects, and other projects as they become committed, could affect the findings presented in this document;
- The conclusions of this document are highly dependent on the size and location of LT2 RFP proposals in the same electrical proximity. As a result, proposals in LT2 RFP may end up competing for the same transmission system availability during the evaluation stage deliverability test.


As this document is only providing preliminary connection guidelines, proponents are still free to submit proposals for projects at locations either not assessed in this document or recommended to avoid, as well as proposals for project sizes that exceed the limits presented in this document. However, there is a higher risk to those proposals during the evaluation stage deliverability test.

1. Introduction

On December 13, 2023, the IESO held a webinar where it provided an update on emerging system reliability needs and announced its intent to pursue a cadence of procurements that will help to competitively acquire energy and capacity to meet those needs. At that time, the IESO presented on the upcoming LT2 RFP, providing a high-level overview of the expected procurement design, revenue model and deliverability considerations.

The goal of the LT2 RFP is to secure 5 TWh of energy (or approximately 2,000 MW of capacity) from non-emitting resources to connect by 2030. The proposed LT2 RFP timelines, and the stage where we currently stand, is presented in Figure 3.

Figure 3 | LT2 Procurement Timeline



Since the LT2 RFP is designed to primarily address an energy need, the approach for ensuring procured resources contribute towards the reliability need will be different from past E-LT1 and LT1 RFPs that mainly addressed a capacity need (i.e., the ability to meet system needs at peak times). During the December 2023, February 2024 and April 2024 LT2 RFP webinars, the IESO has proposed a deliverability process comprised of two steps:

1. Provide early **preliminary connection guidance information** ahead of proposal submission to help proponents select projects locations that will more likely contribute to addressing emerging energy reliability needs (this document);
2. Conduct an **evaluation stage deliverability test** for projects submitted to the LT2 RFP as part of the proposal evaluation stage, to assess whether submitted projects can contribute effectively to addressing emerging reliability needs. The evaluation stage deliverability test methodology will be based on principles and criteria similar to those used in the development of this guidance document. The energy deliverability evaluation methodology is under development at this time, and will be provided at a later date.

Stakeholders provided feedback that showed support for this approach, and indicated they would like to know availability and congestion data on a zonal, circuit and bus basis across Ontario.

To respond to the needs of stakeholders, the IESO, with support from HONI, have developed preliminary connection guidance information that takes into account six types of limitations, as follows:

1. Zonal probabilistic limitations – identify the total new generation that could connect into each of Ontario’s electrical zones with a positive contribution to Ontario’s global resource adequacy, by using a probabilistic resource assessment;
2. Area (multi-zonal, zonal, sub-zonal) congestion limitations – identify the total new generation that can connect into an area and result in a minimum risk of energy curtailments by using load-flow simulations;
3. Inverter-based resource limitations – identify the total amount of new inverter-based generation that can connect to a zone or a circuit and minimize the possibility of unwanted sub-synchronous control interactions (SSCI) with other inverter-based resources and sub-synchronous resonance (SSR) with series capacitors;
4. Circuit congestion limitations – identify the total amount of new generation that can connect to a circuit and result in a minimum risk of energy curtailments by using load-flow simulations;
5. Short-circuit & protection limitations (HONI system only) – identify areas where new resources should avoid connecting because short-circuit levels may exceed the capability of the transmission equipment or circuit protections may become inadequate;
6. Distribution asset limitations (HONI stations only) – identify available capacity at distribution level assets.

The following sections of the document present the objective, methodology, assumptions and results for each of the six types of limitations.

Some locations could be subject to multiple types of limitations. For example, availability in a distribution system identified through Section 7 could be further restricted by transmission-level limitations that are applicable to the station, or the area, the distribution system connects to. As well, multiple types of limitations could apply to the transmission connections. Where multiple limitations apply to a particular location, the most constraining limitation should be used.

The preliminary connection guidance information in this document is presented to help potential LT2 RFP proponents identify project locations where a project is more likely to be found deliverable in the evaluation stage deliverability assessment of the LT2 RFP.

2. Zonal Probabilistic Limitations

2.1 Objective


The goal of the probabilistic zonal energy assessment performed was to determine the total new capacity that could be added into an electrical zone and have a positive contribution towards provincial resource adequacy. New energy resources in a zone can contribute toward provincial resource adequacy when the energy is not congested at times of system need. The limit on the total capacity for each zone was determined for scenarios with new generation composed of 100% wind, 100% solar, and a solar - wind energy mix. Limitations for other non-emitting technologies, such as hydro or biomass, would depend on their respective capacity factors and production profiles.

2.2 Assumptions and Methodology

To calculate the zonal probabilistic limitations, the methodology used for 'perfect capacity' assessments was modified for renewables. This methodology is outlined in the Annual Planning Outlook: Supply, Adequacy and Energy Outlook Module [1], and is detailed as follows.

Zonal capacity limits are calculated using zonal constraint curves. Zonal constraint curves are developed by adding or removing capacity in a zone and removing or adding a corresponding amount of capacity in the rest of the system, such that the total incremental capacity is constant. The zonal constraint curve is developed using a 'two-zone' representation of the transmission system. The only interfaces that are represented in the capacity adequacy tool should be those that are connected to the study zone; the remainder are removed or set to a non-limiting value. The resulting system loss-of-load expectation (LOLE)¹ across a range of study zone capacities creates the zonal constraint curve, as shown in Figure 4.

Figure 4 | General Shape of Zonal Constraint Curve



¹ Loss-of-load expectation represents the expected probability of occurrence of a power system's inability to meet the demand for electricity within a specified period.

The flat portion of the curve represents the range of study zone capacity where the system LOLE will remain approximately unchanged for an equal and offsetting amount of capacity in the rest of the system. Where the curve slopes downwards to the left, LOLE is decreasing as study zone MWs are added and an equal amount of MWs are removed from the rest of the system. This indicates that additional MWs in the study zone improve total system adequacy. When the curve starts to rise, those additional MW cannot be fully utilized to offset capacity in the rest of the system and a zonal maximum can be established where the LOLE is greater than the LOLE threshold.²

2.3 Results

For the LT2 RFP preliminary connection guidance, the IESO determined the following zonal limits for new generators that could contribute to the adequacy needs of the system and avoid or minimize energy curtailments in each electrical zone, as shown in Table 2.

Table 2 | LT2 RFP Zonal Capacity Limits

Zone	Solar only Maximum (MW)¹	Wind only Maximum (MW)¹	Mix Solar & Wind Maximum (Solar MW, Wind MW)¹	Other Non- Emitting Technologies
Northwest	1,200	1,400	1,200, 600	Zone limits are project dependent
Northeast	2,000	1,800	1,600, 800	
NE + NW	2,000	1,800	1,600, 800	
East	Maximum Studied	1,800	Maximum Studied, 1,800	
Ottawa	2,400	Maximum Studied	1,600, 800	
Essa	Maximum Studied	Maximum Studied	Maximum Studied	
Southwest	Maximum Studied	Maximum Studied	Maximum Studied	
West	2,000	800	1,600, 800	
Niagara	800	0	N/A	
Bruce	0	1,800	N/A	
Toronto	2,400	0	N/A	

¹The studies for each zone have tested up to 2,000 MW of wind and up to 4,000 MW of solar generation (solar has a lower capacity factor than wind), and up to 1,000 MW wind + 2,000 MW solar in the mixed case.

² LOLE threshold = System LOLE using target capacity requirement (per seasonal allocation) + 0.001 days/year

3. Area Congestion Limitations

3.1 Objective

The goal of the area (multi-zonal, zonal, sub-zonal) congestion limitation guidance assessment is to determine the total amount of new generation that can connect into an area and have a minimum risk of energy curtailment to prevent thermal overload of the transmission equipment downstream of that area.

3.2 Assumptions and Methodology

To determine area congestion limitations, the IESO created three main basecases for three larger sub-systems of focus:

- Northern Ontario sub-system – includes the Northwest and Northeast electrical zones;
- West of Toronto sub-system – includes the Southwest, West, Bruce and Niagara electrical zones;
- East of Toronto sub-system – includes the Essa, East and Ottawa electrical zones.

Each of these cases was adjusted to deliver energy towards Toronto, and included the following assumptions:

- 2030 coincident minimum load demand for each sub-system of focus, as per the 2024 Annual Planning Outlook (APO) forecast;
- Non-energy-limiting resources, such as nuclear generators, gas generators and run-of the river hydro, were assumed in service at their maximum or normal operating output; with the exception of quick-starting gas fired generators, two Lennox units and one Bruce generating unit, which were assumed out of service;
- Dispatchable energy-limited resources, such as hydroelectric plants, were assumed at 50th percentile MW production, because they were considered able to generate around the intermittent resources and maximize the use of the transmission system;
- Existing wind and solar resources were assumed at 90% of their installed capacity;
- All contracted E-LT1 RFP resources were assumed in service, with the storage resources charging at 50% capacity;
- All major transmission projects committed to come into service by 2030 were considered, as per 2024 APO;
- This analysis did not consider any of the potential LT1 RFP projects that will connect to the system, as the successful projects were not known at the time the analysis was performed;
- Summer thermal ratings were used;

- For any results that indicated a high level of congestion due to high natural gas generation output, additional sub-cases were tested, one with a 50th percentile demand forecast, and one with 50% gas fired generation level. The lowest limit between the two sub-cases is reported for the area limits.

For each of the three cases and sub-cases developed, new generation was injected at various major stations until pre or post-contingency thermal violations were observed. The use of Remedial Action Schemes (RAS) for the purpose of accommodating new resources was not considered in the assessments to avoid reliance on RAS with all transmission elements in-service.

The maximum injection determined using the methodology above was used as an approximation for the amount of generation that could connect into the area upstream of the station under assessment, and includes the station under assessment. For those scenarios where any upstream transmission circuits are recommended to be avoided (as per Appendix A), new generators may be required to connect directly into the stations.

3.3 Results

For Northern Ontario, the following limitations were identified:

Table 3 | Northern Ontario Area Congestion Limits


Area	Area Limit (MW) ²
Northwest ¹	600
West of Mississagi TS	1,350
East of Widdifield SS	150
Northern Ontario	1,600

¹The West of MacKenzie TS and West of Lakehead TS areas were tested and are not limiting beyond the West of Wawa zone.

²Area limits are approximations based on maximum generation that could be injected into the station.

Figure 5 illustrates approximate geographical boundaries for each area above.

Figure 5 | Area Congestion Limits within Northern Ontario



In addition, certain areas that are prone to transient instability and where congestion is often present, such as North and West of Pinard TS, the 115 kV system North of Lakehead TS and the 115 kV system North of Kenora TS, are also to be avoided.


For the West of Toronto scenario, the following area limitations were determined:

Table 4 | West of Toronto Area Congestion Limits

Area	Area Limit (MW)
West of Chatham SS	600
West of Buchanan TS	800
West of Detweiler TS	500
West of Middleport TS	1,000
West of Nanticoke TS	1,000
West of Milton SS	1,000

Figure 6 shows the approximate geographical boundaries for some of the areas above.

Figure 6 | Area Congestion Limits for West of Toronto



For the East of Toronto scenario, the following area limitations were determined:

Table 5 | East of Toronto Area Congestion Limits

Area	Area Limit (MW)
East of Dobbin TS	325
East of Minden TS	250
East of St. Lawrence TS	250
East of Hinchinbrooke TS	750
East of Lennox TS	750
East of Bowmanville SS	2,100

Figure 7 shows the approximate geographical boundaries for some of the areas above.

Figure 7 | Area Congestion Limits for East of Toronto



In addition, certain areas that are prone to transient instability and where congestion is often present, such as the Madawaska 115 kV system, should also be avoided.

4. Inverter Based Resource Limitations

4.1 Objectives

The goal of the Inverter Based Resource (IBR) limitations guidance assessment is to provide information on the amounts of IBR generation that could connect to different parts of the grid with minimal risk of introducing sub-synchronous resonance (SSR) with the existing series capacitors located at the Nobel Switching Station (SS), or introducing undesirable sub-synchronous control interactions (SSCI).

4.2 Assumptions and Methodology

There is a very high likelihood that the vast majority of the LT2 RFP resources will be IBRs. IBRs have a history of oscillating under certain system conditions, typically when they are in proximity of other IBRs in weakly connected systems, or when they are radially connected to series compensated transmission circuits.

In order to avoid potential SSR issues with the series capacitors at Nobel SS on circuits X503E and X504E, the IESO performed a topology scan and excluded certain connection points that could become radially connected to these series capacitors for credible scenarios.

Potential SSCI were determined by the IESO using a screening tool that was developed in-house and that takes the following factors into consideration:

- System topology;
- Ratings and location of neighbouring IBRs;
- Minimum short circuit ratio (SCR) specified by the OEM for stable operation of the IBR.

The following was assumed:

- For each IBR, a minimum SCR of 5 at its point of interconnection is assumed for stable operation;
- An SCR of 2-3 is used for existing IBRs at the inverter level;
- Available Fault Level (AFL) is an indicator of whether the system is strong enough to support stable operation of a new IBR connection at the location measured without the risk of SSCI. It is calculated using the methodology explained in Section 6.6 of 'Connection of wind farms to weak AC networks' [2].

The size and locations of IBR injections were tested as follows:

- Northern Ontario (Northeast + Northwest)
 - Tested 2,200 MW of IBRs using the following 'bright-line' connection criteria:

- Limit IBR 115 kV connections to 30 MW per circuit – the 115 kV network was found incapable of accommodating significant IBR injections in comparison to a stronger 230 kV network; however depending on the point of connection and system configuration, there could be situations when IBRs sized up to 30 MW might not be possible to be connected.
 - Limit IBR 230 kV connections to 100 MW per circuit – current projects of this size have been operated successfully and will be considered a benchmark until further experience with IBR resource integration is gained;
 - A maximum of one injection per circuit was assessed.
- Southern Ontario
 - Size and location of IBRs were chosen using the following 'bright-line' connection criteria:
 - Avoid the limiting circuits of a major transmission interface – to avoid reducing the transfer capability of those interfaces that may have an imbalance of flows;
 - Limit IBR 115 kV connections to 30 MW per circuit – same rationale listed for Northern Ontario;
 - Limit IBR 230 kV network circuit connections to 150 MW per circuit and limit IBR 230 kV radial circuit connections to 100 MW per circuit – current projects of this size have been operated successfully and will be considered a benchmark until further experience with IBR resource integration is gained.
 - A maximum of one injection per circuit was assessed.
 - West of Toronto case – tested up to 2,650 MW of IBRs, following the criteria above
 - East of Toronto case – tested up to 1,400 MW of IBRs, following the criteria above.

4.3 Results

4.3.1 Sub-Synchronous Resonance

The results of the SSR topology scan identified that the following circuits could end up in a radial connection to the Nobel SS series capacitors for credible contingencies, and should be avoided for all IBRs.

Table 6 | Circuits to Avoid Due to Potential SSR Issues

Circuits connected to Hanmer	Circuits connected to Martindale	Circuits connected to Essa	
X74P	S22A	E510V	E8V
X27A	S21N	E511V	E9V
X23N	H23S	E26	E20S
X25S	H24S	E27	E21S
X26S	L1S	E28	
X29S	S2B	E29	
X505P	S5M	M6E	
P502X	S6F	M7E	
X503E			
X504E			

In eliminating the identified circuits for SSR issues, connecting approximately 1,200 MW of IBRs to the remaining northern 230 kV circuits was tested and passed while minimizing the risk of potential SSCI in Northern Ontario. The approximate region where these circuits are located is illustrated in Figure 8.

Figure 8 | Approximate Region of Circuits to Avoid Due to Potential IBR Issues



4.3.2 Sub-Synchronous Control Interactions

The remaining 1,200 MW of IBRs tested for SSCI were found to be feasible for connection in Northern Ontario, where connections to 230 kV circuits are limited to 100 MW per circuit.

For both West and East of Toronto cases in Southern Ontario, injections of 2,650 MW and 1,400 MW respectively, were found to be feasible from an SSCI perspective, where connections to 230 kV circuits are limited to 150 MW and 100 MW, respectively, for network and radial circuits.

4.4 Other Considerations

In regards to utilizing the above results for guidance, the following must be taken into consideration:

- The analysis did not consider any of the potential LT1 RFP projects that will connect to the system, as the size and locations were not known at the time the analysis was performed. As the majority of the resources submitted for the LT1 RFP are also inverter based, their size and locations could potentially impact the availability for potential LT2 RFP resources;
- The analysis is meant to be used for high-level screening purposes only, and is not expected to cover all possible LT2 RFP combinations that may be submitted, as the outcomes of these tests are highly dependent on the size and location of the IBRs modeled;
- A second IBR SSCI assessment will be performed by the IESO during the evaluation stage deliverability test, once the size and location of LT2 RFP projects are known;
- More detailed SSR and SSCI tests, as well as additional Electromagnetic Transient (EMT) studies, will be required once detailed models are known, which will most likely occur during the Connection Assessment stage as part of a System Impact Assessment.

5. Circuit Congestion Limitations

5.1 Objective

The goal of the circuit congestion limitations guidance assessment is to determine the amount of new generation that could inject into a circuit and not require energy curtailments to prevent thermal overload of the transmission equipment.

5.2 Assumptions and Methodology

To determine the maximum incremental generation that could inject into a circuit, the same cases that were developed for the Area Congestion Limitations analysis were used. Using the three basecases and the two additional sub-cases for the West of Toronto area and two sub-cases for the East of Toronto area described in the Area Congestion Limitations section, the maximum incremental injection into each circuit in each of the three areas of study was calculated by determining the remaining capacity between the short-term emergency thermal rating of the circuit and the post-contingency flow through the circuit following the most limiting recognized contingency.

In determining these limits, the following additional criteria was used:

- Where the load-flow study results indicated that a circuit has a capability that exceeds the 'bright-line' connection criteria from the IBR Limitations section, the limit for the circuit was capped at the 'bright-line' level. This decision is also supported by past experience, as existing projects around these sizes have been operated successfully and will be considered a benchmark until further experience with IBR resource integration is gained;
- The 115 kV circuits that participate in remedial action schemes would need to be avoided, as they have a higher likelihood of being near their limits;
- The more limiting circuits of a major transmission interface would need to be avoided. This is to prevent reducing the the transfer capability of those interfaces;
- Available capacity was discounted for circuits on which connecting new resources would have a direct impact on the operability of existing generation units, even those dispatchable. Direct impact could occur if a new resource is located in the proximity of an existing resource and the local transmission capability to evacuate energy is limited, and would significantly inhibit the existing resource to generate, requiring frequent generation redispatch.

5.3 Results

Based on the the studies and additional criteria presented above, the following limitations were determined:

- Northern Ontario
 - Limit new 115 kV connections to 30 MW per circuit;
 - Limit new 230 kV connections to 100 MW per circuit;

- New connections to the circuits listed in Table 7 should be avoided.

Table 7 | List of Circuits in Northern Ontario to Avoid

115 kV					230 kV		
A1B	A9K	D4	H7T	M2W	SK1	D23G	T27P
A4H	B15	D4Z	H6T	M3E	T1B	D5H	T28P
A4L	B5	D6T	H9K	M3K	T7M	H22D	
A4L	B6M	E1C	K2	M9K	T8M	K21W	
A5A	C1A	E2R	K4W	R1LB	T1M	K22W	
A5H	C1C	F1E	K5A	R2LB	W3C	K38S	
A7L	C2A	F3M	K5W	R9A		L20D	
A7V	C3A	H2N	L8L	S1C		L21S	
A8K	D3K	H4Z	M1S	S2B		R21D	

- West and East of Toronto
 - Limit new 115 kV connections to 30 MW per circuit;
 - Limit new 230 kV connections to 100 MW and 150 MW per radial circuit and network circuit, respectively;
 - For West of Toronto, new connections to the circuits listed in Table 8 should be further restricted. This table lists circuits which should be avoided, as well as circuits with available capacity below the bright-line thresholds above.
 - For East of Toronto, new connections to the circuits listed in Table 9 should be further restricted to minimize energy congestion. This table lists circuits which should be avoided, as well as circuits with available capacity below the bright-line thresholds above.

Table 8 | List of Circuits West of Toronto Subject to Further Restrictions

Circuits to avoid				Circuits with Restricted Capacity
115 kV	230 kV			230 kV (Capacities < 150 MW)
B5C	B20P	J5D	R14T	L29C - 75 MW
B6C	B22D	L4D	R17T	N6S - 75 MW
E8F	B23D	L51D	R19TH	N7S - 75 MW
E9F	B24P	N21W	R21TH	N5M - 100 MW
J1B	B27S	N22W	T38B	H76 - 125 MW
J2N	B28S	PA27	T39B	
J3E	B3N	PA301		
J4E	B4V	PA302		
K2Z	B5V	Q10P		
S1H	C43H	Q22P		
S2N	E8V	Q23BM		
S2S	E9V	Q24HM		
Z1E	H25J	Q25BM		
Z7E	H26J	Q28A		

Table 9 | List of Circuits East of Toronto Subject to Further Restrictions

Circuits to avoid			Circuits with Restricted Capacity
115 kV	230 kV		230 kV (Capacities < 150 MW)
A6R	A41T	L24A	D1M - 100 MW
B1S	A42T	L33P	D2M - 100 MW
B5QK	B31L	L34P	D3M - 100 MW
C7BM	B5D	P33C	D4M - 100 MW
D6	C25H	Q4C	T31H/C25H - 125 MW
L1MB	D5A	S25L	T32H/H27H - 100 MW
L2M	D5H	S26L	
M1R	E26	S30L	
Q6S	E27	S32L	
S7M	E8V	X1P	
W3B	E9V		
W6CS	L20H		
X2Y	L21H		
X6	L22H		

5.4 Other Considerations

- Connection to 500 kV circuits should be avoided;
- Connections to intertie circuits should be avoided;
- Any connection to HONI transmission circuits will need to comply with [Hydro One Transmission Generation Interconnection Requirements](#) document;
- Connection to circuits forming a parallel transmission path may require a configuration that balances the flows on all circuits in the path; and
- Connections to new transmission circuits that have a committed in-service date beyond December 31, 2029, as confirmed by the transmission developer at the time of the proposal submission deadline, are not allowed. This is to minimize the risk of procuring new resources that may not be able to connect due to potential delays with the new transmission projects.

6. Short-Circuit & Protection Limitations (HONI transmission system only)

6.1 Objective

The goal of the short-circuit limitations guidance assessment is to identify areas where the short-circuit levels are close to, or exceed, the short-circuit capability of the transmission equipment, and there are no feasible solutions to be implemented before year 2030; therefore, those areas should be avoided by the potential proponents in the LT2 RFP.

6.2 Assumptions and Methodology

HONI has identified transmission stations and equipment with short-circuit capabilities that could be close to their limits or exceeded by 2030 considering the committed generation and transmission projects expected to be in-service prior to the connection of the LT2 RFP projects, as specified by the IESO.

Because any addition of generation resources will increase the short-circuit levels in the proximity of their connection, HONI has recommended that proposals should avoid to connect within a radius of 50 km (electrical) from a station with short-circuit limitations.

A short-circuit assessment will be performed for all proposals in the evaluation stage deliverability test, regardless of their location.

6.3 Results

The following table presents HONI’s transmission stations with known short circuit limitations:


Table 10 | Short-Circuit Limiting Stations (HONI)

Station	Limiting Issue
Cherrywood	Breaker rating
Burlington	Breaker rating
Owen Sound	Breaker rating
Manby	Station grounding
Lennox	Station grounding
Clarington	Breaker rating
Trafalgar	Breaker rating
Richview	Breaker rating
Beck #2	Breaker rating

Other limitations due to station grounding, skywires, strain buses and cable sections will be identified after the size and connection point of the proposed generators are known. Although HONI had

indicated that the approximate distance to avoid was 50 km (electrical), to give the reader a rough geographical context, Figure 9 illustrates the approximate regions to avoid by drawing a 50 km radius around each of the stations identified in Table 10.

Figure 9 | Approximate Regions to Avoid Due to Potential Short-Circuit Limitations



6.4 Constraints Due to Protection

The total generation capacity and number of taps that could connect into a circuit may be limited due to line protection considerations. For example, protection may not reliably detect a circuit fault with a new generator connection on the circuit if the circuit is supplied by stations with low short-circuit levels. This determination can be made only after generator parameters and connection points are known.

Connecting into circuits limited by line protection, especially those protected by line differential as listed in Table 11, may introduce major complexities and costly solutions, from installing sectionalizing breakers and new protection elements, to installing a full switching station at the connection point. It is, therefore, recommended to avoid connecting into these circuits.

Table 11 | HONI Owned Circuits Protected by Line Differential

Circuit	Voltage (kV)	Circuit	Voltage (kV)	Circuit	Voltage (kV)
J3E	115	N37S	230	R24C	230
J4E	115	Q23BM	230	S39M	230
J20B	230	Q24HM	230	S47C	230
K21C	230	Q25BM	230	V41N	230
K23C	230	Q26M	230	V43N	230
L25V	230	Q28A	230	W44LC	230
L27V	230	Q29HM	230	W45LS	230
L28C	230	Q30M	230		
N20K	230	Q35M	230		

7. Distribution Asset Limitations (only HONI stations)

Available capacity at the HONI distribution assets can be found using HONI's Station and Feeder Capacity Calculator, located [here](#). This list shows an approximate amount of generation that can be added at each bus or station owned by HONI.

Please note that upstream restrictions on the high voltage stations may limit the number of resources connecting at the distribution level. Transmission connected resources near a station will increase the fault level in the distribution system of that station, and will therefore compete for the available capacity.

This document does not provide guidance regarding any limitations or availability for connections to the distribution systems owned by Local Distribution Companies (LDCs) beyond the available capacity at distribution level stations supplied from Hydro One stations. Interested proponents are recommended to contact the LDCs operating the distribution system they intend to connect to.

8. General Considerations

The preliminary connection guidance provided in this document is intended to only be used in the context of the procurement of energy under the LT2 RFP, and only addresses electrical transmission system availability and energy deliverability limitations. Any residual capacity needs that may need to be addressed through the LT2 RFP or subsequent procurements will rely on different methodologies and may leverage the deliverability testing processes established under the E-LT1 and LT1 RFPs, pending further detail.

In making use of this guidance document, there are several considerations and limitations, in addition to those detailed in other sections, that are important to take into account. They are listed as follows:

- Some locations could be subject to multiple types of limitations. Where multiple limitations apply to a particular location, the most constraining limitation should be used;
- The assessments did not consider projects that will be successful in LT1 RFP, as those projects were not known at the time the analysis was performed. It is anticipated that energy deliverability testing in the evaluation stage of the LT2 RFP will use updated assumptions, which will take into account projects that are successful in the LT1 RFP, and other committed projects;
- The conclusions of this document are highly dependent on the size and location of LT2 RFP proposals in the same electrical proximity. As a result, proposals in LT2 RFP may compete for the same transmission system availability during the evaluation stage deliverability test;
- The assumptions and methods used to provide this guidance document are reflective of a limited number of historical and forecasted operating scenarios. At the time of the evaluation stage deliverability test, there may be other scenarios, methods and changes to forecasts to consider, which could provide different results;
- Direct connections into a transmission station were not assessed for possible limitations due to physical space available, auto-transformer rating and other operability issues at the station, beyond the limitations described in this document;
- In order to avoid a situation where a connection configuration turns out to be infeasible, impractical or too costly, applicants are encouraged to have discussions with transmitters and LDCs prior to making a submission into the LT2 RFP;
- The IESO strongly recommends that potential proponents with proposed projects connecting to the transmission system, or proposed projects larger than or equal to 10 MW connecting to the distribution system, delay their SIA applications until the results of the LT2 RFP are announced. If an applicant chooses to apply for an SIA, it is important to note that the SIA may need to be updated or restarted after the results of the LT2 RFP are announced, as an SIA completed earlier would not have included all successful projects in the assessment;
- Potential proponents considering projects for future procurements (LT3, LT4 RFPs) should be aware that the outcomes of the LT1 RFP and LT2 RFP, as well as the purpose of the

procurement (e.g., acquisition of energy or capacity), will make the information in this document inadequate for purpose of siting projects for these future procurements.



9. Conclusions

The results of the assessments presented in this document indicate locations that are more viable and locations that are more limited from an energy deliverability perspective, and is intended to guide the siting of new non-emitting generation for the purpose of participating in the LT2 RFP.

As this document is only intended to provide preliminary connection guidelines, proponents are still free to submit proposals into the LT2 RFP for projects at locations that are either not assessed or recommended to avoid in this document, as well as proposals for project sizes that exceed the limits presented in this document. However, there is a higher risk that those proposals will not be successful in the energy deliverability test in the evaluation stage of the LT2 RFP.



10. References

[1] IESO, “[Annual Planning Outlook: Supply, Adequacy and Energy Outlook Module](#)”, March 2024.

[2] CIGRE Working Group B4.62, “Connection of wind farms to weak AC networks”, December 2016.

11. Appendix A: Circuits with Restrictions

Table 12 | Overall Circuits to Avoid

Circuit	Voltage (kV)	Zone	Circuit	Voltage (kV)	Zone	Circuit	Voltage (kV)	Zone
K21W	230	Northwest	K38S	230	Northeast	L8L	115	Northeast
K22W	230	Northwest	L20D	230	Northeast	M3K	115	Northeast
A1B	115	Northwest	L21S	230	Northeast	M9K	115	Northeast
A4L	115	Northwest	R21D	230	Northeast	S2B	115	Northeast
A5A	115	Northwest	S21N	230	Northeast	S5M	115	Northeast
A7L	115	Northwest	S22A	230	Northeast	S6F	115	Northeast
B15	115	Northwest	T27P	230	Northeast	T1B	115	Northeast
B5	115	Northwest	T28P	230	Northeast	T7M	115	Northeast
B6M	115	Northwest	X23N	230	Northeast	T8M	115	Northeast
C1A	115	Northwest	X25S	230	Northeast	D5H	230	Essa
C2A	115	Northwest	X26S	230	Northeast	E20S	230	Essa
C3A	115	Northwest	X27A	230	Northeast	E21S	230	Essa
E1C	115	Northwest	X29S	230	Northeast	E26	230	Essa
E2R	115	Northwest	X74P	230	Northeast	E27	230	Essa
F3M	115	Northwest	A4H	115	Northeast	E28	230	Essa
K4W	115	Northwest	A5H	115	Northeast	E29	230	Essa
K5A	115	Northwest	A7V	115	Northeast	E8V	230	Essa
K5W	115	Northwest	A8K	115	Northeast	E8V	230	Essa
M1S	115	Northwest	A9K	115	Northeast	E9V	230	Essa
M2W	115	Northwest	C1C	115	Northeast	M6E	230	Essa
M3E	115	Northwest	D3K	115	Northeast	M7E	230	Essa
R1LB	115	Northwest	D4	115	Northeast	D6	115	Essa
R2LB	115	Northwest	D4Z	115	Northeast	A41T	230	Ottawa
R9A	115	Northwest	D6T	115	Northeast	A42T	230	Ottawa
S1C	115	Northwest	F1E	115	Northeast	B5D	230	Ottawa
SK1	115	Northwest	H2N	115	Northeast	D5A	230	Ottawa
T1M	115	Northwest	H4Z	115	Northeast	L24A	230	Ottawa
W3C	115	Northwest	H6T	115	Northeast	A6R	115	Ottawa
D23G	230	Northeast	H7T	115	Northeast	L2M	115	Ottawa
H22D	230	Northeast	H9K	115	Northeast	M1R	115	Ottawa
H23S	230	Northeast	K2	115	Northeast	S7M	115	Ottawa
H24S	230	Northeast	L1S	115	Northeast	B31L	230	East

Circuit	Voltage (kV)	Zone	Circuit	Voltage (kV)	Zone	Circuit	Voltage (kV)	Zone
C25H	230	East	PA301	230	Niagara	B3N	230	West
L20H	230	East	PA302	230	Niagara	C43H	230	West
L21H	230	East	Q10P	230	Niagara	H25J	230	West
L22H	230	East	Q22P	230	Niagara	H26J	230	West
L33P	230	East	Q23BM	230	Niagara	J20B	230	West
L34P	230	East	Q23BM	230	Niagara	J5D	230	West
P33C	230	East	Q24HM	230	Niagara	L25V	230	West
Q4C	230	East	Q25BM	230	Niagara	L27V	230	West
S25L	230	East	Q26M	230	Niagara	L28C	230	West
S26L	230	East	Q28A	230	Niagara	L4D	230	West
S30L	230	East	Q29HM	230	Niagara	L51D	230	West
S32L	230	East	Q30M	230	Niagara	N21W	230	West
X1P	230	East	Q35M	230	Niagara	N22W	230	West
X2Y	230	East	B22D	230	Southwest	S47C	230	West
B1S	115	East	B23D	230	Southwest	V41N	230	West
B5QK	115	East	B4V	230	Southwest	V43N	230	West
C7BM	115	East	B5V	230	Southwest	W44LC	230	West
L1MB	115	East	N20K	230	Southwest	W45LS	230	West
Q6S	115	East	N37S	230	Southwest	E8F	115	West
W3B	115	East	S39M	230	Southwest	E9F	115	West
W6CS	115	East	T38B	230	Southwest	J1B	115	West
X6	115	East	T39B	230	Southwest	J2N	115	West
K21C	230	Toronto	B5C	115	Southwest	J3E	115	West
K23C	230	Toronto	B6C	115	Southwest	J4E	115	West
R14T	230	Toronto	S1H	115	Southwest	K2Z	115	West
R17T	230	Toronto	S2S	115	Southwest	S2N	115	West
R19TH	230	Toronto	B20P	230	Bruce	Z1E	115	West
R21TH	230	Toronto	B24P	230	Bruce	Z7E	115	West
R24C	230	Toronto	B27S	230	Bruce			
PA27	230	Niagara	B28S	230	Bruce			

Table 13 | Overall Circuits with Restricted Capacity

Circuit	Capacity	Voltage (kV)	Zone	Circuit	Capacity	Voltage (kV)	Zone
D1M	100 MW	230	Essa	N5M	100 MW	230	Southwest
D2M	100 MW	230	Essa	H76	125 MW	230	West
D3M	100 MW	230	Essa	L29C	75 MW	230	West
D4M	100 MW	230	Essa	N6S	75 MW	230	West
T31H/C25H	125 MW	230	East	N7S	75 MW	230	West
T32H/H27H	100 MW	230	East				

– End of Document –

**Independent Electricity
System Operator**

1600-120 Adelaide Street West
Toronto, Ontario M5H 1T1

Phone: 905.403.6900

Toll-free: 1.888.448.7777

E-mail: customer.relations@ieso.ca

ieso.ca



[@IESO_Tweets](https://twitter.com/IESO_Tweets)



[linkedin.com/company/IESO](https://www.linkedin.com/company/IESO)