

Feedback Form

Long-Term 2 RFP | Deliverability Guidance Document | April 18, 2024

Feedback Provided by:

Name: Don Richardson

Title: CEO

Organization: Minogi Corp.

Email: [REDACTED]

Date: May 3, 2024

To promote transparency, feedback submitted will be posted on the Long-Term RFP engagement page unless otherwise requested by the sender. If you wish to provide confidential feedback, please mark "Confidential".

Following the LT2 RFP Guidance Document webinar on April 18, 2024, the Independent Electricity System Operator (IESO) is seeking feedback from participants on the items discussed during the session. The presentation material and recording can be accessed from the [engagement web page](#).

Please submit feedback to engagement@ieso.ca by May 3, 2024.

Guidance Document: Readability and Layout

Topic	Feedback
<p>Do you have any advice or feedback on the style, layout and overall readability of the April 2024 Deliverability Guidance Document released by the IESO?</p>	<p>Minogi thanks the IESO for seeking feedback on the Preliminary Connection Guidance for Long-Term 2 Procurement.</p> <p>While the information provided begins to narrow down preferred locations for resources, we are concerned that a list of circuits and station names is near impossible to use in the absence of a corresponding map.</p> <p>Minogi requests that the IESO provide a map of the transmission system in either an interactive online version, or ArcGIS shapefile by request and possibly subject to NDA. This map should clearly display substations, individual transmission lines (incl. kV), IESO regulated generation, known loads, and IESO planning regions.</p> <p>As an example, please consider the map published by the Alberta Electricity System Operator.</p> <p>https://aeso.maps.arcgis.com/apps/webappviewer/index.html?id=7470f563c3634f81a4455f06a3310176</p>

Guidance Document: Content

Topic	Feedback
<p>Are there any specific areas of the Deliverability Guidance Document that you would like to provide feedback on from a technical and/or content-specific point of view?</p> <p>If so, please be as specific as possible in your feedback and consider using page numbers and content title where possible to ensure the IESO can consider your feedback accurately</p>	<p>We are seeking more information on the following:</p> <ul style="list-style-type: none"> • Short circuit limitations at Lennox TS • Area congestion limits at <ul style="list-style-type: none"> ○ East of Dobbin TS = 325 ○ East of Minden TS = 250 ○ East of St. Lawrence TS = 250 ○ East of Hinchinbrooke SS = 750 ○ East of Lennox TS = 750 ○ East of Bowmanville SS= 2,100 • East Zone – Capacity Limits • Sub-Synchronous Resonance concerns • Short circuit limitations in the East

Topic	Feedback
Do you find the preliminary connection guidance information sufficient for your siting needs? If you feel more information is required, please be specific on what other information you would find useful.	No. A map is required to effectively understand the guidance document and apply to siting considerations.

General Comments/Feedback:

Minogi is a clean energy economic development firm, wholly owned by the Mississaugas of Scugog Island First Nation. We are actively seeking partnerships for First Nation equity in projects, for the benefit of all interested Williams Treaties First Nations.