

## Market Rule Amendment Proposal Form

### Part 1 - Market Rule Information

Identification No.:	MR-00459-R00
Subject:	Market Renewal Program: The Pre-Dispatch Calculation Engine
Title:	Market Renewal Program: The Pre-Dispatch Calculation Engine
Nature of Proposal:	<input type="checkbox"/> Alteration <input checked="" type="checkbox"/> Deletion <input checked="" type="checkbox"/> Addition
Chapter:	7
Appendix:	Appendix 7.5A (New)
Sections:	
Sub-sections proposed for amending:	
Current Market Rules Baseline:	

### Part 2 - Proposal History

Version	Reason for Issuing	Version Date
1.0	Draft for Stakeholder Review	February 4, 2022
2.0	Draft for Stakeholder Review	July 8, 2022
3.0	Draft for Stakeholder Review	March 13, 2024
4.0	Draft for Technical Panel Review	March 26, 2024
5.0	Publish for Stakeholder Review and Comment	April 11, 2024
6.0	Submitted for Technical Panel Provisional Vote	May 7, 2024

Approved Amendment Publication Date:

Approved Amendment Effective Date:

### Part 3 - Explanation for Proposed Amendment

Provide a brief description that includes some or all of the following points:

- The reason for the proposed amendment and the impact on the *IESO-administered markets* if the amendment is not made.
- Alternative solutions considered.
- The proposed amendment, how the amendment addresses the above reason and impact of the proposed amendment on the *IESO-administered markets*.

#### Summary

The IESO proposes to amend the market rules to codify the Market Renewal Program's (MRP) Pre-Dispatch Calculation Engine design.

The proposed introduction of Appendix 7.5A of Chapter 7: The Pre-Dispatch Calculation Engine Process describes the process used by the pre-dispatch calculation engine to determine commitments, schedules and prices for the pre-dispatch look-ahead period.

This proposal is based on input from various stakeholder engagement initiatives for the Market Renewal Program (MRP).

Further information on MRP can be found on the IESO's [Market Renewal webpage](#).

#### Background

The calculation engine appendices define the mathematical terms and algorithms that optimize dispatch data from market participants to meet power system needs. Terms and algorithms for the current calculation engines are captured in appendices in the market rules, providing transparency for how the IESO meets its Chapter 7 obligations for algorithms to schedule and price the market. The IESO has maintained this approach in codifying the terms and algorithms used to support the renewed market.

The IESO provided stakeholders with an in-depth overview of the calculation engine designs and market rules at a February 22, 2022 MRP engagement session. That presentation can be found here: [Calculation Engine Market Rules Presentation](#).

#### Discussion

The accompanying [Summary of Calculation Engine Appendices](#) readers guide provides a summary of the market rule amendments to Appendices 7.5, 7.5A and 7.6 of the market rules.

Subsequent to the latest publication of the above referenced Summary of Calculation Engine Appendices, the IESO proposed revisions to sections 11 and 14 of Appendix 7.5A. The revisions include the following:

- Sections 11 and 14 related to conduct tests and price impact tests for energy and operating reserve were amended to include an absolute value operator in the equations to address outcomes caused by negative prices; and
- Correction of a typographical error in section 11.5.1.1.5 to replace *P10NDG* with the correct variable *P10NDL*.

#### Part 4 - Proposed Amendment

Note: The proposed amendments to Appendix 7.5A – The Pre-Dispatch Calculation Engine, while not shown as (redlined) changes to existing market rules, represent entirely new sections in the market rules.

# Appendix 7.5A – The Pre-Dispatch Calculation Engine Process

## 1.1 Purpose

- 1.1.1 This appendix describes the process used by the *pre-dispatch calculation engine* to determine commitments, schedules, and prices for the pre-dispatch look-ahead period.

## 2 Pre-Dispatch Calculation Engine

### 2.1 Pre-Dispatch Look-Ahead Period

- 2.1.1 The pre-dispatch look-ahead period is the time horizon considered in the multi-hour optimization. The pre-dispatch look-ahead period changes depending on when the *pre-dispatch calculation engine* runs:
- 2.1.1.1 for the *pre-dispatch calculation engine* runs from 00:00 EST to 19:00 EST in the current *dispatch day*, the pre-dispatch look-ahead period consists of the remaining hours of the current *dispatch day*; and
  - 2.1.1.2 for the *pre-dispatch calculation engine* runs from 20:00 EST to 23:00 EST in the current *dispatch day*, the pre-dispatch look-ahead period consists of the remaining hours of the current *dispatch day* in addition to all hours in the next *dispatch day*.

### 2.2 Pre-Dispatch Calculation Engine Pass

- 2.2.1 The *pre-dispatch calculation engine* shall execute one pass, Pass 1, the Pre-Dispatch Scheduling Process Pass, in accordance with section 7, to produce *pre-dispatch schedules*, commitments and *locational marginal prices*:

## 3 Information Used by the Pre-Dispatch Calculation Engine

- 3.1.1 The *pre-dispatch calculation engine* shall use the information in section 3A.1 of Chapter 7.

# 4 Sets, Indices and Parameters Used in the Pre-Dispatch Calculation Engine

## 4.1 Fundamental Sets and Indices

- 4.1.1  $A$  designates the set of all *intertie zones*;
- 4.1.2  $B$  designates the set of buses identifying all *dispatchable* and *non-dispatchable resources* within Ontario;
- 4.1.3  $B^{DG} \subseteq B$  designates the set of buses identifying *dispatchable generation resources*;
- 4.1.4  $B^{DL} \subseteq B$  designates the set of buses identifying *dispatchable loads*;
- 4.1.5  $B^{ELR} \subseteq B^{DG}$  designates the subset of buses identifying *energy limited resources*;
- 4.1.6  $B^{HDR} \subseteq B$  designates the set of buses identifying *hourly demand response resources*;
- 4.1.7  $B^{HE} \subseteq B^{DG}$  designates the subset of buses identifying *dispatchable hydroelectric generation resources*;
- 4.1.8  $\wp(B^{HE})$  designates the set of all subsets of the set  $B^{HE}$ ;
- 4.1.9  $B_{up}^{HE} \subseteq \wp(B^{HE})$  designates the set of buses identifying all upstream *dispatchable hydroelectric generation resources* with a registered *forebay* that are linked via *time lag* and *MWh ratio dispatch data* with downstream *dispatchable hydroelectric generation resources* with a registered *forebay*;
- 4.1.10  $B_{dn}^{HE} \subseteq \wp(B^{HE})$  designates the set of buses identifying all downstream *dispatchable hydroelectric generation resources* with a registered *forebay* that are linked via *time lag* and *MWh ratio dispatch data* with upstream *dispatchable hydroelectric generation resources* with a registered *forebay*;
- 4.1.11  $B_s^{HE} \subseteq B^{HE}$  designates the subset of buses identifying *dispatchable hydroelectric generation resources* in set  $s \in SHE$ ;
- 4.1.12  $B^{NDG} \subseteq B$  designates the set of buses identifying *non-dispatchable generation resources*;
- 4.1.13  $B^{NO10DF} \subseteq B^{PSU}$  designates the subset of buses identifying *pseudo-units* that cannot provide *ten-minute operating reserve* from the duct firing region;

- 4.1.14  $B^{NQS} \subseteq B^{DG}$  designates the subset of buses identifying *dispatchable non-quick start resources*;
- 4.1.15  $B^{PSU} \subseteq B^{NQS}$  designates the subset of buses identifying *pseudo-units*;
- 4.1.16  $B_r^{REG} \subseteq B$  designates the set of internal buses in *operating reserve region*  $r \in ORREG$ ;
- 4.1.17  $B_p^{ST} \subseteq B^{PSU}$  designates the subset of buses identifying *pseudo-units* with a share of steam turbine *resource*  $p \in PST$ ;
- 4.1.18  $B^{VG} \subseteq B^{DG}$  designates the subset of buses identifying *dispatchable variable generation resources*;
- 4.1.19  $C$  designates the set of contingencies that shall be considered in the *security assessment function*;
- 4.1.20  $D$  designates the set of buses outside Ontario corresponding to imports and exports at *intertie zones*;
- 4.1.21  $DAYS$  designates the set of days in the look-ahead period. If the look-ahead period spans one day, then  $DAYS = \{tod\}$ . If the look-ahead period spans two days, then  $DAYS = \{tod, tom\}$ ;
- 4.1.22  $D_r^{REG} \subseteq D$  designates the set of *intertie zone* buses identifying *boundary entity resources* in *operating reserve region*  $r \in ORREG$ ;
- 4.1.23  $DX \subseteq D$  designates the subset of *intertie zone* buses identifying *boundary entity resources* that correspond to export *bids*;
- 4.1.24  $DI \subseteq D$  designates the subset of *intertie zone* buses identifying *boundary entity resources* that correspond to import *offers*;
- 4.1.25  $D_a \subseteq D$  designates the set of all buses identifying *boundary entity resources* in *intertie zone*  $a \in A$ ;
- 4.1.26  $DI_a \subseteq D_a$  designates the subset of *intertie zone* buses identifying *boundary entity resources* that correspond to import *offers* in *intertie zone*  $a \in A$ ;
- 4.1.27  $DI_t^{CAPEX} \subseteq DI$  designates the *intertie zone* source buses identifying import *offers* flagged as capacity imports in time-step  $t \in \{4, \dots, n_{LAP}\}$ ;
- 4.1.28  $DI_t^{EM} \subseteq DI$  designates the *intertie zone* buses corresponding to *emergency energy* import transactions for time-step  $t \in TS$ ;

- 4.1.29  $DI_t^{EMNS} \subseteq DI_t^{EM}$  designates the *intertie zone* buses corresponding to *emergency energy* import transactions that do not support *emergency energy* export transactions in time-step  $t \in TS$ ;
- 4.1.30  $DI_t^{INP} \subseteq DI$  designates the *intertie zone* buses corresponding to inadvertent *energy* payback import transactions for time-step  $t \in TS$ ;
- 4.1.31  $DX_a \subseteq D_a$  designates the subset of *intertie zone* buses identifying *boundary entity resources* that correspond to export *bids* in *intertie zone*  $a \in A$ ;
- 4.1.32  $DX_t^{CAPEX} \subseteq DX$  designates the *intertie zone* sink buses identifying export *bids* flagged as *capacity exports* in time-step  $t$ ;
- 4.1.33  $DX_t^{INP} \subseteq DX$  designates the *intertie zone* buses corresponding to inadvertent *energy* payback export transactions for time-step  $t \in TS$ ;
- 4.1.34  $DX_t^{EM} \subseteq DX$  designates the *intertie zone* buses corresponding to *emergency energy* export transactions for time-step  $t \in TS$ ;
- 4.1.35  $F$  designates the set of *facilities* and groups of *facilities* for which transmission constraints may be identified;
- 4.1.36  $F_t \subseteq F$  designates the set of *facilities* whose pre-contingency limit was violated in time step  $t$  as determined by a preceding *security* assessment function iteration;
- 4.1.37  $F_{t,c} \subseteq F$  designates the set of *facilities* whose post-contingency limit for contingency  $c$  is violated in time step  $t$  as determined by a preceding *security* assessment function iteration;
- 4.1.38  $J_{t,b}^E$  designates the set of *bid* laminations for energy at bus  $b \in B \cup DX$  for time-step  $t \in TS$ ;
- 4.1.39  $J_{t,b}^{10S}$  designates the set of *offer* laminations for synchronized *ten-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.40  $J_{t,b}^{10S}$  designates the set of *reference level value* laminations for synchronized *ten-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.41  $J_{t,b}^{10N}$  designates the set of *offer* laminations for non-synchronized *ten-minute operating reserve* at bus  $b \in B \cup DX$  for time-step  $t \in TS$ ;

- 4.1.42  $J_{t,b}^{10N}$  designates the set of *reference level value* laminations for non-synchronized *ten-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.43  $\tilde{J}_{t,b}^{30R}$  designates the set of *offer* laminations for *thirty-minute operating reserve offer* at bus  $b \in B \cup DX$  for time-step  $t \in TS$ ;
- 4.1.44  $J'_{t,b}{}^{30R}$  designates the set of *reference level value* laminations for *thirty-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.45  $K_{t,b}^{DF} \subseteq K_{t,b}^E$  designates the set of *offer* laminations for *energy* corresponding to the duct firing region of a *pseudo-unit* at bus  $b \in B^{PSU}$  for time-step  $t \in TS$ ;
- 4.1.46  $K_{t,b}^{DR} \subseteq K_{t,b}^E$  designates the set of *offer* laminations for *energy* corresponding to the *dispatchable* region of a *pseudo-unit* at bus  $b \in B^{PSU}$  for time-step  $t \in TS$ ;
- 4.1.47  $K_{t,b}^E$  designates the set of *offer* laminations for *energy* at bus  $b \in B \cup DI$  for time-step  $t \in TS$ ;
- 4.1.48  $K_{t,b}^E$  designates the set of *reference level value* laminations for *energy* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.49  $K_{t,b}^{LTMLP}$  designates the set of *offer* laminations for *energy* quantities up to the *minimum loading point* for a *non-quick start resource* at bus  $b \in B^{NQS}$  for time-step  $t \in TS$ ;
- 4.1.50  $K'_{t,b}{}^{LTMLP}$  designates the set of *reference level value* laminations for *energy* quantities up to the *minimum loading point reference level* for a *non-quick start resource* at bus  $b \in B^{NQS}$  for time-step  $t \in TS$ ;
- 4.1.51  $K_{t,b}^{10S}$  designates the set of *offer* laminations for synchronized *ten-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.52  $K'_{t,b}{}^{10S}$  designates the set of *reference level value* laminations for synchronized *ten-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.53  $K_{t,b}^{10N}$  designates the set of *offer* laminations for non-synchronized *ten-minute operating reserve* at bus  $b \in B \cup DI$  for time-step  $t \in TS$ ;



- 4.1.54  $K_{t,b}^{10N}$  designates the set of *reference level value* laminations for non-synchronized *ten-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.55  $K_{t,b}^{30R}$  designates the set of *offer* laminations for *thirty-minute operating reserve* at bus  $b \in B \cup DI$  for time-step  $t \in TS$ ;
- 4.1.56  $K_{t,b}^{80R}$  designates the set of *reference level value* laminations for *thirty-minute operating reserve* at bus  $b \in B$  for time-step  $t \in TS$ ;
- 4.1.57  $L$  designates the set of buses where the *locational marginal prices* represent prices for *delivery points* associated with *non-dispatchable generation resources* and *dispatchable generation resources*, *dispatchable loads*, *hourly demand response resources*, *price responsive loads* and *non-dispatchable loads*;
- 4.1.58  $L_y^{NDL} \subseteq L$ , designates the buses contributing to the zonal price for *non-dispatchable load zone*  $y \in Y$ ;
- 4.1.59  $L_m^{VIRT} \subseteq L$ , designates the buses contributing to the *virtual zonal price* for *virtual transaction zone*  $m \in M$ ;
- 4.1.60  $M$  designates the set of *virtual transaction zones*;
- 4.1.61  $NCA$  designates the set of *narrow constrained areas*;
- 4.1.62  $DCA$  designates the set of *dynamic constrained areas*;
- 4.1.63  $BCA$  designates the set of *broad constrained areas*;
- 4.1.64  $PST$  designates the set of steam turbine *resources offered* as part of a *pseudo-unit*;
- 4.1.65  $SHE$  designates the set indexing the sets of *dispatchable hydroelectric generation resources* with a *maximum daily energy limit* or a *minimum daily energy limit* or both for a registered *forebay*;
- 4.1.66  $THERM = \{COLD, WARM, HOT\}$  designates the set of *thermal states* for *non-quick start resources*;
- 4.1.67  $TS = \{2, \dots, n_{LAP}\}$  designates the set of all time-steps in the look-ahead period that are included in the *pre-dispatch calculation engine* optimization, where  $n_{LAP}$  designates the number of time-steps in the look-ahead period;
- 4.1.68  $TS_{tod} \subseteq TS$  designates the time-steps in the look-ahead period that are part of the current *dispatch day*;

- 4.1.69  $TS_{tom} \subseteq TS$  designates the time-steps in the look-ahead period that are part of the next *dispatch day*;
- 4.1.70  $TSC_b \subseteq TS$  designates the set of time-steps representing the first hour of a *day-ahead operational commitment* for the *resource* at bus  $b \in B$ ;
- 4.1.71  $t_{tom} \in TS_{tom}$  designates the first time-step of the next *dispatch day*;
- 4.1.72  $Y$  designates the *non-dispatchable load* zones in Ontario; and
- 4.1.73  $Z_{Sch}$  designates the set of all *inertie* limit constraints.

## 4.2 Market Participant Data Parameters

- 4.2.1 With respect to a *non-dispatchable generation resource* identified by bus  $b \in B^{NDG}$ :
  - 4.2.1.1  $QNDG_{t,b,k}$  designates the maximum incremental quantity of *energy* that may be scheduled in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^E$ ; and
  - 4.2.1.2  $PNDG_{t,b,k}$  designates the price for the maximum incremental quantity of *energy* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^E$ .
- 4.2.2 With respect to a *dispatchable generation resource* identified by bus  $b \in B^{DG}$ :
  - 4.2.2.1  $MinQDG_{q,b}$  designates the *minimum loading point* for day  $q \in DAYS$ ;
  - 4.2.2.2  $QDG_{t,b,k}$  designates the maximum incremental quantity of *energy* above the *minimum loading point* that may be scheduled in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^E$ ;
  - 4.2.2.3  $PDG_{t,b,k}$  designates the price for the maximum incremental quantity of *energy* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^E$ ;
  - 4.2.2.4  $Q10SDG_{t,b,k}$  designates the maximum incremental quantity of *synchronized ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{10S}$ ;
  - 4.2.2.5  $P10SDG_{t,b,k}$  designates the price for the maximum incremental quantity of *synchronized ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{10S}$ ;

- 4.2.2.6  $Q10NDG_{t,b,k}$  designates the maximum incremental quantity of non-synchronized *ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{10N}$ ;
- 4.2.2.7  $P10NDG_{t,b,k}$  designates the price for the maximum incremental quantity of non-synchronized *ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{10N}$ ;
- 4.2.2.8  $Q30RDG_{t,b,k}$  designates the maximum incremental quantity of *thirty-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{30R}$ ;
- 4.2.2.9  $P30RDG_{t,b,k}$  designates the price for the maximum incremental quantity of *thirty-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{30R}$ ;
- 4.2.2.10  $ORRDG_b$  designates the maximum *operating reserve* ramp rate in MW per minute;
- 4.2.2.11  $NumRRDG_{t,b}$  designates the number of ramp rates provided in time-step  $t \in TS$ ;
- 4.2.2.12  $RmpRngMaxDG_{t,b,w}$  for  $w \in \{1, \dots, NumRRDG_{t,b}\}$  designates the  $w^{\text{th}}$  ramp rate break point in time-step  $t \in TS$ ;
- 4.2.2.13  $URRDG_{t,b,w}$  for  $w \in \{1, \dots, NumRRDG_{t,b}\}$  designates the ramp rate in MW per minute at which the *resource* can increase the amount of *energy* it supplies in time-step  $t \in TS$  while operating in the range between  $RmpRngMaxDG_{t,b,w-1}$  and  $RmpRngMaxDG_{t,b,w}$ , where  $RmpRngMaxDG_{t,b,0}$  shall be equal to zero;
- 4.2.2.14  $DRRDG_{t,b,w}$  for  $w \in \{1, \dots, NumRRDG_{t,b}\}$  designates the ramp rate in MW per minute at which the *resource* can decrease the amount of *energy* it supplies in time-step  $t \in TS$  while operating in the range between  $RmpRngMaxDG_{t,b,w-1}$  and  $RmpRngMaxDG_{t,b,w}$ , where  $RmpRngMaxDG_{t,b,0}$  shall be equal to zero;
- 4.2.2.15  $RLP30R_{t,b}$  designates the *reserve loading point* for *thirty-minute operating reserve* in time-step  $t \in TS$ ; and
- 4.2.2.16  $RLP10S_{t,b}$  designates the *reserve loading point* for synchronized *ten-minute operating reserve* in time-step  $t \in TS$ .
- 4.2.3 With respect to a *dispatchable non-quick start resource* identified by bus  $b \in B^{NQS}$  :

4.2.3.1  $LT_{q,b}^m$  designates the *lead time* in *dispatch day*  $q \in DAYS$  for *thermal state*  $m \in THERM$ ;

4.2.3.2  $MGODG_{t,b}$  designates the *minimum generation cost* to operate at *minimum loading point* in time-step  $t \in TS$ . This parameter is calculated as follows:

$$MGODG_{t,b} = SNL_{t,b} + \sum_{k \in K_{t,b}^{LTMLP}} PLTMLP_{t,b,k} \cdot QLTMLP_{t,b,k}.$$

4.2.3.3  $MGBRTDG_{q,b}$  designates the *minimum generation block run-time* within *dispatch day*  $q \in DAYS$ ;

4.2.3.4  $MaxStartsDG_{q,b}$  designates the *maximum number of starts per day* within *dispatch day*  $q \in DAYS$ ;

4.2.3.5  $MGBDTDG_{q,b}^{HOT}$  designates the *minimum generation block down-time* for a *hot thermal state* within *dispatch day*  $q \in DAYS$ ;

4.2.3.6  $MGBDTDG_{q,b}^{WARM}$  designates the *minimum generation block down-time* for a *warm thermal state* in *dispatch day*  $q \in DAYS$ ;

4.2.3.7  $MGBDTDG_{q,b}^{COLD}$  designates the *minimum generation block down-time* for a *cold thermal state* in *dispatch day*  $q \in DAYS$ ;

4.2.3.8  $PLTMLP_{t,b,k}$  designates the *price* for the maximum incremental quantity of *energy* up to the *minimum loading point* that may be scheduled in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{LTMLP}$ ;

4.2.3.9  $QLTMLP_{t,b,k}$  designates the maximum incremental quantity of *energy* up to the *minimum loading point* that may be scheduled in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,b}^{LTMLP}$ ;

4.2.3.10  $RampE_{q,b,w}^m$  designates the *ramp up energy to minimum loading point* in *dispatch day*  $q \in DAYS$  for  $w \in \{1, \dots, RampHrs_{q,b}^m\}$  and *thermal state*  $m \in THERM$ ;

4.2.3.11  $RampHrs_{q,b}^m$  designates the *ramp hours to minimum loading point* in *dispatch day*  $q \in DAYS$  for *thermal state*  $m \in THERM$ ;

4.2.3.12  $SNL_{t,b}$  designates the *speed no-load offer* in time-step  $t \in TS$ ;

4.2.3.13  $SUDG_{t,b}^m$  designates the *start-up offer* in time-step  $t \in TS$  for *thermal state*  $m \in THERM$ ;

- 4.2.3.14  $SUDG_{t,b}^{DAM}$  designates the *start-up offer* used to evaluate the *day-ahead operational commitment* starting in time-step  $t \in TSC_b$ ;
- 4.2.3.15  $SUAdjDG_{t,b}^m$  designates the *start-up offer* that the optimization function will evaluate in time-step  $t \in TS$  under *thermal state m*.
- 4.2.4 With respect to an *energy limited resource* identified by bus  $b \in B^{ELR}$ :
- 4.2.4.1  $MaxDEL_{q,b}$  designates the *maximum daily energy limit* for a single resource with or without a registered *forebay* within *dispatch day*  $q \in DAYS$ .
- 4.2.5 With respect to a *dispatchable hydroelectric generation resource* identified by bus  $b \in B^{HE}$ :
- 4.2.5.1  $MinHMR_{t,b}$  designates the *hourly must-run* value in time-step  $t \in TS$ ;
- 4.2.5.2  $MinHO_{t,b}$  designates the *minimum hourly output* in time-step  $t \in TS$ ;
- 4.2.5.3  $MinDEL_{q,b}$  designates the *minimum daily energy limit* for a single resource with or without a registered *forebay* within *dispatch day*  $q \in DAYS$ ;
- 4.2.5.4  $MaxStartsHE_{q,b}$  designates the *maximum number of starts per day* within *dispatch day*  $q \in DAYS$ ;
- 4.2.5.5  $StartMW_{b,i}$  for  $i \in \{1, \dots, NStartMW_b\}$  designates the *start indication value* for measuring *maximum number of starts per day*; a start is counted between time-step  $t$  and  $(t + 1)$  if the schedule increases from below  $StartMW_{b,i}$  to at or above  $StartMW_{b,i}$ ; and
- 4.2.5.6  $(ForL_{q,b,i}, ForU_{q,b,i})$  for  $i \in \{1, \dots, NFor_{q,b}\}$  designates the lower and upper limits of the *forbidden regions* and indicate that the resource cannot be scheduled between  $ForL_{q,b,i}$  and  $ForU_{q,b,i}$  for all  $i \in \{1, \dots, NFor_{q,b}\}$  within *dispatch day*  $q \in DAYS$ .
- 4.2.6 With respect to multiple *dispatchable hydroelectric generation resources* with a registered *forebay*:
- 4.2.6.1  $MaxSDEL_{q,s}$  designates the *maximum daily energy limit* shared by all *dispatchable hydroelectric generation resources* in set  $s \in SHE$  for *dispatch day*  $q \in DAYS$ ; and

- 4.2.6.2  $MinSDEL_{q,s}$  designates the *minimum daily energy limit* shared by all *dispatchable hydroelectric generation resources* in set  $s \in SHE$  within *dispatch day*  $q \in DAYS$ .
- 4.2.7 With respect to a *dispatchable hydroelectric generation resource* for which a *MWh ratio* was respected:
- 4.2.7.1  $LNK_q \subseteq B_{up}^{HE} \times B_{dn}^{HE}$  designates the set of linked *dispatchable hydroelectric generation resources* for *dispatch day*  $q \in DAYS$ , where  $LNK_q$  designates a set with elements of the form  $(b_1, b_2)$  where  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$ ;
- 4.2.7.2  $Lag_{q,b_1,b_2} \in \{0, \dots, 23\}$  designates the *time lag* in hours between upstream *dispatchable hydroelectric generation resources*  $b_1 \in B_{up}^{HE}$  and downstream *dispatchable hydroelectric generation resources*  $b_2 \in B_{dn}^{HE}$  for  $(b_1, b_2) \in LNK_q$  for *dispatch day*  $q \in DAYS$ ; and
- 4.2.7.3  $MWhRatio_{q,b_1,b_2}$  designates the *MWh ratio* between upstream *dispatchable hydroelectric generation resources*  $b_1 \in B_{up}^{HE}$  and downstream *dispatchable hydroelectric generation resources*  $b_2 \in B_{dn}^{HE}$  for  $(b_1, b_2) \in LNK_q$  for *dispatch day*  $q \in DAYS$ .
- 4.2.8 With respect to a *pseudo-unit* identified by bus  $b \in B^{PSU}$ :
- 4.2.8.1  $STShareMLP_b$  designates the steam turbine *resource's share* of the *minimum loading point region*;
- 4.2.8.2  $STShareDR_b$  designates the steam turbine *resource's share* of the *dispatchable region*;
- 4.2.8.3  $RampCT_{q,b,w}^m$  designates the quantity of *energy* injected  $w$  hours before the *pseudo-unit* reaches its *minimum loading point* in *dispatch day*  $q \in DAYS$  and *thermal state*  $m \in THERM$  that is attributed to the combustion turbine *resource* for  $w \in \{1, \dots, RampHrs_{q,b}^m\}$ ; and
- 4.2.8.4  $RampST_{q,b,w}^m$  designates the quantity of *energy* injected  $w$  hours before the *pseudo-unit* reaches its *minimum loading point* in *dispatch day*  $q \in DAYS$  for *thermal state*  $m \in THERM$  that is attributed to the steam turbine *resource* for  $w \in \{1, \dots, RampHrs_{q,b}^m\}$ .
- 4.2.9 With respect to a *dispatchable load* identified by bus  $b \in B^{DL}$ :
- 4.2.9.1  $QDL_{t,b,j}$  designates the maximum incremental quantity of *energy* that may be scheduled in time-step  $t \in TS$  in association with *bid lamination*  $j \in J_{t,b}^E$ ;

- 4.2.9.2  $PDL_{t,b,j}$  designates the price for the maximum incremental quantity of *energy* in time-step  $t \in TS$  in association with *bid* lamination  $j \in J_{t,b}^E$ ;
- 4.2.9.3  $Q10SDL_{t,b,j}$  designates the maximum incremental quantity of synchronized *ten-minute operating reserve* that may be scheduled in time-step  $t \in TS$  in association with *offer* lamination  $j \in J_{t,b}^{10S}$ ;
- 4.2.9.4  $P10SDL_{t,b,j}$  designates the price for the maximum incremental quantity of synchronized *ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer* lamination  $j \in J_{t,b}^{10S}$ ;
- 4.2.9.5  $Q10NDL_{t,b,j}$  designates the maximum incremental quantity of non-synchronized *ten-minute operating reserve* that may be scheduled in time-step  $t \in TS$  in association with *offer* lamination  $j \in J_{t,b}^{10N}$ ;
- 4.2.9.6  $P10NDL_{t,b,j}$  designates the price for the maximum incremental quantity of non-synchronized *ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer* lamination  $j \in J_{t,b}^{10N}$ ;
- 4.2.9.7  $Q30RDL_{t,b,j}$  designates the maximum incremental quantity of *thirty-minute operating reserve* that may be scheduled in time-step  $t \in TS$  in association with *offer* lamination  $j \in J_{t,b}^{30R}$ ;
- 4.2.9.8  $P30RDL_{t,b,j}$  designates the price for the maximum incremental quantity of *thirty-minute operating reserve* in time-step  $t \in TS$  in association with *offer* lamination  $j \in J_{t,b}^{30R}$ ;
- 4.2.9.9  $ORRDL_b$  designates the *operating reserve* ramp rate in MW per minute for reductions in load consumption;
- 4.2.9.10  $NumRRDL_{t,b}$  designates the number of ramp rates provided in time-step  $t \in TS$ ;
- 4.2.9.11  $RmpRngMaxDL_{t,b,w}$  for  $w \in \{1, \dots, NumRRDL_{t,b}\}$  designates the  $w^{\text{th}}$  ramp rate break point in time-step  $t \in TS$ ;
- 4.2.9.12  $URRDL_{t,b,w}$  for  $w \in \{1, \dots, NumRRDL_{t,b}\}$  designates the ramp rate in MW per minute at which the *dispatchable load* can increase its amount of *energy* consumption in time-step  $t \in TS$  while operating in the range between  $RmpRngMaxDL_{t,b,w-1}$  and  $RmpRngMaxDL_{t,b,w}$ , where  $RmpRngMaxDL_{t,b,0}$  shall be equal to zero;
- 4.2.9.13  $DRRDL_{t,b,w}$  for  $w \in \{1, \dots, NumRRDL_{t,b}\}$  designates the ramp rate in MW per minute at which the *dispatchable load* can decrease its amount of

energy consumption in time-step  $t \in TS$  while operating in the range between  $RmpRngMaxDL_{t,b,w-1}$  and  $RmpRngMaxDL_{t,b,w}$ , where  $RmpRngMaxDL_{t,b,0}$  shall be equal to zero; and

- 4.2.9.14  $QDLFIRM_{t,b}$  designates the quantity of energy that is bid at the maximum market clearing price in time-step  $t \in TS$ .
- 4.2.10 With respect to an hourly demand response resource identified by bus  $b \in B^{HDR}$ :
- 4.2.10.1  $QHDR_{t,b,j}$  designates an maximum incremental quantity of reduction in energy consumption that may be scheduled in time-step  $t \in TS$  in association with bid lamination  $j \in J_{t,b}^E$ ;
- 4.2.10.2  $PHDR_{t,b,j}$  designates the price for the maximum incremental quantity of reduction in energy consumption for time-step  $t \in TS$  in association with bid lamination  $j \in J_{t,b}^E$ ;
- 4.2.10.3  $URRHDR_b$  designates the maximum rate in MW per minute at which the hourly demand response resource can decrease its amount of energy consumption; and
- 4.2.10.4  $DRRHDR_b$  designates the maximum rate in MW per minute at which the hourly demand response resource can increase its amount of energy consumption.
- 4.2.11 With respect to a boundary entity resource import from intertie zone bus  $d \in DI$ , where the locational marginal price represents the price for the intertie metering point:
- 4.2.11.1  $QIG_{t,d,k}$  designates the maximum incremental quantity of energy that may be scheduled to import in time-step  $t \in TS$  in association with offer lamination  $k \in K_{t,d}^E$ ;
- 4.2.11.2  $PIG_{t,d,k}$  designates the price for the maximum incremental quantity of energy may be scheduled to import in time-step  $t \in TS$  in association with offer lamination  $k \in K_{t,d}^E$ ;
- 4.2.11.3  $Q10NIG_{t,d,k}$  designates the maximum incremental quantity of non-synchronized ten-minute operating reserve that may be scheduled in time-step  $t \in TS$  in association with offer lamination  $k \in K_{t,d}^{10N}$ ;
- 4.2.11.4  $P10NIG_{t,d,k}$  designates the price for the maximum incremental quantity of non-synchronized ten-minute operating reserve in time-step  $t \in TS$  in association with offer lamination  $k \in K_{t,d}^{10N}$ ;



- 4.2.11.5  $Q30RIG_{t,d,k}$  designates the maximum incremental quantity of *thirty-minute operating reserve* quantity that may be scheduled in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,d}^{30R}$ ; and
- 4.2.11.6  $P30RIG_{t,d,k}$  designates the price for the maximum incremental quantity of *thirty-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $k \in K_{t,d}^{30R}$ .
- 4.2.12 With respect to a *boundary entity resource export to intertie zone sink bus*  $d \in DX$ , where the *locational marginal price* represents the price for the *intertie metering point*:
- 4.2.12.1  $QXL_{t,d,j}$  designates the maximum incremental quantity of *energy* that may be scheduled to export in time-step  $t \in TS$  in association with *bid lamination*  $j \in J_{t,d}^E$ ;
- 4.2.12.2  $PXL_{t,d,j}$  designates the price for the maximum incremental quantity of *energy* that may be scheduled to export in time-step  $t \in TS$  in association with *bid lamination*  $j \in J_{t,d}^E$ ;
- 4.2.12.3  $Q10NXL_{t,d,j}$  designates the maximum incremental quantity of non-synchronized *ten-minute operating reserve* that may be scheduled to provide in time-step  $t \in TS$  in association with *offer lamination*  $j \in J_{t,d}^{10N}$ ;
- 4.2.12.4  $P10NXL_{t,d,j}$  designates the price for the maximum incremental quantity of non-synchronized *ten-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $j \in J_{t,d}^{10N}$ ;
- 4.2.12.5  $Q30RXL_{t,d,j}$  designates the maximum incremental quantity of *thirty-minute operating reserve* that may be scheduled to provide in time-step  $t \in TS$  in association with *offer lamination*  $j \in J_{t,d}^{30R}$ ; and
- 4.2.12.6  $P30RXL_{t,d,j}$  designates the price for the maximum incremental quantity of *thirty-minute operating reserve* in time-step  $t \in TS$  in association with *offer lamination*  $j \in J_{t,d}^{30R}$ .
- 4.2.13 With respect to a *linked wheeling through transaction*:
- 4.2.13.1  $L_t \subseteq DX \times DI$  designates the set of linked *boundary entity resource import and export buses* corresponding to *linked wheeling through transactions*, where  $L_t$  is a set with elements of the form  $(dx, di)$  where  $dx \in DX$  and  $di \in DI$ .

## 4.3 IESO Data Parameters

### 4.3.1 Variable Generation Forecast

4.3.1.1  $FG_{t,b}$  designates the IESO's centralized *variable generation* forecast for a *variable generation resource* identified by bus  $b \in B^{VG}$  in time-step  $t \in TS$ .

### 4.3.2 Variable Generation Tie-Breaking

4.3.2.1  $NumVG_t$  designates the number of *variable generation resources* in the daily *dispatch* order for time-step  $t \in TS$ ; and

4.3.2.2  $TBM_{t,b} \in \{1, \dots, NumVG_t\}$  designates the tie-breaking modifier for the *variable generation resource* at bus  $b \in B^{VG}$  for time-step  $t \in TS$ .

### 4.3.3 Intertie Curtailments

4.3.3.1  $ICMaxXL_{t,d}$  designates the maximum limit on the quantity of *energy* scheduled for export to *intertie zone* sink bus  $d \in DX$  and time-step  $t \in TS$  as the result of an *intertie* curtailment;

4.3.3.2  $ICMinXL_{t,d}$  designates the minimum limit on the quantity of *energy* scheduled for export to *intertie zone* sink bus  $d \in DX$  and time-step  $t \in TS$  as the result of an *intertie* curtailment;

4.3.3.3  $ICMaxIG_{t,d}$  designates the maximum limit on the quantity of *energy* scheduled for import from *intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$  as the result of an *intertie* curtailment;

4.3.3.4  $ICMax10NIG_{t,d}$  designates the maximum limit on the quantity of non-synchronized *ten-minute operating reserve* scheduled for import from *intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$  as the result of an *intertie* curtailment;

4.3.3.5  $ICMax30RIG_{t,d}$  designates the maximum limit on the quantity of *thirty-minute operating reserve* scheduled for import from *intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$  as the result of an *intertie* curtailment;

4.3.3.6  $ICMinIG_{t,d}$  designates the minimum limit on the quantity of *energy* scheduled for import from *intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$  as the result of an *intertie* curtailment;

4.3.3.7  $ICMin10NIG_{t,d}$  designates the minimum limit on the quantity of non-synchronized *ten-minute operating reserve* scheduled for import from

*intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$  as the result of an *intertie* curtailment; and

- 4.3.3.8  $ICMin30RIG_{t,d}$  designates the minimum limit on the quantity of *thirty-minute operating reserve* scheduled for import from *intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$  as the result of an *intertie* curtailment.
- 4.3.4 Operating Reserve Requirements
- 4.3.4.1  $TOT10S_t$  designates the synchronized *ten-minute operating reserve* requirement;
  - 4.3.4.2  $TOT10R_t$  designates the total *ten-minute operating reserve* requirement;
  - 4.3.4.3  $TOT30R_t$  designates the *thirty-minute operating reserve* requirement;
  - 4.3.4.4  $ORREG$  designates the set of regions for which regional *operating reserve* limits have been defined;
  - 4.3.4.5  $REGMin10R_{t,r}$  designates the minimum requirement for total *ten-minute operating reserve* in region  $r \in ORREG$  in time-step  $t \in TS$ ;
  - 4.3.4.6  $REGMin30R_{t,r}$  designates the minimum requirement for *thirty-minute operating reserve* in region  $r \in ORREG$  in time-step  $t \in TS$ ;
  - 4.3.4.7  $REGMax10R_{t,r}$  designates the maximum amount of total *ten-minute operating reserve* that may be scheduled in region  $r \in ORREG$  in time-step  $t \in TS$ ; and
  - 4.3.4.8  $REGMax30R_{t,r}$  designates the maximum amount of *thirty-minute operating reserve* that may be scheduled in region  $r \in ORREG$  in time-step  $t \in TS$ .
- 4.3.5 Intertie Limits
- 4.3.5.1  $EnCoeff_{a,z}$  designates the coefficient for calculating the contribution of scheduled *energy* flows and *operating reserve* inflows for *intertie zone*  $a \in A$ , which is part of *intertie* limit constraint  $z \in Z_{Sch}$ . A coefficient of  $+1$  shall describe flows into Ontario while a coefficient of  $-1$  shall describe flows out of Ontario;
  - 4.3.5.2  $MaxExtSch_{t,z}$  designates the maximum flow limit for *intertie* flow constraint  $z \in Z_{Sch}$  in time-step  $t \in TS$ ;
  - 4.3.5.3  $ExtDSC_t$  designates the net interchange scheduling limit for when the net flows over all *interties* from time-step  $(t-1)$  to time-step  $t$  decrease; and

4.3.5.4  $ExtUSC_t$  designates the net interchange scheduling limit for when the net flows over all *inerties* from time-step  $(t - 1)$  to time-step  $t$  increase.

#### 4.3.6 Resource Minimum and Maximum Constraints

4.3.6.1 Where applicable the minimum or maximum output of a *dispatchable generation resource* or a *non-dispatchable generation resource*, minimum or maximum consumption of a *dispatchable load*, and minimum and maximum reduction of an *hourly demand response resource* may be limited due to *reliability* constraints, applicable *contracted ancillary services*, *day-ahead operational commitments*, previous *pre-dispatch operational commitments*, *outages*, derates, activation/non-activation of *hourly demand response resources* and other constraints, such that:

4.3.6.1.1  $MinDL_{t,b}$  designates the most restrictive minimum consumption limit for the *dispatchable load* at bus  $b \in B^{DL}$ ;

4.3.6.1.2  $MaxDL_{t,b}$  designates the most restrictive maximum consumption limit for the *dispatchable load* at bus  $b \in B^{DL}$ ;

4.3.6.1.3  $MinNDG_{t,b}$  designates the most restrictive minimum output limit for the *non-dispatchable generation resource* at bus  $b \in B^{NDG}$ ;

4.3.6.1.4  $MaxNDG_{t,b}$  designates the most restrictive maximum output limit for the *non-dispatchable generation resource* at bus  $b \in B^{NDG}$ ;

4.3.6.1.5  $MinDG_{t,b}$  designates the most restrictive minimum output limit for the *dispatchable generation resource* at bus  $b \in B^{DG}$ ;

4.3.6.1.6  $MaxDG_{t,b}$  designates the most restrictive maximum output limit for the *dispatchable generation resource* at bus  $b \in B^{DG}$ ;

4.3.6.1.7  $MaxMLP_{t,b}$  designates the maximum output limit in time-step  $t$  for the *minimum loading point* region of a *pseudo-unit* at bus  $b \in B^{PSU}$ ;

4.3.6.1.8  $MaxDR_{t,b}$  designates the maximum output limit in time-step  $t$  for the *dispatchable* region of a *pseudo-unit* at bus  $b \in B^{PSU}$ ;

4.3.6.1.9  $MaxDF_{t,b}$  designates the maximum output limit in time-step  $t$  for the *duct firing* region of a *pseudo-unit* at bus  $b \in B^{PSU}$ ;

4.3.6.1.10  $MinHDR_{t,b}$  designates the minimum load reduction level that may be scheduled for the *hourly demand response resource* at bus  $b \in B^{HDR}$ ; and

4.3.6.1.11  $MaxHDR_{t,b}$  designates the maximum load reduction level that may be scheduled for the *hourly demand response resource* at bus  $b \in B^{HDR}$ .

4.3.7 Constraint violation penalties for time step  $t \in TS$ :

4.3.7.1  $(PLdViolSch_{st,i}, QLdViolSch_{t,i})$  for  $i \in \{1, \dots, N_{LdViol_t}\}$  designates the price-quantity segments of the penalty curve for under generation used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;

4.3.7.2  $(PLdViolPrc_{t,i}, QLdViolPrc_{t,i})$  for  $i \in \{1, \dots, N_{LdViol_t}\}$  designates the price-quantity segments of the penalty curve for under generation used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;

4.3.7.3  $(PGenViolSch_{t,i}, QGenViolSch_{t,i})$  for  $i \in \{1, \dots, N_{GenViol_t}\}$  designates the price-quantity segments of the penalty curve for over generation used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;

4.3.7.4  $(PGenViolPrc_{t,i}, QGenViolPrc_{t,i})$  for  $i \in \{1, \dots, N_{GenViol_t}\}$  designates the price-quantity segments of the penalty curve for over generation used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;

4.3.7.5  $(P10SViolSch_{t,i}, Q10SViolSch_{t,i})$  for  $i \in \{1, \dots, N_{10SViol_t}\}$  designates the price-quantity segments of the penalty curve for the synchronized *ten-minute operating reserve* requirement used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;

4.3.7.6  $(P10SViolPrc_{t,i}, Q10SViolPrc_{t,i})$  for  $i \in \{1, \dots, N_{10SViol_t}\}$  designates the price-quantity segments of the penalty curve for the synchronized *ten-minute operating reserve* requirement used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;

4.3.7.7  $(P10RViolSch_{t,i}, Q10RViolSch_{t,i})$  for  $i \in \{1, \dots, N_{10RViol_t}\}$  designates the price-quantity segments of the penalty curve for the total *ten-minute operating reserve* requirement used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;

- 4.3.7.8  $(P_{10RViolPrc_{t,i}}, Q_{10RViolPrc_{t,i}})$  for  $i \in \{1, \dots, N_{10RViol_t}\}$  designates the price-quantity segments of the penalty curve for the total *ten-minute operating reserve* requirement used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.9  $(P_{30RViolSch_{t,i}}, Q_{30RViolSch_{t,i}})$  for  $i \in \{1, \dots, N_{30RViol_t}\}$  designates the price-quantity segments of the penalty curve for the total *thirty-minute operating reserve* requirement and, when applicable, the flexibility *operating reserve* requirement used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.10  $(P_{30RViolPrc_{t,i}}, Q_{30RViolPrc_{t,i}})$  for  $i \in \{1, \dots, N_{30RViol_t}\}$  designates the price-quantity segments of the penalty curve for the total *thirty-minute operating reserve* requirement and, when applicable, the flexibility *operating reserve* requirement used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.11  $(P_{REG10RViolSch_{t,i}}, Q_{REG10RViolSch_{t,i}})$  for  $i \in \{1, \dots, N_{REG10RViol_t}\}$  designates the price-quantity segments of the penalty curve for area total *ten-minute operating reserve* minimum requirements used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.12  $(P_{REG10RViolPrc_{t,i}}, Q_{REG10RViolPrc_{t,i}})$  for  $i \in \{1, \dots, N_{REG10RViol_t}\}$  designates the price-quantity segments of the penalty curve for area total *ten-minute operating reserve* minimum requirements used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.13  $(P_{REG30RViolSch_{t,i}}, Q_{REG30RViolSch_{t,i}})$  for  $i \in \{1, \dots, N_{REG30RViol_t}\}$  designates the price-quantity segments of the penalty curve for area *thirty-minute operating reserve* minimum requirements used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.14  $(P_{REG30RViolPrc_{t,i}}, Q_{REG30RViolPrc_{t,i}})$  for  $i \in \{1, \dots, N_{REG30RViol_t}\}$  designates the price-quantity segments of the penalty curve for area *thirty-minute operating reserve* minimum requirements used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.15  $(P_{XREG10RViolSch_{t,i}}, Q_{XREG10RViolSch_{t,i}})$  for  $i \in \{1, \dots, N_{XREG10RViol_t}\}$  designates the price-quantity segments of the penalty curve for area total *ten-minute operating reserve* maximum restrictions used by the Pre-

Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;

- 4.3.7.16  $(PXREG10RViolPrc_{t,i}, QXREG10RViolPrc_{t,i})$  for  $i \in \{1, \dots, N_{XREG10RViol_t}\}$  designates the price-quantity segments of the penalty curve for area total *ten-minute operating reserve* maximum restrictions used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.17  $(PXREG30RViolSch_{t,i}, QXREG30RViolSch_{t,i})$  for  $i \in \{1, \dots, N_{XREG30RViol_t}\}$  designates the price-quantity segments of the penalty curve for area total *thirty-minute operating reserve* maximum restrictions used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.18  $(PXREG30RViolPrc_{t,i}, QXREG30RViolPrc_{t,i})$  for  $i \in \{1, \dots, N_{XREG30RViol_t}\}$  designates the price-quantity segments of the penalty curve for area total *thirty-minute operating reserve* maximum restrictions used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.19  $(PPreITLViolSch_{f,t,i}, QPreITLViolSch_{f,t,i})$  for  $i \in \{1, \dots, N_{PreITLViol_{f,t}}\}$  designates the price-quantity segments of the penalty curve for exceeding the pre-contingency limit of the transmission constraint for *facility*  $f \in F$  used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.20  $(PPreITLViolPrc_{f,t,i}, QPreITLViolPrc_{f,t,i})$  for  $i \in \{1, \dots, N_{PreITLViol_{f,t}}\}$  designates the price-quantity segments of the penalty curve for exceeding the pre-contingency limit of the transmission constraint for *facility*  $f \in F$  used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.21  $(PITLViolSch_{c,f,t,i}, QITLViolSch_{c,f,t,i})$  for  $i \in \{1, \dots, N_{ITLViol_{c,f,t}}\}$  designates the price-quantity segments of the penalty curve for exceeding the contingency  $c \in C$  post-contingency limit of the transmission constraint for *facility*  $f \in F$  used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.22  $(PITLViolPrc_{c,f,t,i}, QITLViolPrc_{c,f,t,i})$  for  $i \in \{1, \dots, N_{ITLViol_{c,f,t}}\}$  designates the price-quantity segments of the penalty curve for exceeding the contingency  $c \in C$  post-contingency limit of the transmission constraint for *facility*  $f \in F$  used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;

- 4.3.7.23 ( $P_{PreXTLViolSch_{z,t,i}}$ ,  $Q_{PreXTLViolSch_{z,t,i}}$ ) for  $i \in \{1, \dots, N_{PreXTLViol_{z,t}}\}$  designates the price-quantity segments of the penalty curve for exceeding the flow limit specified by  $z \in Z_{Sch}$  used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.24 ( $P_{PreXTLViolPrc_{z,t,i}}$ ,  $Q_{PreXTLViolPrc_{z,t,i}}$ ) for  $i \in \{1, \dots, N_{PreXTLViol_{z,t}}\}$  designates the price-quantity segments of the penalty curve for exceeding the flow limit specified by  $z \in Z_{Sch}$  used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.25 ( $P_{NIUViolSch_{t,i}}$ ,  $Q_{NIUViolSch_{t,i}}$ ) for  $i \in \{1, \dots, N_{NIUViol_t}\}$  designates the price-quantity segments of the penalty curve for exceeding the time-step  $t$  net interchange increase constraint between time-steps  $(t-1)$  and  $t$  used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.26 ( $P_{NIUViolPrc_{t,i}}$ ,  $Q_{NIUViolPrc_{t,i}}$ ) for  $i \in \{1, \dots, N_{NIUViol_t}\}$  designates the price-quantity segments of the penalty curve for exceeding the time-step  $t$  net interchange increase constraint between time-steps  $(t-1)$  and  $t$  used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.27 ( $P_{NIDViolSch_{t,i}}$ ,  $Q_{NIDViolSch_{t,i}}$ ) for  $i \in \{1, \dots, N_{NIDViol_t}\}$  designates the price-quantity segments of the penalty curve for exceeding the time-step  $t$  net interchange decrease constraint between time-steps  $(t-1)$  and  $t$  used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.28 ( $P_{NIDViolPrc_{t,i}}$ ,  $Q_{NIDViolPrc_{t,i}}$ ) for  $i \in \{1, \dots, N_{NIDViol_t}\}$  designates the price-quantity segments of the penalty curve for exceeding the time-step  $t$  net interchange decrease constraint between time-steps  $(t-1)$  and  $t$  used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.29 ( $P_{MaxDelViolSch_{t,i}}$ ,  $Q_{MaxDelViolSch_{t,i}}$ ) for  $i \in \{1, \dots, N_{MaxDelViol_t}\}$  designates the price-quantity segments of the penalty curve for exceeding a resource's maximum daily energy limit used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.30 ( $P_{MaxDelViolPrc_{t,i}}$ ,  $Q_{MaxDelViolPrc_{t,i}}$ ) for  $i \in \{1, \dots, N_{MaxDelViol_t}\}$  designates the price-quantity segments of the penalty curve for exceeding a resource's maximum daily energy limit used by the Pre-Dispatch Pricing



algorithm in section 9 and Reference Level Pricing algorithm in section 13;

- 4.3.7.31 ( $PMinDelViolSch_{t,i}, QMinDelViolSch_{t,i}$ ) for  $i \in \{1, \dots, N_{MinDelViol_t}\}$  designates the price-quantity segments of the penalty curve for under-scheduling a *resource's minimum daily energy limit* used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.32 ( $PMinDelViolPrc_{t,i}, QMinDelViolPrc_{t,i}$ ) for  $i \in \{1, \dots, N_{MinDelViol_t}\}$  designates the price-quantity segments of the penalty curve for under-scheduling a *resource's minimum daily energy limit* used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.33 ( $PSMaxDelViolSch_{t,i}, QSMAXDelViolSch_{t,i}$ ) for  $i \in \{1, \dots, N_{SMAXDelViol_t}\}$  designate the price-quantity segments of the penalty curve for exceeding a shared *maximum daily energy limit* used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.34 ( $PSMaxDelViolPrc_{t,i}, QSMAXDelViolPrc_{t,i}$ ) for  $i \in \{1, \dots, N_{MAXDelViol_t}\}$  designate the price-quantity segments of the penalty curve for exceeding a shared *maximum daily energy limit* used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.35 ( $PSMinDelViolSch_{t,i}, QSMINDelViolSch_{t,i}$ ) for  $i \in \{1, \dots, N_{SMINDelViol_t}\}$  designate the price-quantity segments of the penalty curve for under-scheduling a shared *minimum daily energy limit* used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;
- 4.3.7.36 ( $PSMinDelViolPrc_{t,i}, QSMINDelViolPrc_{t,i}$ ) for  $i \in \{1, \dots, N_{SMINDelViol_t}\}$  designate the price-quantity segments of the penalty curve for under-scheduling a shared *minimum daily energy limit* used by the Pre-Dispatch Pricing algorithm in section 9 and Reference Level Pricing algorithm in section 13;
- 4.3.7.37 ( $POGenLnkViolSch_{t,i}, QOGenLnkViolSch_{t,i}$ ) for  $i \in \{1, \dots, N_{OGenLnkViol_t}\}$  designate the price-quantity segments of the penalty curve for over generation on a downstream *resource* used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12;

- 4.3.7.38 ( $PUGenLnkViolSch_{t,i}$ ,  $QUGenLnkViolSch_{t,i}$ ) for  $i \in \{1, \dots, N_{UGenLnkViol_t}\}$  designate the price-quantity segments of the penalty curve for under generation on a downstream *resource* used by the Pre-Dispatch Scheduling algorithm in section 8 and the Reference Level Scheduling algorithm in section 12; and
- 4.3.7.39  $NISLPen$  designates the net interchange scheduling limit constraint violation penalty price for *locational marginal pricing*.
- 4.3.8 Price Bounds
- 4.3.8.1  $EngyPrcCeil$  designates and is equal to the *maximum market clearing price* for energy;
- 4.3.8.2  $EngyPrcFlr$  designates and is equal to the *settlement floor price* for energy;
- 4.3.8.3  $ORPrcCeil$  designates and is equal to the *maximum operating reserve price* for all classes of *operating reserve*; and
- 4.3.8.4  $ORPrcFlr$  designates the minimum price for all classes of *operating reserve* and is equal to \$0.
- 4.3.9 Ex-Ante Market Power Mitigation
- 4.3.9.1  $BCACondThresh$  designates the threshold for the congestion component of a *resource's locational marginal price* for energy, above which the *resource* will meet the broad constrained area condition, and is equal to \$25/MWh;
- 4.3.9.2  $IBPThresh$  designates the *inertie border price* threshold for energy and is equal to \$100/MWh;
- 4.3.9.3  $ORGCondThresh$  designates the global market power condition threshold for a *resource's locational marginal price* for *operating reserve* and is equal to \$15/MW;
- 4.3.9.4  $PDGRef_{t,b,k'}$  designates the *reference level value* for energy lamination  $k' \in K_{t,b}^E$  for the *resource* at bus  $b \in B^{DG}$  in time-step  $t \in TS$ ;
- 4.3.9.5  $P10SDGRef_{t,b,k'}$  designates the *reference level value* for synchronized *ten-minute operating reserve* lamination  $k' \in K_{t,b}^{10S}$  for the *resource* at bus  $b \in B^{DG}$  in time-step  $t \in TS$ ;

- 4.3.9.6  $P10NDGRef_{t,b,k'}$  designates the *reference level value* for non-synchronized *ten-minute operating reserve lamination*  $k' \in K_{t,b}^{10N}$  for the *resource* at bus  $b \in B^{DG}$  in time-step  $t \in TS$ ;
- 4.3.9.7  $P30RDGRef_{t,b,k'}$  designates the *reference level value* for *thirty-minute operating reserve lamination*  $k' \in K_{t,b}^{30R}$  for the *resource* at bus  $b \in B^{DG}$  in time-step  $t \in TS$ ;
- 4.3.9.8  $P10SDLRef_{t,b,j'}$  designates the *reference level value* for synchronized *ten-minute operating reserve lamination*  $j' \in J_{t,b}^{10S}$  for the *resource* at bus  $b \in B^{DL}$  in time-step  $t \in TS$ ;
- 4.3.9.9  $P10NDLRef_{t,b,j'}$  designates the *reference level value* for non-synchronized *ten-minute operating reserve lamination*  $j' \in J_{t,b}^{10N}$  for the *resource* at bus  $b \in B^{DL}$  in time-step  $t \in TS$ ;
- 4.3.9.10  $P30RDLRef_{t,b,j'}$  designates the *reference level value* for *thirty-minute operating reserve lamination*  $j' \in J_{t,b}^{30R}$  for the *resource* at bus  $b \in B^{DG}$  in time-step  $t \in z$
- 4.3.9.11  $SUDGRef_{t,b}$  designates the *reference level value* for the *start-up offer* for the *resource* at bus  $b \in B^{NQS}$  in time-step  $t \in TS$ ;
- 4.3.9.12  $SNLRef_{t,b}$  designates the *reference level value* for the *speed no-load offer* for the *resource* at bus  $b \in B^{NQS}$  in time-step  $t \in TS$ ;
- 4.3.9.12  $PLTMLPRef_{t,b,k'}$  designates the *reference level value* for the *energy* up to the *minimum loading point reference level lamination*  $k' \in K_{h,b}^{LTMLP}$  of the *offer* for the *resource* at bus  $b \in B^{DG}$  in time-step  $t \in TS$ ;
- 4.3.9.14  $CTEnThresh1^{NCA}$  designates the conduct threshold for a *resource* in a *narrow constrained area* as a percent increase above the *reference level value* of the *energy offer* for the *resource* and is equal to 50%;
- 4.3.9.15  $CTEnThresh2^{NCA}$  designates the conduct threshold for a *resource* in a *narrow constrained area* as a \$/MWh increase above the *reference level value* of the *energy offer* for the *resource* and is equal to \$25/MWh;
- 4.3.9.16  $CTSUThresh^{NCA}$  designates the conduct threshold for a *resource* in a *narrow constrained area* as a percent increase above the *reference level value* of the *start-up offer* for the *resource* and is equal to 25%;
- 4.3.9.17  $CTSNLThresh^{NCA}$  designates the conduct threshold for a *resource* in a *narrow constrained area* as a percent increase above the *reference level value* of the *speed no-load offer* for the *resource* and is equal to 25%;

- 4.3.9.18 *CTEnThresh1<sup>DCA</sup>* designates the conduct threshold for a *resource* in a *dynamic constrained area* as a percent increase above the *reference level value* of the *energy offer* for the *resource* and is equal to 50%;
- 4.3.9.19 *CTEnThresh2<sup>DCA</sup>* designates the conduct threshold for a *resource* in a *dynamic constrained area* as a \$/MWh increase above the *reference level value* of the *energy offer* for the *resource* and is equal to \$25/MWh;
- 4.3.9.20 *CTSUThresh<sup>DCA</sup>* designates the conduct threshold for a *resource* in a *dynamic constrained area* as a percent increase above the *reference level value* of the *start-up offer* for the *resource* and is equal to 25%;
- 4.3.9.21 *CTSNLThresh<sup>DCA</sup>* designates the conduct threshold for a *resource* in a *dynamic constrained area* as a percent increase above the *reference level value* of the *speed no-load offer* for the *resource* and is equal to 25%;
- 4.3.9.22 *CTEnThresh1<sup>BCA</sup>* designates the conduct threshold for a *resource* in a *broad constrained area* as a percent increase above the *reference level value* of the *energy offer* for the *resource* and is equal to 300%;
- 4.3.9.23 *CTEnThresh2<sup>BCA</sup>* designates the conduct threshold for a *resource* in a *broad constrained area* as a \$/MWh increase above the *reference level value* of the *energy offer* for the *resource* and is equal to \$100/MWh;
- 4.3.9.24 *CTSUThresh<sup>BCA</sup>* designates the conduct threshold for a *resource* in a *broad constrained area* as a percent increase above the *reference level value* of the *start-up offer* for the *resource* and is equal to 100%;
- 4.3.9.25 *CTSNLThresh<sup>BCA</sup>* designates the conduct threshold for a *resource* in a *broad constrained area* as a percent increase above the *reference level value* of the *speed no-load offer* for the *resource* and is equal to 100%;
- 4.3.9.26 *CTEnThresh1<sup>GMP</sup>* designates the global market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *energy offer* for the *resource* and is equal to 300%;
- 4.3.9.27 *CTEnThresh2<sup>GMP</sup>* designates the global market power conduct threshold for a *resource* as a \$/MWh increase above the *reference level value* of the *energy offer* for the *resource* and is equal to \$100 MW/h;
- 4.3.9.28 *CTSUThresh<sup>GMP</sup>* designates the global market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *start-up offer* for the *resource* and is equal to 100%;
- 4.3.9.29 *CTSNLThresh<sup>GMP</sup>* designates the global market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *speed no-load offer* for the *resource* and is equal to 100%;

- 4.3.9.30 *CTORThresh1<sup>ORL</sup>* designates the local market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *operating reserve offer* for the *resource* and is equal to 10%;
- 4.3.9.31 *CTORThresh2<sup>ORL</sup>* designates the local market power conduct threshold for a *resource* as a \$/MW increase above the *reference level value* of the *operating reserve offer* for the *resource* and is equal to \$25/MW;
- 4.3.9.32 *CTEnThresh1<sup>ORL</sup>* designates the local market power conduct threshold for *energy to minimum loading point* for a *resource* as a percent increase above the *reference level value* of the *offer for energy* up to the *minimum loading point* for the *resource* and is equal to 10%;
- 4.3.9.33 *CTEnThresh2<sup>ORL</sup>* designates the local market power conduct threshold for *energy to minimum loading point* conduct threshold for a *resource* as a \$/MW increase above the *reference level value* of the *energy for energy* up to the *minimum loading point* for the *resource* and is equal to \$25/MW;
- 4.3.9.34 *CTSUThresh<sup>ORL</sup>* designates the local market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *start-up offer* for the *resource* and is equal to 10%;
- 4.3.9.35 *CTSNLThresh<sup>ORL</sup>* designates the local market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *speed no-load offer* for the *resource* and is equal to 10%;
- 4.3.9.36 *CTORThresh1<sup>ORG</sup>* designates the global market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *operating reserve offer* for the *resource* and is equal to 50%;
- 4.3.9.37 *CTORThresh2<sup>ORG</sup>* designates the global market power conduct threshold for a *resource* as a \$/MW increase above the *reference level value* of the *operating reserve offer* for the *resource* and is equal to \$25/MW;
- 4.3.9.38 *CTEnThresh1<sup>ORG</sup>* designates the global market power conduct threshold for *energy to minimum loading point* for a *resource* as a percent increase above the *reference level value* of the *offer for energy* up to the *minimum loading point* for the *resource* and is equal to 50%;
- 4.3.9.39 *CTEnThresh2<sup>ORG</sup>* designates the global market power conduct threshold for *energy to minimum loading point* for a *resource* as a \$/MW increase above the *reference level value* of the *offer for energy* up to the *minimum loading point* for the *resource* and is equal to \$25/MW;
- 4.3.9.40 *CTSUThresh<sup>ORG</sup>* designates the global market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *start-up offer* for the *resource* and is equal to 25%;

- 4.3.9.41 *CTSNLThresh<sup>ORG</sup>* designates the global market power conduct threshold for a *resource* as a percent increase above the *reference level value* of the *speed no-load offer* for the *resource* and is equal to 25%;
- 4.3.9.42 *CTEnMinOffer* designates the minimum price for the *offer* lamination for *energy* to be included in the Conduct Test. *Offer* laminations for *energy* below this value are excluded from the Conduct Test and is equal to \$25/MWh;
- 4.3.9.43 *CTORMinOffer* designates the minimum price for the *offer* lamination for *operating reserve* to be included in the Conduct Test. *Offer* laminations for *operating reserve* below this value are excluded from the Conduct Test and is equal to \$5/MW;
- 4.3.9.44 *ITThresh1<sup>NCA</sup>* designates the price impact threshold for a *resource* in a *narrow constrained area* as a percent increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to 50%;
- 4.3.9.45 *ITThresh2<sup>NCA</sup>* designates the price impact threshold for a *resource* in a *narrow constrained area* as a \$/MWh increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to \$25/MWh;
- 4.3.9.46 *ITThresh1<sup>DCA</sup>* designates the price impact threshold for a *resource* in a *dynamic constrained area* as a percent increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to 50%;
- 4.3.9.47 *ITThresh2<sup>DCA</sup>* designates the price impact threshold for a *resource* in a *dynamic constrained area* as a \$/MWh increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to \$25/MWh;
- 4.3.9.48 *ITThresh1<sup>BCA</sup>* designates the price impact threshold for a *resource* in a *broad constrained area* as a percent increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to 100%;
- 4.3.9.49 *ITThresh2<sup>BCA</sup>* designates the price impact threshold for a *resource* in a *broad constrained area* as a \$/MWh increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to \$50/MWh;
- 4.3.9.50 *ITThresh1<sup>GMP</sup>* designates the global market power price impact threshold for a *resource* as a percent increase in the *energy locational marginal*

price output from section 9 above the *energy locational marginal price* output from section 13 and is equal to 100%;

- 4.3.9.51  $ITThresh2^{GMP}$  designates the global market power price impact threshold for a *resource* as a \$/MWh increase in the *energy locational marginal price* output from section 9 above the *energy locational marginal price* output from section 13 and is equal to \$50/MWh;
- 4.3.9.52  $ITThresh1^{ORG}$  designates the global market power price impact threshold for a *resource* as a percent increase in the *operating reserve locational marginal price* output from section 9 above the *operating reserve locational marginal price* output from section 13 and is equal to 50%; and
- 4.3.9.53  $ITThresh2^{ORG}$  designates the global market power price impact threshold for a *resource* as a \$/MW increase in the *operating reserve locational marginal price* output from section 9 above the *operating reserve locational marginal price* output from section 13 and is equal to \$25/MW.
- 4.3.10 Weighting Factors for Zonal Prices
- 4.3.10.1  $WF_{t,m,b}^{VIRT}$  designates the weighting factor for bus  $b \in L_m^{VIRT}$  used to calculate the price for *virtual transaction zone*  $m \in M$  for time-step  $t \in TS$  and is equal to the weighting factor used in the *day-ahead market* for the applicable hour;
- 4.3.10.2  $WF_{h,y,b}^{NDL}$  designates the weighting factor for bus  $b \in L_y^{NDL}$  used to calculate the price for *non-dispatchable load zone*  $y \in Y$  for time-step  $t \in TS$ . The weighting factors shall be obtained by renormalizing the load distribution factors so that for a given time-step the sum of weighting factors for a *non-dispatchable load zone* is equal to one.
- 4.3.11 Day-Ahead Market Scheduled Intertie Transactions
- 4.3.11.1  $SIGT_{t,d}^{DAM}$  designates the *day-ahead market* scheduled quantity of import energy for *intertie zone* source bus  $d \in DI$  in time-step  $t \in \{4, \dots, n_{LAP}\}$ ;
- 4.3.11.2  $S10NIGT_{t,d}^{DAM}$  designates the *day-ahead market* scheduled quantity of non-synchronized *ten-minute operating reserve* for *intertie zone* source bus  $d \in DI$  in time-step  $t \in \{4, \dots, n_{LAP}\}$ ;
- 4.3.11.3  $S30RIGT_{t,d}^{DAM}$  designates the *day-ahead market* scheduled quantity of *thirty-minute operating reserve* for *intertie zone* source bus  $d \in DI$  in time-step  $t \in \{4, \dots, n_{LAP}\}$ ;
- 4.3.11.4  $SXLT_{t,d}^{DAM}$  designates the *day-ahead market* scheduled quantity of export energy for *intertie zone* sink bus  $d \in DX$  in time-step  $t \in \{4, \dots, n_{LAP}\}$ ;

- 4.3.11.5  $S10NXLT_{t,d}^{DAM}$  designates the *day-ahead market* scheduled quantity of non-synchronized *ten-minute operating reserve* for *intertie zone* sink bus  $d \in DX$  in time-step  $t \in \{4, \dots, n_{LAP}\}$ ; and
- 4.3.11.6  $S30RXLT_{t,d}^{DAM}$  designates the *day-ahead market* scheduled quantity of *thirty-minute operating reserve* for *intertie zone* sink bus  $d \in DX$  in time-step  $t \in \{4, \dots, n_{LAP}\}$ .
- 4.3.12 Import Offers Without a Day-Ahead Market Schedule
- 4.3.12.1  $SIGT_{t,d}^{EXTRA}$  designates the extra quantity of *energy* for import from *intertie zone* source bus  $d \in DI$  in time-step  $t \in \{4, \dots, n_{LAP}\}$  that may be considered for the purpose of *reliability*;
- 4.3.12.2  $S10NIGT_{t,d}^{EXTRA}$  designates the extra quantity of non-synchronized *ten-minute operating reserve* for import from *intertie zone* source bus  $d \in DI$  in time-step  $t \in \{4, \dots, n_{LAP}\}$  that may be considered for the purpose of *reliability*; and
- 4.3.12.3  $S30RIGT_{t,d}^{EXTRA}$  designates the extra quantity of *thirty-minute operating reserve* for import from *intertie zone* source bus  $d \in DI$  in time-step  $t \in \{4, \dots, n_{LAP}\}$  that may be considered for the purpose of *reliability*.

## 4.4 Other Data Parameters

### 4.4.1 Non-Dispatchable Demand Forecast

- 4.4.1.1  $FL_t$  designates the total province-wide *non-dispatchable demand* forecast for time-step  $t \in TS$  calculated by the *security* assessment function.

### 4.4.2 Internal Transmission Constraints

- 4.4.2.1  $PreConSF_{t,f,b}$  designates the pre-contingency sensitivity factor for bus  $b \in BU D$  indicating the fraction of *energy* injected at bus  $b$  which flows on *facility*  $f$  during time-step  $t$  under pre-contingency conditions;
- 4.4.2.2  $AdjNormMaxFlow_{t,f}$  designates the limit corresponding to the maximum flow allowed on *facility*  $f$  in time-step  $t$  under pre-contingency conditions;
- 4.4.2.3  $SF_{t,c,f,b}$  designates the post-contingency sensitivity factor for bus  $b \in BU D$  indicating the fraction of *energy* injected at bus  $b$  which flows on *facility*  $f$  during time-step  $t$  under post-contingency conditions for contingency  $c$ , and



- 4.4.2.4 *AdjEmMaxFlow<sub>t,c,f</sub>* designates the limit corresponding to the maximum flow allowed on *facility f* in time-step *t* under post-contingency conditions for contingency *c*.
- 4.4.3 Transmission Losses
  - 4.4.3.1 *MglLoss<sub>t,b</sub>* designates the marginal loss factor and represents the marginal impact on transmission losses resulting from transmitting *energy* from the *reference bus* to serve an increment of additional load at *resource bus b*  $b \in B \cup D$  in time-step  $t \in TS$ ; and
  - 4.4.3.2 *LossAdj<sub>t</sub>* designates any adjustment needed for time-step  $t \in TS$  to correct for any discrepancy between Ontario total system losses calculated using a base case power flow from the *security* assessment function and linearized losses that would be calculated using the marginal loss factors.

## 5 Initialization

### 5.1 Purpose

- 5.1.1 The initialization processes set out in this section 5 shall occur prior to the execution of the *pre-dispatch calculation engine* described in section 2.2.1 above.

### 5.2 Reference Bus

- 5.2.1 The *IESO* shall use Richview Transformer Station as the *pre-dispatch calculation engine*'s default *reference bus* for the calculation of *locational marginal prices*.
- 5.2.2 If the default *reference bus* is out of service, another in-service bus shall be selected.

### 5.3 Islanding Conditions

- 5.3.1 In the event of a network split, the *pre-dispatch calculation engine* shall:
  - 5.3.1.1 only evaluate *resources* that are within the *main island*;
  - 5.3.1.2 use only forecasts of *demand* forecast areas in the *main island*; and
  - 5.3.1.3 use a bus within the *main island* in place of the *reference bus* if the *reference bus* does not fall within the *main island*.

## 5.4 Variable Generation Tie-Breaking

- 5.4.1 For each time-step  $t \in TS$ , each *variable generation resource* bus  $b \in B^{VG}$  and each *offer lamination*  $k \in K_{t,b}^E$ , the *offer price*  $PDG_{t,b,k}$  shall be modified to  $PDG_{t,b,k} - \left(\frac{TBM_{t,b}}{NumVG_t}\right) \rho$ , where  $\rho$  is a small nominal value of order  $10^{-4}$ .

## 5.5 Pseudo-Unit Constraints

- 5.5.1 Constraints for *pseudo-units* corresponding to minimum and maximum constraints on physical *resources* shall be determined in accordance with section 15.

## 5.6 Dispatch Data Across Two Dispatch Days

- 5.6.1 If the pre-dispatch look-ahead period spans two *dispatch days*, then the *pre-dispatch calculation engine* shall set the parameters below as follows:

- 5.6.1.1  $LNKC$ , which designates the linked *dispatchable hydroelectric generation resources* and is defined by:

$$LNKC = \begin{cases} LNK_{tod} & \text{if } DAYS = \{tod\} \\ LNK_{tom} & \text{if } DAYS = \{tod, tom\} \end{cases}.$$

- 5.6.1.2  $LagC_{b_1,b_2}$ , which designates the *time lag* between *dispatchable hydroelectric generation resources*  $(b_1,b_2) \in LNKC$  and is defined by:

$$LagC_{b_1,b_2} = \begin{cases} Lag_{tod,b_1,b_2} & \text{if } DAYS = \{tod\} \\ Lag_{tom,b_1,b_2} & \text{if } DAYS = \{tod, tom\} \end{cases}.$$

- 5.6.1.3  $MWhRatioC_{b_1,b_2}$ , which designates the *MWh ratio* for *dispatchable hydroelectric generation resources*  $(b_1,b_2) \in LNKC$  and is defined by:

$$MWhRatioC_{b_1,b_2} = \begin{cases} MWhRatio_{tod,b_1,b_2} & \text{if } DAYS = \{tod\} \\ MWhRatio_{tom,b_1,b_2} & \text{if } DAYS = \{tod, tom\} \end{cases}.$$

- 5.6.1.4  $MinQDGC_b$ , which designates the *minimum loading point* for *dispatchable generation resource*  $b \in B^{DG}$  and, subject to section 5.6.2, is defined by:

$$MinQDGC_b = \begin{cases} MinQDG_{tod,b} & \text{if } DAYS = \{tod\} \\ MinQDG_{tom,b} & \text{if } DAYS = \{tod, tom\} \end{cases}.$$

5.6.1.5  $MGBRTDGC_b$ , which designates the *minimum generation block run-time* for *non-quick start resource*  $b \in B^{NQS}$  and, subject to section 5.6.2, is defined by:

$$MGBRTDGC_b = \begin{cases} MGBRTDG_{tod,b} & \text{if } DAYS = \{tod\} \\ MGBRTDG_{tom,b} & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.1.6  $MGBDTDGC_b^m$ , which designates the *minimum generation block down-time* for *non-quick start resource*  $b \in B^{NQS}$  for *thermal state*  $m \in THERM$  and is defined by:

$$MGBDTDGC_b^m = \begin{cases} MGBDTDG_{tod,b}^m & \text{if } DAYS = \{tod\} \\ MGBDTDG_{tom,b}^m & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.1.7  $LTC_b^m$ , which designates the *lead time* for *non-quick start resource*  $b \in B^{NQS}$  for *thermal state*  $m \in THERM$  and is defined by

$$LTC_b^m = \begin{cases} LT_{tod,b}^m & \text{if } DAYS = \{tod\} \\ LT_{tom,b}^m & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.1.8  $RampHrsC_b^m$ , which designates the *ramp hours to minimum loading point* for a *non-quick start resource*  $b \in B^{NQS}$  for *thermal state*  $m \in THERM$  and is defined by:

$$RampHrsC_b^m = \begin{cases} RampHrs_{tod,b}^m & \text{if } DAYS = \{tod\} \\ RampHrs_{tom,b}^m & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.1.9  $RampEC_{b,w}^m$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ , which designates the *ramp up energy to minimum loading point* for a *non-quick start resource*  $b \in B^{NQS}$  for *thermal state*  $m \in THERM$  and is defined by:

$$RampEC_{b,w}^m = \begin{cases} RampE_{tod,b,w}^m & \text{if } DAYS = \{tod\} \\ RampE_{tom,b,w}^m & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.1.10  $RampCTC_{b,w}^m$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ , which designates the *ramp up energy to minimum loading point* for the *combustion turbine resource* associated with the *pseudo-unit* at bus  $b \in B^{PSU}$  for *thermal state*  $m \in THERM$  and is defined by:

$$RampCTC_{b,w}^m = \begin{cases} RampCT_{tod,b,w}^m & \text{if } DAYS = \{tod\} \\ RampCT_{tom,b,w}^m & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.1.11  $RampSTC_{b,w}^m$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ , which designates the *ramp up energy to minimum loading point* for the steam turbine resource's portion of the pseudo-unit at bus  $b \in B^{PSU}$  for thermal state  $m \in THERM$  and is defined by:

$$RampSTC_{b,w}^m = \begin{cases} RampST_{tod,b,w}^m & \text{if } DAYS = \{tod\} \\ RampST_{tom,b,w}^m & \text{if } DAYS = \{tod, tom\} \end{cases}$$

5.6.2 If a *non-quick start resource* receives a commitment prior to the 20:00 EST *pre-dispatch calculation engine* run but that commitment is not yet complete, then:

5.6.2.1  $MinQDG_{tod,b}$  and  $MGBRTDG_{tod,b}$  shall continue to be applied until the commitment is complete; and

5.6.2.2  $MinQDG_{tom,b}$  and  $MGBRTDG_{tom,b}$  shall be applied for any new commitments made in the 20:00 EST *pre-dispatch calculation engine* run or later.

5.6.3 For all other daily *dispatch data*, except the *single cycle mode* flag determined in section 15.5, the current day value shall be used for all *dispatch hours* in the current *dispatch day* and the next day value shall be used for all *dispatch hours* in the next *dispatch day*.

## 5.7 Start-Up Offers for Non-Quick Start Resource Advancements

5.7.1 The *pre-dispatch calculation engine* shall use *start-up offers* for *non-quick start resources* with a *day-ahead operational commitment* as follows:

5.7.1.1 If the time-step  $t$  in the set of hours preceding the start-up time  $t_{DAM} \in TSC_b$  of a *day-ahead operational commitment* in day  $q \in DAYS$  are such that  $t \in \{\max(t_{DAM} - (MGBRTDG_{q,b} + MGBDTDG_{q,b}^{HOT}), 2), \dots, t_{DAM}\}$ , then:

$$\text{If } SUDG_{t,b}^m \geq SUDG_{t,b}^{DAM}, \text{ then set } SAdjDG_{t,b}^m = SUDG_{t,b}^m$$

$$\text{If } SUDG_{t,b}^m < SUDG_{t,b}^{DAM}, \text{ then set } SAdjDG_{t,b}^m = SUDG_{t,b}^{DAM}$$

5.7.1.2 If the time-step  $t$  in the set of hours preceding the start-up time  $t_{DAM} \in TSC_b$  of a *day-ahead operational commitment* in day  $q \in DAYS$  are offers such that  $t \notin \{\max(t_{DAM} - (MGBRTDG_{q,b} + MGBDTDG_{q,b}^{HOT}), 2), \dots, t_{DAM}\}$ , then:

$$SAdjDG_{t,b}^m = SUDG_{t,b}^m$$

## 5.8 Non-Quick Start Resource First Time-Step Available to Start

5.8.1 The *pre-dispatch calculation engine* shall determine the first time-step a *non-quick start resource* can be scheduled to its *minimum loading point* as follows:

5.8.1.1 For a *non-quick start resource* at bus  $b \in B^{NQS}$  that has not been scheduled at or above its *minimum loading point* for  $InitDownHrs_b$  hours:

5.8.1.1.1 If  $0 \leq InitDownHrs_b + t - 1 \leq MGBD TDGC_b^{HOT}$ , then the *resource* cannot be scheduled to reach *minimum loading point* in time-step  $t \in TS$ ;

5.8.1.1.2 If  $InitDownHrs_b + LTC_b^{HOT} + 1 \leq MGBD TDGC_b^{WARM}$ , then a *lead time* of  $LTC_b^{HOT}$  will be applied and the *resource* can be scheduled to its *minimum loading point* in time-step  $t \in TS$  only if  $t \geq LTC_b^{HOT} + 2$ ;

5.8.1.1.3 If  $InitDownHrs_b + LTC_b^{WARM} + 1 \leq MGBD TDGC_b^{COLD}$ , then a *lead time* of  $LTC_b^{WARM}$  will be applied and the *resource* can be scheduled to its *minimum loading point* in time-step  $t \in TS$  only if  $t \geq LTC_b^{WARM} + 2$ ; and

5.8.1.1.4 If a *lead time* of  $LTC_b^{COLD}$  will be applied and the *resource* can be scheduled to its *minimum loading point* in time-step  $t \in TS$  only if  $t \geq LTC_b^{COLD} + 2$ .

## 5.9 Initial Scheduling Assumptions

5.9.1 Initial Schedules

5.9.1.1 The following parameters designate the initial *energy* schedules used for time-step 1 of the pre-dispatch look-ahead period and shall be based on the values determined by the *IESO's energy* management system for internal *resources* and the most recent *interchange schedules* for time-step 1 for *boundary entity resources*:

5.9.1.1.1  $SDL_{1,b,j}$  designates the amount of *energy* that a *dispatchable load* is scheduled to consume at bus  $b \in B^{DL}$ ;

5.9.1.1.2  $SHDR_{1,b,j}$  designates the amount of *energy* an *hourly demand response resource* is scheduled to reduce consumption at bus  $b \in B^{HDR}$ ;

- 5.9.1.1.3  $SXL_{1,d,j}$  designates the amount of *energy* a *boundary entity resource* is scheduled to export at bus  $d \in DX$ ;
- 5.9.1.1.4  $SDG_{1,b,k}$  designates the amount of *energy* that a *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{DG}$ ;
- 5.9.1.1.5  $SCT_{1,b}$  designates the schedule of the combustion turbine *resource* associated with the *pseudo-unit* at bus  $b \in B^{PSU}$ ;
- 5.9.1.1.6  $SST_{1,p}$  designates the schedule of the steam turbine *resource*  $p \in PST$ ;
- 5.9.1.1.7  $SIG_{1,d,k}$  designates the amount of *energy* that a *boundary entity resource* is scheduled to import from *intertie zone* source bus  $d \in DI$ ;

5.9.1.2 The initial schedules for *non-quick start resources* shall be determined to align with the commitment status logic described in section 5.9.2.

5.9.2 The following parameters designate initial commitment status, number of hours in operation and number of hours down for time-step 1 of the pre-dispatch look-ahead period:

5.9.2.1  $ODG_{1,b}$  designates whether the *dispatchable generation resource* at bus  $b \in B^{NQS}$  has been scheduled at or above its *minimum loading point* in time-step 1, where  $ODG_{1,b}$  shall be set to  $ODG_{2,b}$  from the previous *pre-dispatch calculation engine run* unless the *real-time calculation engine* has kept such *resource* at or above its *minimum loading point* to respect a *reliability* constraint. In such cases,  $ODG_{1,b}$  shall be determined by the *real-time calculation engine* advisory schedule;

5.9.2.2  $InitOperHrs_b$  designates the number of consecutive hours at the end of time-step 1 for which the *resource* at bus  $b \in B^{NQS}$  has been, and is anticipated to be, operating at or above its *minimum loading point*. For *resources* with  $ODG_{1,b} = 0$ ,  $InitOperHrs_b$  shall be set to zero; and

5.9.2.3  $InitDownHrs_b$  designates the number of consecutive hours at the end of time-step 1 for which the *resource* at bus  $b \in B^{NQS}$  has not been, and is not anticipated to be, operating at or above its *minimum loading point*. For *resources* with  $ODG_{1,b} = 1$ ,  $InitDownHrs_b$  shall be set to zero.

5.9.3 Initial Net Interchange Schedule

5.9.3.1 The initial net *interchange schedule* value shall be the difference between all imports to Ontario and all exports from Ontario for time-step 1. By

default, this value will be based on fixed schedules for imports and exports from the *real-time calculation engine*.

#### 5.9.4 Number of Starts for Non-Quick Start Resources

5.9.4.1  $NumStarts_b$  designates the number of starts the *resource* at bus  $b \in B^{NQS}$  has incurred in the current *dispatch day*, plus any anticipated starts in time-step 1.

#### 5.9.5 Number of Starts for Hydroelectric Resources

5.9.5.1  $NumStartsHE_b$  designates the number of starts the *resource* at bus  $b \in B^{HE}$  has incurred in the current *dispatch day*, plus any anticipated starts in time-step 1.

#### 5.9.6 Cumulative Energy Production for Energy Limited Resources and Dispatchable Hydroelectric Resources

5.9.6.1  $EngyUsed_b$  designates the *energy* already provided by the *resource* at bus  $b \in B^{ELR} \cup B^{HE}$  in the current *dispatch day*, plus the *energy* scheduled in time-step 1; and

5.9.6.2  $EngyUsedSHE_s$  designates the *energy* already provided in the current *dispatch day* by all *resources* sharing a *maximum daily energy limit* or *minimum daily energy limit* in set  $s \in SHE$  plus the *energy* scheduled in time-step 1.

#### 5.9.7 Past Hourly Production for Linked Hydroelectric Resources

5.9.7.1 For linked hydroelectric *resources*, the past hourly *energy* production of upstream *resources* shall be used to schedule downstream *resources* for time-steps in the pre-dispatch look-ahead period within the *time lag*. These past hourly production schedules shall be equal to the output determined by the *IESO's energy* management system based on real-time telemetry less any production scheduled as part of an *operating reserve* activation. For all linked hydroelectric *resources*  $(b_1, b_2) \in LNKC$  and all time-steps  $t \in TS$  such that  $t \leq LagC_{b_1, b_2}$ ,  $PastMWh_{t, b_1}$  designates the total *energy* produced by *resource*  $b_1$  exactly  $LagC_{b_1, b_2}$  hours prior to time-step  $t$ .

5.9.7.2 The schedules of downstream *resources* linked to time-step 1 upstream *resource* schedules shall be pre-determined based on the average value of the upstream *resource* advisory schedules from the last *real-time calculation engine* run that successfully completed before the *pre-dispatch calculation engine* run commenced. If the advisory schedule reflects an *operating reserve* activation for an upstream *resource*, then the schedule determined by the *real-time calculation engine* run prior to the *operating reserve* activation shall be used. For all linked hydroelectric *resources*

$(b_1, b_2) \in LNKC$  and all time-steps  $t \in TS$  such that  $t = LagC_{b_1, b_2} + 1$ ,  $PastMWh_{t, b_1}$  designates the total *energy* determined for *resource*  $b_1$  for time-step 1 to be used for scheduling downstream *resources* in time-step  $t$ .

## 6 Security Assessment Function in the Pre-Dispatch Calculation Engine

### 6.1 Interaction between the Security Assessment Function and Optimization Functions

- 6.1.1 The scheduling and pricing algorithms of the *pre-dispatch calculation engine* shall perform multiple iterations of the optimization functions and the *security* assessment function to check for violations of monitored thermal limits and operating *security limits* using the schedules produced by the optimization functions.
- 6.1.2 As multiple iterations are performed, the transmission constraints produced by the *security* assessment function shall be used by the optimization functions.
- 6.1.3 The *security* assessment function shall use the physical *resource* representation of *combined cycle plant* that are registered as *pseudo-units*.

### 6.2 Inputs into the Security Assessment Function

- 6.2.1 The *security* assessment function shall use the following inputs:
  - 6.2.1.1 the *IESO demand* forecasts; and
  - 6.2.1.2 applicable *IESO-controlled grid* information pursuant to section 3A.1 of Chapter 7.
- 6.2.2 The *security* assessment function shall also use the following outputs of the optimization functions:
  - 6.2.2.1 the schedules for *dispatchable loads* and *hourly demand response resources*;
  - 6.2.2.2 the schedules for *non-dispatchable generation resources* and *dispatchable generation resources*; and
  - 6.2.2.3 the schedules for *boundary entity resources* at each *intertie zone*.



## 6.3 Security Assessment Function Processing

6.3.1 The *security* assessment function shall determine the province-wide non-*dispatchable demand* forecast for time-step  $t$ ,  $FL_t$ , as follows:

6.3.1.1 determine forecast MW quantities for all *load resources* and losses using the *IESO demand* forecasts for *demand* forecast areas, load distribution factors, and the total of the *bid* quantities submitted for virtual *hourly demand response resources* and physical *hourly demand response resources*; and

6.3.1.2 determine  $FL_t$  by adding the forecast MW quantities determined for each *non-dispatchable load*, each *price responsive load*, and each *dispatchable load* with no *bid*, including forecast MW losses in the *demand* forecast areas.

6.3.2 The *security* assessment function shall perform the following calculations and analyses:

6.3.2.1 A base case solution function shall prepare a power flow solution for each time-step. The base case solution function shall select the power system model state applicable to the forecast of conditions for the time-step and input schedules.

6.3.2.2 The base case solution function shall use an AC power flow analysis. If the AC power flow analysis fails to converge, the base case solution function shall use a non-linear DC power flow analysis. If the non-linear DC power flow analysis fails to converge, the base case solution function shall use a linear DC power flow analysis.

6.3.2.3 If the AC or non-linear DC power flow analysis converges, continuous thermal limits for all monitored equipment and operating *security limits* shall be monitored to check for pre-contingency limit violations.

6.3.2.4 Violated pre-contingency limits shall be linearized using pre-contingency sensitivity factors and incorporated as constraints for use by the optimization functions.

6.3.2.5 If the linear DC power flow analysis is used, the pre-contingency *security* assessment may develop linear constraints to facilitate the convergence of the AC or non-linear DC power flow analysis in the subsequent iterations.

6.3.2.6 A linear power flow analysis shall be used to simulate contingencies, calculate post-contingency flows and check all monitored equipment for limited-time thermal limit violations.

- 6.3.2.7 Violated post-contingency limits shall be linearized using post-contingency sensitivity factors and incorporated as constraints for use by the optimization functions.
- 6.3.2.8 The base case solution shall be used to calculate Ontario *transmission system* losses, marginal loss factors and loss adjustment for each time-step. The impact of losses on branches between the *resource* bus and the *resource connection point* to the *IESO-controlled grid* and losses on branches outside Ontario shall be excluded when determining marginal loss factors.
- 6.3.2.9 The Pre-Dispatch Scheduling and the Reference Level Scheduling algorithms described in sections 8 and 12, respectively, shall use the marginal loss factors for each time step calculated by the *security* assessment function.
- 6.3.2.10 The Pre-Dispatch Pricing and Reference Level Pricing algorithms described in sections 9 and 13, respectively, shall use the marginal loss factors used in the last iteration of the optimization function in the corresponding scheduling algorithm.

## 6.4 Outputs from the Security Assessment Function

- 6.4.1 The outputs of the *security* assessment function used in the optimization functions include the following:
  - 6.4.1.1 a set of linearized constraints for all violated pre-contingency and post-contingency limits for each time-step. The sensitivities and limits associated with the constraints shall be those provided by the most recent *security* assessment function iteration;
  - 6.4.1.2 pre-contingency and post-contingency sensitivity factors for each time step;
  - 6.4.1.3 the marginal loss factors as described in sections 6.3.2.8 - 6.3.2.10; and
  - 6.4.1.4 loss adjustment quantity for each time-step.

# 7 Pass 1: Pre-Dispatch Scheduling Process

7.1.1 Pass 1 shall use *market participant* and *IESO* inputs and *resource* and system constraints to determine a set of *resource* schedules, commitments and *locational marginal prices*. Pass 1 shall consist of the following algorithms and tests:

- the Pre-Dispatch Scheduling algorithm described in section 8;
- the Pre-Dispatch Pricing algorithm described in section 9;
- the Constrained Area Conditions Test described in section 10;
- the Conduct Test described in section 11;
- the Reference Level Scheduling algorithm described in section 12;
- the Reference Level Pricing algorithm described in section 13; and
- the Price Impact Test described in section 14.

## 8 Pre-Dispatch Scheduling

### 8.1 Purpose

8.1.1 The Pre-Dispatch Scheduling algorithm shall perform a *security*-constrained unit commitment and economic *dispatch* to maximize gains from trade using *dispatch data* submitted by *registered market participants*, subject to section 14.7.1.3, to meet the *IESO's* province-wide non-*dispatchable demand* forecast and *IESO*-specified *operating reserve* requirements for each hour of the pre-dispatch look-ahead period.

### 8.2 Information, Sets, Indices and Parameters

8.2.1 Information, sets, indices and parameters used by the Pre-Dispatch Scheduling algorithm are described in sections 3 and 4.

### 8.3 Variables and Objective Function

8.3.1 The Pre-Dispatch Scheduling algorithm shall solve for the following variables:

- 8.3.1.1  $SDL_{t,b,j}$ , which designates the amount of *energy* that a *dispatchable load* is scheduled to consume at bus  $b \in B^{DL}$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,b}^E$ ;
- 8.3.1.2  $S10SDL_{t,b,j}$ , which designates the amount of synchronized *ten-minute operating reserve* that a *dispatchable load* is scheduled to provide at bus  $b \in B^{DL}$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,b}^{10S}$ ;
- 8.3.1.3  $S10NDL_{t,b,j}$ , which designates the amount of non-synchronized *ten-minute operating reserve* that a *dispatchable load* is scheduled to provide at bus  $b \in B^{DL}$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,b}^{10N}$ ;
- 8.3.1.4  $S30RDL_{t,b,j}$ , which designates the amount of *thirty-minute operating reserve* that a *dispatchable load* is scheduled to provide at bus  $b \in B^{DL}$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,b}^{30R}$ ;
- 8.3.1.5  $SHDR_{t,b,j}$ , which designates the amount of *energy* reduction scheduled for an *hourly demand response resource* at bus  $b \in B^{HDR}$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,b}^E$ ;
- 8.3.1.6  $SXL_{t,d,j}$ , which designates the amount of *energy* a *boundary entity resource* is scheduled to export at bus  $d \in DX$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,d}^E$ ;
- 8.3.1.7  $S10NXL_{t,d,j}$ , which designates the amount of non-synchronized *ten-minute operating reserve* that a *boundary entity resource* is scheduled to provide at bus  $d \in DX$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,d}^{10N}$ ;
- 8.3.1.8  $S30RXL_{t,d,j}$ , which designates the amount of *thirty-minute operating reserve* that a *boundary entity resource* is scheduled to provide at bus  $d \in DX$  in time-step  $t \in TS$  in association with lamination  $j \in J_{t,d}^{30R}$ ;
- 8.3.1.9  $SNDG_{t,b,k}$ , which designates the amount of *energy* that a *non-dispatchable generation resource* is scheduled to provide at bus  $b \in B^{NDG}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^E$ ;
- 8.3.1.10  $SDG_{t,b,k}$ , which designates the amount of *energy* that a *dispatchable generation resource* is scheduled to provide above  $MinQDGC_b$  at bus  $b \in B^{DG}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^E$ ;
- 8.3.1.11  $ODG_{t,b}$ , which designates whether the *dispatchable generation resource* at bus  $b \in B^{DG}$  has been scheduled at or above its *minimum loading point* in time-step  $t \in TS$ ;

- 8.3.1.12  $IDG_{t,b}$ , which designates whether the *dispatchable generation resource* at bus  $b \in B^{DG}$  has been scheduled to reach its *minimum loading point* in time-step  $t \in TS$ ;
- 8.3.1.13  $S10SDG_{t,b,k}$ , which designates the amount of *synchronized ten-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{DG}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{10S}$ ;
- 8.3.1.14  $S10NDG_{t,b,k}$ , which designates the amount of *non-synchronized ten-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{DG}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{10N}$ ;
- 8.3.1.15  $S30RDG_{t,b,k}$ , which designates the amount of *thirty-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{DG}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{30R}$ ;
- 8.3.1.16  $SCT_{t,b}$ , which designates the schedule of the *combustion turbine resource* associated with the *pseudo-unit* at bus  $b \in B^{PSU}$  in time-step  $t \in TS$ ;
- 8.3.1.17  $SST_{t,p}$ , which designates the schedule of *steam turbine resource*  $p \in PST$  in time-step  $t \in TS$ ;
- 8.3.1.18  $O10R_{t,b}$ , which designates whether the *pseudo-unit* at bus  $b \in B^{NO10DF}$  has been scheduled for *ten-minute operating reserve* in time-step  $t \in TS$ ;
- 8.3.1.19  $OHO_{t,b}$ , which designates whether the *dispatchable hydroelectric generation resource* at bus  $b \in B^{HE}$  has been scheduled at or above  $MinHO_{t,b}$  in time-step  $t \in TS$ ;
- 8.3.1.20  $OFR_{t,b,i}$  for  $i \in \{1, \dots, NFor_{q,b}\}$ , which designates whether the *dispatchable hydroelectric generation resource* at bus  $b \in B^{HE}$  has been scheduled at or below  $ForL_{q,b,i}$ , or, at or above  $ForU_{q,b,i}$  in time-step  $t \in TS$ ;
- 8.3.1.21  $IHE_{t,b,i}$ , which designates whether the *dispatchable hydroelectric generation resource* at bus  $b \in B^{HE}$  registered a start between time-step  $(t-1)$  and  $t$  as a result of its schedule increasing from below  $StartMW_{b,i}$  to at or above  $StartMW_{b,i}$  for  $i \in \{1, \dots, NStartMW_b\}$ ;
- 8.3.1.22  $SIG_{t,d,k}$ , which designates the amount of *energy* that a *boundary entity resource* is scheduled to import from *intertie zone* source bus  $d \in DI$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,d}^E$ ;

- 8.3.1.23  $S10NIG_{t,d,k}$ , which designates the amount of non-synchronized *ten-minute operating reserve* that a *boundary entity resource* is scheduled to provide from *intertie zone* source bus  $d \in DI$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,d}^{10N}$ ;
- 8.3.1.24  $S30RIG_{t,d,k}$ , which designates the amount of *thirty-minute operating reserve* that a *boundary entity resource* is scheduled to provide from *intertie zone* source bus  $d \in DI$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,d}^{30R}$ ;
- 8.3.1.25  $TB_t$ , which designates any adjustment to the objective function to facilitate pro-rata tie-breaking in time-step  $t \in TS$ , as described in section 8.3.2.1; and
- 8.3.1.26  $ViolCost_t$ , which designates the cost incurred in order to avoid having the schedules violate constraints in time-step  $t \in TS$ , as described in section 8.3.2.3.

8.3.2 The objective function for the Pre-Dispatch Scheduling algorithm shall maximize gains from trade by maximizing the following expression:

$$\sum_{t \in TS} \left( ObjDL_t - ObjHDR_t + ObjXL_t - ObjNDG_t - ObjDG_t - ObjIG_t - TB_t - ViolCost_t \right)$$

where:

$$ObjDL_t = \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^E} SDL_{t,b,j} \cdot PDL_{t,b,j} - \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \cdot P10SDL_{t,b,j} - \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \cdot P10NDL_{t,b,j} - \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \cdot P30RDL_{t,b,j} \right);$$

$$ObjHDR_t = \sum_{b \in B^{HDR}} \left( \sum_{j \in J_{t,b}^E} SHDR_{t,b,j} \cdot PHDR_{t,b,j} \right);$$

$$ObjXL_t = \sum_{d \in DX} \left( \sum_{j \in J_{t,d}^E} SXL_{t,d,j} \cdot PXL_{t,d,j} - \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \cdot P10NXL_{t,d,j} - \sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \cdot P30RXL_{t,d,j} \right);$$

$$ObjNDG_t = \sum_{b \in B^{NDG}} \left( \sum_{k \in K_{t,b}^E} SNDG_{t,b,k} \cdot PNDG_{t,b,k} \right);$$

$$ObjDG_t = \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \cdot PDG_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \cdot P10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \cdot P10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \cdot P30RDG_{t,b,k} \right) + \sum_{b \in B^{NQS}} (ODG_{t,b} \cdot MGODG_{t,b} + IDG_{t,b} \cdot SUAdjDG_{t,b}^{T,b});$$

and

$$ObjIG_t = \sum_{d \in DI} \left( \sum_{k \in K_{t,d}^E} SIG_{t,d,k} \cdot PIG_{t,d,k} + \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \cdot P10NIG_{t,d,k} + \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \cdot P30RIG_{t,d,k} \right).$$

- 8.3.2.1 The tie-breaking term  $TB_t$  shall sum a term for each *bid* or *offer* lamination. For each lamination, this term shall be the product of a small penalty cost and the quantity of the lamination scheduled. The penalty cost shall be calculated by multiplying a base penalty cost of  $TBPen$  by the amount of the lamination scheduled and then dividing by the maximum amount that could have been scheduled. That is:

$$TB_t = TBDL_t + TBHDR_t + TBXL_t + TBNDG_t + TBDG_t + TBIG_t$$

Where

$$TBDL_t = \sum_{b \in B^{DL}} \left( \sum_{j \in I_{t,b}^E} \left( \frac{(SDL_{t,b,j})^2 \cdot TBPen}{QDL_{t,b,j}} \right) + \sum_{j \in I_{t,b}^{10S}} \left( \frac{(S10SDL_{t,b,j})^2 \cdot TBPen}{Q10SDL_{t,b,j}} \right) + \sum_{j \in I_{t,b}^{10N}} \left( \frac{(S10NDL_{t,b,j})^2 \cdot TBPen}{Q10NDL_{t,b,j}} \right) + \sum_{j \in I_{t,b}^{30R}} \left( \frac{(S30RDL_{t,b,j})^2 \cdot TBPen}{Q30RDL_{t,b,j}} \right) \right);$$

$$TBHDR_t = \sum_{b \in B^{HDR}} \left( \sum_{j \in I_{t,b}^E} \left( \frac{(SHDR_{t,b,j})^2 \cdot TBPen}{QHDR_{t,b,j}} \right) \right);$$

$$TBXL_t = \sum_{d \in DX} \left( \sum_{j \in I_{t,d}^E} \left( \frac{(SXL_{t,d,j})^2 \cdot TBPen}{QXL_{t,d,j}} \right) + \sum_{j \in I_{t,d}^{10N}} \left( \frac{(S10NXL_{t,d,j})^2 \cdot TBPen}{Q10NXL_{t,d,j}} \right) + \sum_{j \in I_{t,d}^{30R}} \left( \frac{(S30RXL_{t,d,j})^2 \cdot TBPen}{Q30RXL_{t,d,j}} \right) \right);$$

$$TBNDG_t = \sum_{b \in B^{NDG}} \left( \sum_{k \in K_{t,b}^E} \left( \frac{(SNDG_{t,b,k})^2 \cdot TBPen}{QNDG_{t,b,k}} \right) \right);$$

$$TBDG_t = \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^E} \left( \frac{(SDG_{t,b,k})^2 \cdot TBPen}{QDG_{t,b,k}} \right) + \sum_{k \in K_{t,b}^{10S}} \left( \frac{(S10SDG_{t,b,k})^2 \cdot TBPen}{Q10SDG_{t,b,k}} \right) + \sum_{k \in K_{t,b}^{10N}} \left( \frac{(S10NDG_{t,b,k})^2 \cdot TBPen}{Q10NDG_{t,b,k}} \right) + \sum_{k \in K_{t,b}^{30R}} \left( \frac{(S30RDG_{t,b,k})^2 \cdot TBPen}{Q30RDG_{t,b,k}} \right) \right);$$

and

$$TBIG_t = \sum_{d \in DI} \left( \sum_{k \in K_{t,d}^E} \left( \frac{(SIG_{t,d,k})^2 \cdot TBPen}{QIG_{t,d,k}} \right) + \sum_{k \in K_{t,d}^{10N}} \left( \frac{(S10NIG_{t,d,k})^2 \cdot TBPen}{Q10NIG_{t,d,k}} \right) + \sum_{k \in K_{t,d}^{30R}} \left( \frac{(S30RIG_{t,d,k})^2 \cdot TBPen}{Q30RIG_{t,d,k}} \right) \right).$$

8.3.2.2  $ViolCost_t$  shall be calculated for time-step  $t \in TS$  using the following variables:

8.3.2.2.1  $SLdViol_{t,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{LdViol_t}\}$  of the penalty curve for the energy balance constraint allowing under-generation;



- 8.3.2.2.2  $S_{GenViol_{t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{GenViol_t}\}$  of the penalty curve for the *energy* balance constraint allowing over-generation;
- 8.3.2.2.3  $S_{10SViol_{t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{10SViol_t}\}$  of the penalty curve for the synchronized *ten-minute operating reserve* requirement;
- 8.3.2.2.4  $S_{10RViol_{t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{10RViol_t}\}$  of the penalty curve for the total *ten-minute operating reserve* requirement;
- 8.3.2.2.5  $S_{30RViol_{t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{30RViol_t}\}$  of the penalty curve for the *thirty-minute operating reserve* requirement and, when applicable, the *flexibility operating reserve* requirement;
- 8.3.2.2.6  $S_{REG10RViol_{r,t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{REG10RViol_t}\}$  of the penalty curve for violating the area total *ten-minute operating reserve* minimum requirement in region  $r \in ORREG$ ;
- 8.3.2.2.7  $S_{REG30RViol_{r,t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{REG30RViol_t}\}$  of the penalty curve for violating the area *thirty-minute operating reserve* minimum requirement in region  $r \in ORREG$ ;
- 8.3.2.2.8  $S_{XREG10RViol_{r,t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{XREG10RViol_t}\}$  of the penalty curve for violating the area total *ten-minute operating reserve* maximum restriction in region  $r \in ORREG$ ;
- 8.3.2.2.9  $S_{XREG30RViol_{r,t,i}}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{XREG30RViol_t}\}$  of the penalty curve for violating the area *thirty-minute operating reserve* maximum restriction in region  $r \in ORREG$ ;
- 8.3.2.2.10  $S_{PreITLViol_{f,t,i}}$ , which designates the violation variable affiliated with segment  $I \in \{1, \dots, N_{PreITLViol_{f,t}}\}$  of the penalty curve for violating the pre-contingency transmission limit for *facility*  $f \in F$ ;

- 8.3.2.2.11  $SITLViol_{c,f,t,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{ITLViol_{c,f,t}}\}$  of the penalty curve for violating the post-contingency transmission limit for facility  $f \in F$  and contingency  $c \in C$ ;
- 8.3.2.2.12  $SPreXTLViol_{z,t,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{PreXTLViol_{z,t}}\}$  of the penalty curve for violating the import/export limit affiliated with *intertie* limit constraint  $z \in Z_{Sch}$ ;
- 8.3.2.2.13  $SNIUViol_{t,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{NIUViol_t}\}$  of the penalty curve for exceeding the net interchange increase limit between time-steps  $(t-1)$  and  $t$ ;
- 8.3.2.2.14  $SNIDViol_{t,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{NIDViol_t}\}$  of the penalty curve for exceeding the net interchange decrease limit between time-steps  $(t-1)$  and  $t$ ;
- 8.3.2.2.15  $SMaxDelViol_{t,b,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{MaxDelViol_t}\}$  of the penalty curve for exceeding the *maximum daily energy limit* constraint for a *resource* at bus  $b \in B^{ELR}$ ;
- 8.3.2.2.16  $SMinDelViol_{t,b,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{MinDelViol_t}\}$  of the penalty curve for violating the *minimum daily energy limit* constraint for a *resource* at bus  $b \in B^{HE}$ ;
- 8.3.2.2.17  $SSMaxDelViol_{t,s,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{SSMaxDelViol_t}\}$  of the penalty curve for exceeding the shared *maximum daily energy limit* constraint for *dispatchable* hydroelectric generation resources in set  $s \in SHE$ ;
- 8.3.2.2.18  $SSMinDelViol_{t,s,i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{SSMinDelViol_t}\}$  of the penalty curve for violating the shared *minimum daily energy limit* constraint for *dispatchable* hydroelectric generation resources in set  $s \in SHE$ ;
- 8.3.2.2.19  $SGenLnkViol_{t,(b_1,b_2),i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{0GenLnkViol_t}\}$  of the

penalty curve for violating the linked *dispatchable hydroelectric generation resources* constraint by over-generating the downstream *resource*, for  $(b_1, b_2) \in LNK$  such that  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$ ; and

8.3.2.2.20  $SUGenLnkViol_{t,(b_1,b_2),i}$ , which designates the violation variable affiliated with segment  $i \in \{1, \dots, N_{UGenLnkViol_t}\}$  of the penalty curve for violating the linked *dispatchable hydroelectric generation resources* constraint by under-generating the downstream *resource*, for  $(b_1, b_2) \in LNK$  such that  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$ .

8.3.2.3  $ViolCost_t$  shall be calculated as follows:

$$\begin{aligned}
 ViolCost_t = & \sum_{i=1..N_{LdViol_t}} SLdViol_{t,i} \cdot PLdViolSch_{t,i} - \\
 & \sum_{i=1..N_{GenViol_t}} SGenViol_{t,i} \cdot PGenViolSch_{t,i} + \sum_{i=1..N_{10SViol_t}} S10SViol_{t,i} \cdot P10SViolSch_{t,i} + \\
 & \sum_{i=1..N_{10RViol_t}} S10RViol_{t,i} \cdot P10RViolSch_{t,i} + \sum_{i=1..N_{30RViol_t}} S30RViol_{t,i} \cdot P30RViolSch_{t,i} + \\
 & \sum_{r \in ORREG} \left( \sum_{i=1..N_{REG10RViol_t}} SREG10RViol_{r,t,i} \cdot PREG10RViolSch_{t,i} \right) + \\
 & \sum_{r \in ORREG} \left( \sum_{i=1..N_{REG30RViol_t}} SREG30RViol_{r,t,i} \cdot PREG30RViolSch_{t,i} \right) + \\
 & \sum_{r \in ORREG} \left( \sum_{i=1..N_{XREG10RViol_t}} SXREG10RViol_{r,t,i} \cdot PXREG10RViolSch_{t,i} \right) + \\
 & \sum_{r \in ORREG} \left( \sum_{i=1..N_{XREG30RViol_t}} SXREG30RViol_{r,t,i} \cdot PXREG30RViolSch_{t,i} \right) + \dots
 \end{aligned}$$

$$\begin{aligned}
& + \sum_{f \in F_t} \left( \sum_{i=1..N_{PreITLViol_{f,t}}} SP_{PreITLViol_{f,t,i}} \cdot PP_{PreITLViol_{f,t,i}} \right) \\
& + \sum_{c \in C} \sum_{f \in F_{t,c}} \left( \sum_{i=1..N_{ITLViol_{c,f,t}}} SITL_{Viol_{c,f,t,i}} \cdot PITL_{Viol_{c,f,t,i}} \right) \\
& + \sum_{z \in Z_{Sch}} \left( \sum_{i=1..N_{PreXTLViol_{z,t}}} SPre_{XTLViol_{z,t,i}} \cdot PPre_{XTLViol_{z,t,i}} \right) \\
& + \sum_{i=1..N_{NIUViol_t}} SNIUViol_{t,i} \cdot PNIUViol_{t,i} + \sum_{i=1..N_{NIDViol_t}} SNIDViol_{t,i} \cdot PNIDViol_{t,i} \\
& + \sum_{b \in B^{LR}} \left( \sum_{i=1..N_{MaxDelViol_t}} SMaxDelViol_{t,b,i} \cdot PMaxDelViol_{t,b,i} \right) \\
& + \sum_{b \in B^{HE}} \left( \sum_{i=1..N_{MinDelViol_t}} SMinDelViol_{t,b,i} \cdot PMinDelViol_{t,b,i} \right) \\
& + \sum_{s \in SHE} \left( \sum_{i=1..N_{SMaxDelViol_t}} SSMaxDelViol_{t,s,i} \cdot PSSMaxDelViol_{t,s,i} \right) \\
& + \sum_{s \in SHE} \left( \sum_{i=1..N_{SMinDelViol_t}} SSMinDelViol_{t,s,i} \cdot PSSMinDelViol_{t,s,i} \right) \\
& + \sum_{(b_1, b_2) \in LNK} \left( \sum_{i=1..N_t} SOGenLnkViol_{t,(b_1, b_2),i} \cdot POGenLnkViol_{t,i} \right) / \\
& + \sum_{(b_1, b_2) \in LNK} \left( \sum_{i=1..N_t} SUGenLnkViol_{t,(b_1, b_2),i} \cdot PUGenLnkViol_{t,i} \right).
\end{aligned}$$

## 8.4 Constraints

8.4.1 The constraints described in sections 8.5 – 8.7 apply to the optimization function in the Pre-Dispatch Scheduling algorithm.

## 8.5 Dispatch Data Constraints Applying to Individual Hours

8.5.1 Scheduling Variable Bounds

8.5.1.1 A Boolean variable  $ODG_{t,b}$  indicates whether the *resource* at bus  $b \in B^{DG}$  is committed in time-step  $t \in TS$ . A value of zero indicates that a *resource* is not committed, while a value of one indicates that it is committed. Therefore:

$$ODG_{t,b} \in \{0,1\} \text{ for all time-steps } t \in TS \text{ and all buses } b \in B^{DG}.$$

8.5.1.2 *Reliability must-run resources* are considered committed for all must-run hours.

8.5.1.3 *Resources providing regulation* are considered committed for all the hours that they are regulating.

8.5.1.4 *Dispatchable generation resources* that have *minimum loading points*, *start-up offers*, *speed no-load offers*, *minimum generation block run-times* and *minimum generation block down-times* equal to zero shall be considered committed for all hours.

8.5.1.5 If the *dispatchable generation resource* at bus  $b \in B^{DG}$  is considered committed according to the requirements in sections 8.5.1.2, 8.5.1.3, and 8.5.1.4 in time-step  $t \in TS$  then:

$$ODG_{t,b} = 1$$

8.5.1.6 No schedule shall be negative, nor shall any schedule exceed the quantity *offered* for the respective *energy* and *operating reserve* market. Therefore:

$$\begin{aligned}
0 \leq SDL_{t,b,j} &\leq QDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^E; \\
0 \leq S10SDL_{t,b,j} &\leq Q10SDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^{10S}; \\
0 \leq S10NDL_{t,b,j} &\leq Q10NDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^{10N}; \\
0 \leq S30RDL_{t,b,j} &\leq Q30RDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^{30R}; \\
0 \leq SHDR_{t,b,j} &\leq QHDR_{t,b,j} && \text{for all } b \in B^{HDR}, j \in \mathcal{J}_{t,b}^E; \\
0 \leq SXL_{t,d,j} &\leq QXL_{t,d,j} && \text{for all } d \in DX, j \in \mathcal{J}_{t,d}^E; \\
0 \leq S10NXL_{t,d,j} &\leq Q10NXL_{t,d,j} && \text{for all } d \in DX, j \in \mathcal{J}_{t,d}^{10N}; \\
0 \leq S30RXL_{t,d,j} &\leq Q30RXL_{t,d,j} && \text{for all } d \in DX, j \in \mathcal{J}_{t,d}^{30R}; \\
0 \leq SNDG_{t,b,k} &\leq QNDG_{t,b,k} && \text{for all } b \in B^{NDG}, k \in K_{t,b}^E; \\
0 \leq SIG_{t,d,k} &\leq QIG_{t,d,k} && \text{for all } d \in DI, k \in K_{t,d}^E; \\
0 \leq S10NIG_{t,d,k} &\leq Q10NIG_{t,d,k} && \text{for all } d \in DI, k \in K_{t,d}^{10N}; \text{ and} \\
0 \leq S30RIG_{t,d,k} &\leq Q30RIG_{t,d,k} && \text{for all } d \in DI, k \in K_{t,d}^{30R} \\
\end{aligned}$$

for all time-steps  $t \in TS$ .

8.5.1.7 *Generation resources* may be scheduled for *energy* and/or *operating reserve* only if their commitment status is equal to 1. Therefore, for all time-steps  $t \in TS$ :

$$\begin{aligned}
0 \leq SDG_{t,b,k} &\leq ODG_{t,b} \cdot QDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^E; \\
0 \leq S10SDG_{t,b,k} &\leq ODG_{t,b} \cdot Q10SDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^{10S}; \\
0 \leq S10NDG_{t,b,k} &\leq ODG_{t,b} \cdot Q10NDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^{10N}; \\
\text{and} \\
0 \leq S30RDG_{t,b,k} &\leq ODG_{t,b} \cdot Q30RDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^{30R}.
\end{aligned}$$

## 8.5.2 Resource Minimums and Maximums for Energy

8.5.2.1 A constraint shall limit schedules for *dispatchable loads* within their minimum and maximum consumption for a time-step. For all time-steps  $t \in TS$  and all buses  $b \in B^{DL}$ :

$$MinDL_{t,b} \leq \sum_{j \in J_{t,b}^E} SDL_{t,b,j} \leq MaxDL_{t,b}$$

8.5.2.2 The non-*dispatchable* portion of a *dispatchable load* shall always be scheduled. For all time-steps  $t \in TS$  and all buses  $b \in B^{DL}$ :

$$\sum_{j \in J_{t,b}^E} SDL_{t,b,j} \geq QDLFIRM_{t,b}$$

8.5.2.3 A constraint shall limit schedules for *non-dispatchable generation resources* within their minimum and maximum output for a time-step. For all time-steps  $t \in TS$  and all buses  $b \in B^{NDG}$ :

$$MinNDG_{t,b} \leq \sum_{k \in K_{t,b}^E} SNDG_{t,b,k} \leq MaxNDG_{t,b}$$

8.5.2.4 A constraint shall limit schedules for *dispatchable generation resources* within their minimum and maximum output for a time-step. For a *dispatchable variable generation resource*, the maximum schedule shall be limited by its forecast. That is:

For all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ ,

$$AdjMaxDG_{t,b} = \begin{cases} \text{Min}(MaxDG_{t,b}, FG_{t,b}) & \text{if } b \in B^{VG} \\ MaxDG_{t,b} & \text{otherwise} \end{cases}$$

and

$$AdjMinDG_{t,b} = \text{Min}(MinDG_{t,b}, AdjMaxDG_{t,b}).$$

For all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ :

$$AdjMinDG_{t,b} \leq MinQDGC_b \cdot ODG_{t,b} + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq AdjMaxDG_{t,b}$$

8.5.2.5 If the commitment status,  $ODG_{t,b}$ , of a *dispatchable generation resource* is equal to 1 and if this status is inconsistent with the adjusted minimum and maximum constraints,  $MinQDGC_b > AdjMaxDG_{t,b}$ , then the commitment status value,  $ODG_{t,b}$ , shall be changed to a value between 0 and 1.

8.5.2.6 If the total *offered* quantity does not exceed the minimum,  $MinQDGC_b + \sum_{k \in K_{t,b}^E} QDG_{t,b,k} < AdjMinDG_{t,b}$ , then the *resource* shall receive a schedule of zero.

8.5.2.7 Minimum and maximum limits placed on *hourly demand response resource* schedules for the purposes of reflecting activation/non-activation decisions shall be respected. For all time-steps  $t \in TS$  and all buses  $b \in B^{HDR}$ :

$$MinHDR_{t,b} \leq \sum_{j \in J_{t,b}^E} SHDR_{t,b,j} \leq MaxHDR_{t,b}$$

### 8.5.3 Off-Market Transactions

8.5.3.1 For all time-steps  $t \in TS$  and all *intertie zone* buses corresponding to an inadvertent *energy* payback export transaction  $d \in DX_t^{INP}$ :

$$\sum_{j \in J_{t,d}^E} SXL_{t,d,j} = \sum_{j \in J_{t,d}^E} QXL_{t,d,j}$$

8.5.3.2 For all time-steps  $t \in TS$  and all *intertie zone* buses corresponding to an inadvertent *energy* payback import transaction  $d \in DI_t^{INP}$ :

$$\sum_{k \in K_{t,d}^E} SIG_{t,d,k} = \sum_{k \in K_{t,d}^E} QIG_{t,d,k}$$

8.5.3.3 For all time-steps  $t \in TS$  and all *intertie zone* buses corresponding to an *emergency energy* export  $d \in DX_t^{EM}$ :

$$\sum_{j \in J_{t,d}^E} SXL_{t,d,j} = \sum_{j \in J_{t,d}^E} QXL_{t,d,j}$$

8.5.3.4 For all time-steps  $t \in TS$  and all *intertie zone* buses corresponding to *emergency energy* import  $d \in DI_t^{EM}$ :

$$\sum_{k \in K_{t,d}^E} SIG_{t,d,k} = \sum_{k \in K_{t,d}^E} QIG_{t,d,k}$$

### 8.5.4 Intertie Minimum and Maximum Constraints



- 8.5.4.1 A constraint shall limit export schedules beyond the first two forecast hours of the pre-dispatch look-ahead period to the corresponding *day-ahead market* schedules for export transactions, subject to Chapter 7, section 5.2.2. For time-step  $t \in \{4, \dots, n_{LAP}\}$  and *intertie zone* sink bus  $d \in DX$  such that  $d \notin DX_t^{CAPEX} \cup DX_t^{EM} \cup DX_t^{INP}$ :

$$\sum_{j \in J_{t,d}^E} SXL_{t,d,j} \leq SXL T_{t,d}^{DAM};$$

$$\sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \leq S10NXL T_{t,d}^{DAM};$$

and

$$\sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \leq S30RXL T_{t,d}^{DAM}.$$

- 8.5.4.2 Import *offers* with no *day-ahead market* schedule may be evaluated beyond the first two forecast hours of the look-ahead period for the purpose of *reliability*.

- 8.5.4.3 A constraint shall limit import schedules beyond the first two forecast hours of the pre-dispatch look-ahead period to the corresponding *day-ahead market* schedules for import transactions plus any additional *offered* quantities permitted for *reliability* reasons, with the exception of transactions flagged as capacity imports or off-market transactions, subject to Chapter 7, section 5.2.2. For time-step  $t \in \{4, \dots, n_{LAP}\}$  and *intertie zone* source bus  $d \in DI$  such that  $d \notin DI_t^{CAPEX} \cup DI_t^{EM} \cup DI_t^{INP}$ :

$$\sum_{k \in K_{t,d}^B} SIG_{t,d,k} \leq SIG T_{t,d}^{DAM} + SIG T_{t,d}^{EXTRA};$$

$$\sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \leq S10NIG T_{t,d}^{DAM} + S10NIG T_{t,d}^{EXTRA};$$

and

$$\sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \leq S30RIG T_{t,d}^{DAM} + S30RIG T_{t,d}^{EXTRA}.$$

- 8.5.4.4 A constraint shall limit *intertie* schedules as a result of *intertie* curtailments. For *intertie zone* sink bus  $d \in DX$  and time-step  $t \in TS$ :

$$ICMinXL_{t,d} \leq \sum_{j \in J_{t,d}^E} SXL_{t,d,j} \leq ICMaXL_{t,d}$$

8.5.4.4.1 For *intertie zone* source bus  $d \in DI$  and time-step  $t \in TS$ :

$$ICMinIG_{t,d} \leq \sum_{k \in K_{t,d}^E} SIG_{t,d,k} \leq ICMaIG_{t,d}$$

$$ICMin10NIG_{t,d} \leq \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \leq ICMa10NIG_{t,d}$$

and

$$ICMin30RIG_{t,d} \leq \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \leq ICMa30RIG_{t,d}$$

## 8.5.5 Operating Reserve Requirements

8.5.5.1 The total synchronized *ten-minute operating reserve*, non-synchronized *ten-minute operating reserve* and *thirty-minute operating reserve* scheduled from a *dispatchable load* shall not exceed:

8.5.5.1.1 the *dispatchable load's* ramp capability over 30 minutes;

8.5.5.1.2 the total scheduled load less the non-*dispatchable* portion;  
and

8.5.5.1.3 the remaining portion of its capacity that is *dispatchable* after considering minimum load consumption constraints.

8.5.5.1.4 These restrictions shall be enforced by the following constraints for all time-steps  $t \in TS$  and all buses  $b \in B^{DL}$ :

$$\sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} + \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} + \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \leq 30 \cdot ORRDL_b;$$

$$\sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} + \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} + \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \leq \sum_{j \in J_{t,b}^E} SDL_{t,b,j} - QDLFIRM_{t,b};$$

and

$$\sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} + \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} + \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \leq \sum_{j \in J_{t,b}^E} SDL_{t,b,j} - MinDL_{t,b}$$

8.5.5.2 The amount of both synchronized and non-synchronized *ten-minute operating reserve* that a *dispatchable load* is scheduled to provide shall

not exceed the amount by which the *dispatchable load* can decrease its load over 10 minutes, as limited by its *operating reserve* ramp rate. This restriction shall be enforced by the following constraint for all time-steps  $t \in TS$  and all buses  $b \in B^{DL}$ :

$$\sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} + \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \leq 10 \cdot ORRD L_b$$

- 8.5.5.3 The total non-synchronized *ten-minute operating reserve* and *thirty-minute operating reserve* scheduled for an hour shall not exceed total scheduled exports. This restriction shall be enforced by the following constraint for all all time-steps  $t \in TS$  and all *intertie zone sink buses*  $d \in DX$ :

$$\sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} + \sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \leq \sum_{j \in J_{t,d}^E} SXL_{t,d,j}$$

- 8.5.5.4 The total *operating reserve* scheduled from a committed *dispatchable generation resource* shall not exceed that *resource*'s: (i) ramp capability over 30 minutes; (ii) remaining capacity; and (iii) unscheduled capacity. These restrictions shall be enforced by the following constraints for all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ :

$$\sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \leq 30 \cdot ORRD G_b;$$

$$\sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \leq \sum_{k \in K_{t,b}^E} (QDG_{t,b,k} - SDG_{t,b,k});$$

and

$$\sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \leq AdjMaxDG_{t,b} - \sum_{k \in K_{t,b}^E} SDG_{t,b,k} - MinQDGC_b$$

- 8.5.5.5 The amount of both synchronized and non-synchronized *ten-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide shall not exceed the amount by which the *resource* can increase its output over 10 minutes, as limited by its *operating reserve* ramp rate. This restriction shall be enforced by the following constraint for all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ :

$$\sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \leq 10 \cdot ORRDG_b.$$

- 8.5.5.6 The amount of synchronized *ten-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide shall be limited by its *reserve loading point for synchronized ten-minute operating reserve*. This restriction shall be enforced by the following constraint for all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$  with  $RLP10S_{t,b} > 0$ :

$$\begin{aligned} \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} &\leq \left( MinQDGC_b \cdot ODG_{t,b} + \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \right) \cdot \left( \frac{1}{RLP10S_{t,b}} \right) \\ &\cdot \left( \min \left\{ 10 \cdot ORRDG_b, \sum_{k \in K_{t,b}^{10S}} Q10SDG_{t,b,k} \right\} \right). \end{aligned}$$

- 8.5.5.7 The amount of *thirty-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide shall be limited by its *reserve loading point for thirty-minute operating reserve*. This restriction shall be enforced by the following constraint for all all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$  with  $RLP30R_{t,b} > 0$ :

$$\begin{aligned} \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} &\leq \left( MinQDGC_b \cdot ODG_{t,b} + \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \right) \cdot \left( \frac{1}{RLP30R_{t,b}} \right) \\ &\cdot \left( \min \left\{ 30 \cdot ORRDG_b, \sum_{k \in K_{t,b}^{30R}} Q30RDG_{t,b,k} \right\} \right). \end{aligned}$$

- 8.5.5.8 The total non-synchronized *ten-minute operating reserve* and *thirty-minute operating reserve* scheduled for an hour shall not exceed the remaining maximum import *offers* minus scheduled *energy imports*. This restriction shall be enforced by the following constraint for all time-steps  $t \in TS$  and all *intertie zone* source buses  $d \in DI$ :

$$\sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} + \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \leq \sum_{k \in K_{t,d}^B} (QIG_{t,d,k} - SIG_{t,d,k}).$$

## 8.5.6 Pseudo-Units

- 8.5.6.1 A constraint shall be required to calculate physical *generation resource* schedules from *pseudo-unit* schedules using the steam turbine *resource's* shares in the operating regions of the *pseudo-unit* determined in section 15. For all time-steps  $t \in TS$  and *pseudo-unit* buses  $b \in B^{PSU}$ :

$$SCT_{t,b} = (1 - STShareMLP_b) \cdot MinQDGC_b \cdot ODG_{t,b} + (1 - STShareDR_b) \cdot \left( \sum_{k \in K_{t,b}^{DR}} SDG_{t,b,k} \right),$$

and for all time-steps  $t \in TS$  and steam turbine *resources*  $p \in PST$ :

$$SST_{t,p} = \sum_{b \in B_p^{ST}} \left( STShareMLP_b \cdot MinQDGC_b \cdot ODG_{t,b} + STShareDR_b \cdot \left( \sum_{k \in K_{t,b}^{DR}} SDG_{t,b,k} \right) + \sum_{k \in K_{t,b}^{DF}} SDG_{t,b,k} \right).$$

- 8.5.6.2 Maximum constraints shall be enforced on the operating region to which they apply for both *energy* and *operating reserve* schedules. For all time-steps  $t \in TS$  and *pseudo-unit* buses  $b \in B^{PSU}$ :

$$MinQDGC_b \cdot ODG_{t,b} \leq MaxMLP_{t,b},$$

$$\sum_{k \in K_{t,b}^{DR}} SDG_{t,b,k} \leq MaxDR_{t,b},$$

$$\sum_{k \in K_{t,b}^{DF}} SDG_{t,b,k} \leq MaxDF_{t,b},$$

and

$$\sum_{k \in K_{t,b}^B} SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \leq MaxDR_{t,b} + MaxDF_{t,b}.$$

- 8.5.6.3 For a *pseudo-unit* that cannot provide *ten-minute operating reserve* from its duct firing region, constraints shall limit the *pseudo-unit* from being scheduled in its duct firing region whenever the *pseudo-unit* is scheduled

for *ten-minute operating reserve*. For all all time-steps  $t \in TS$  and *pseudo-unit* buses  $b \in B^{NO10DF}$ :

$$O10R_{t,b} \in \{0,1\},$$

and

$$\sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \leq MaxDR_{t,b} + (1 - O10R_{t,b}) \cdot MaxDF_{t,b}$$

8.5.6.3.1 For all time-steps  $t \in TS$ , *pseudo-unit* buses  $b \in B^{NO10DF}$ , and laminations  $k \in K_{t,b}^{10S}$ :

$$S10SDG_{t,b,k} \leq O10R_{t,b} \cdot Q10SDG_{t,b,k}.$$

8.5.6.3.2 For all time-steps  $t \in TS$ , *pseudo-unit* buses  $b \in B^{NO10DF}$ , and laminations  $k \in K_{t,b}^{10N}$ :

$$S10NDG_{t,b,k} \leq O10R_{t,b} \cdot Q10NDG_{t,b,k}.$$

8.5.6.4 For the purposes of the *energy* balance constraint in section 8.7.1 and the transmission constraints in section 8.7.3, the combustion turbine *resource*'s schedule for the *pseudo-unit* at bus  $b \in B^{PSU}$  in in time-step  $t \in TS$  will be equal to:

8.5.6.4.1  $SCT_{t,b}$  if the *pseudo-unit* is scheduled at or above *minimum loading point*;

8.5.6.4.2  $RampCTC_{b,w}^m$  if the *pseudo-unit* is scheduled to reach *minimum loading point* in *thermal state*  $m \in THERM$  in time-step  $t + w$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ ; or

8.5.6.4.3 0 otherwise.

8.5.6.5 For the purposes of the *energy* balance constraint in section 8.7.1 and the transmission constraints in section 8.7.3, the steam turbine *resource*'s schedule for  $p \in PST$  shall be equal to  $SST_{h,p}$  plus any contribution from *pseudo-unit*  $b \in B_p^{ST}$  ramping to *minimum loading point* as given by  $RampSTC_{b,w}^m$  for a *pseudo-unit* scheduled to reach *minimum loading point* in *thermal state*  $m \in THERM$  in time-step  $(t + w)$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ .

## 8.5.7 Dispatchable Hydroelectric Generation Resources

8.5.7.1 A *dispatchable hydroelectric generation resource* shall be scheduled to at least its *hourly must-run quantity*. For all time-steps  $t \in TS$  and *dispatchable hydroelectric generation resource buses*  $b \in B^{HE}$ :

$$ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \geq MinHMR_{t,b}.$$

8.5.7.2 A *dispatchable hydroelectric generation resource* shall either be scheduled to 0 or to at least its *minimum hourly output*. For all time-steps  $t \in TS$  and all *hydroelectric generation resource buses*  $b \in B^{HE}$ :

$$OHO_{t,b} \in \{0,1\};$$

$$ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \geq MinHO_{t,b} \cdot OHO_{t,b};$$

and for all  $k \in K_{t,b}^E$ :

$$0 \leq SDG_{t,b,k} \leq OHO_{t,b} \cdot QDG_{t,b,k}.$$

8.5.7.3 A *dispatchable hydroelectric generation resource* shall not be scheduled within its *forbidden regions*. For *dispatch days*  $q \in DAYS$ , all time-steps  $t \in TS$  in *dispatch day*  $q$ , all *dispatchable hydroelectric generation resource buses*  $b \in B^{HE}$  and all  $i \in \{1, \dots, NFor_{q,b}\}$ :

$$OFR_{t,b,i} \in \{0,1\};$$

$$ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq OFR_{t,b,i} \cdot ForL_{q,b,i} + (1 - OFR_{t,b,i}) \cdot \left( MinQDGC_b + \sum_{k \in K_{t,b}^E} QDG_{t,b,k} \right);$$

and

$$ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \geq (1 - OFR_{t,b,i}) \cdot ForU_{q,b,i}.$$

## 8.5.8 Linked Wheeling Through Transactions

8.5.8.1 The amount of scheduled export *energy* must be equal to the amount of scheduled import *energy* for *linked wheeling through transactions*. For all time-steps  $t \in TS$  and all linked *boundary entity resource buses*  $(dx, di) \in L_t$ :

$$\sum_{j \in J_{t,dx}^B} SXL_{t,dx,j} = \sum_{k \in K_{t,di}^B} SIG_{t,di,k}$$

## 8.6 Dispatch Data Inter-Hour/Multi-Hour Constraints

### 8.6.1 Energy Ramping

- 8.6.1.1 For *dispatchable loads*, the constraints in section 8.6.1.5 and section 8.6.2.1 use  $URRDL_b$  to represent a ramp up rate selected from  $URRDL_{t,b,w}$  and uses  $DRRDL_b$  to represent a ramp down rate selected from  $DRRDL_{t,b,w}$ .
- 8.6.1.2 For *dispatchable generation resources*, the constraints in section 8.6.1.7 and section 8.6.2.2 use  $URRDG_b$  to represent a ramp up rate selected from  $URRDG_{t,b,w}$  and uses  $DRRDG_b$  to represent a ramp down rate selected from  $DRRDG_{t,b,w}$ .
- 8.6.1.3 The *pre-dispatch calculation engine* shall respect the ramping restrictions determined by the up to five *offered* MW quantity, ramp up rate and ramp down rate value sets.
- 8.6.1.4 In all ramping constraints, the schedules for time-step 1 are obtained from the initial scheduling assumptions in section 5.9. For all time-steps  $t \in TS$  the ramping rates in all ramping constraints shall be adjusted to allow the applicable *resource* to:
- 8.6.1.4.1 ramp down from its lower limit in time-step  $(t - 1)$  to its upper limit in time-step  $t$ ; and
- 8.6.1.4.2 ramp up from its upper limit in time-step  $(t - 1)$  to its lower limit in time-step  $t$ .
- 8.6.1.5 *Energy* schedules for *dispatchable loads* cannot vary by more than an hour's ramping capability for the applicable *resource*. This constraint shall be enforced by the following for all time-steps  $t \in TS$  and buses  $b \in B^{DL}$ :

$$\begin{aligned} \sum_{j \in J_{t-1,b}^B} SDL_{t-1,b,j} - 60 \cdot DRRDL_b &\leq \sum_{j \in J_{t,b}^B} SDL_{t,b,j} \\ &\leq \sum_{j \in J_{t-1,b}^B} SDL_{t-1,b,j} + 60 \cdot URRDL_b. \end{aligned}$$

- 8.6.1.6 *Energy* schedules for *hourly demand response resources* cannot vary by more than an hour's ramping capability for the applicable *resource*. This



constraint shall be enforced by the following for all time-steps  $t \in TS$  and all buses  $b \in B^{HDR}$ :

$$\begin{aligned} \sum_{j \in J_{t-1,b}^B} (QHDR_{t-1,b,j} - SHDR_{t-1,b,j}) - 60 \cdot URRHDR_b \\ \leq \sum_{j \in J_{t,b}^B} (QHDR_{t,b,j} - SHDR_{t,b,j}) \\ \leq \sum_{j \in J_{t-1,b}^B} (QHDR_{t-1,b,j} - SHDR_{t-1,b,j}) + 60 \cdot DRRHDR_b. \end{aligned}$$

8.6.1.7 *Energy schedules for a dispatchable generation resource that is committed cannot vary by more than an hour's ramping capability for the applicable resource. For all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ :*

8.6.1.7.1 For the first hour a *resource* reaches its *minimum loading point*, where  $ODG_{t,b} = 1$ ,  $ODG_{t-1,b} = 0$ , the following constraint shall be applied:

$$0 \leq \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \leq 30 \cdot URRDG_b$$

8.6.1.7.2 If the *resource* stays on at or above *minimum loading point* and  $ODG_{t,b} = 1$ ,  $ODG_{t-1,b} = 1$ , the following constraint shall be applied:

$$\begin{aligned} \sum_{k \in K_{t-1,b}^B} SDG_{t-1,b,k} - 60 \cdot DRRDG_b \leq \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \\ \leq \sum_{k \in K_{t-1,b}^B} SDG_{t-1,b,k} + 60 \cdot URRDG_b \end{aligned}$$

8.6.1.7.3 For the last hour the *resource* is scheduled at or above *minimum loading point* before being scheduled off, where  $ODG_{t,b} = 1$ ,  $ODG_{t+1,b} = 0$ , the following constraint shall be applied:

$$0 \leq \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \leq 30 \cdot DRRDG_b$$

8.6.1.8 The first and third constraint in section 8.6.1.6 do not apply to a *quick start resource*.

8.6.1.9 For time-steps where *non-quick start resources* are ramping up to *minimum loading point*, energy shall be scheduled for these *resources* using the submitted *ramp up energy to minimum loading point*.

## 8.6.2 Operating Reserve Ramping

8.6.2.1 The total synchronized *ten-minute operating reserve*, non-synchronized *ten-minute operating reserve* and *thirty-minute operating reserve* from *dispatchable loads* shall not exceed their ramp capability to decrease load consumption and for all time-steps  $t \in TS$  and all buses  $b \in B^{DL}$ :

$$\begin{aligned} \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} + \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} + \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \\ \leq \sum_{j \in J_{t,b}^B} SDL_{t,b,j} - \sum_{j \in J_{t-1,b}^B} SDL_{t-1,b,j} + 60 \cdot DRRDL_b. \end{aligned}$$

8.6.2.2 The total synchronized *ten-minute operating reserve*, non-synchronized *ten-minute operating reserve* and *thirty-minute operating reserve* from a committed *dispatchable generation resource* shall not exceed its ramp capability to increase generation and for all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ :

$$\begin{aligned} \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \\ \leq \sum_{k \in K_{t-1,b}^B} SDG_{t-1,b,k} - \sum_{k \in K_{t,b}^B} SDG_{t,b,k} + 60 \cdot URRDG_b; \\ \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \\ + \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \leq [(t-n) \cdot 60 + 30] \cdot URRDG_b \cdot ODG_{t,b} \end{aligned}$$

where  $n$  is the time-step of the last start before or in time-step  $t$ , and

$$\begin{aligned} \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{h,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \\ + \sum_{k \in K_{t,b}^B} SDG_{t,b,k} \leq [(m-t) \cdot 60 + 30] \cdot DRRDG_b \cdot ODG_{t,b} \end{aligned}$$

where  $m$  is the time-step of the last shutdown in or after time-step  $t$ .

### 8.6.3 Non-Quick Start Resources

8.6.3.1 Schedules for a *non-quick start resource* shall not violate such *resource's minimum generation block run-times, minimum generation block down-times* and *maximum number of starts per day*.

8.6.3.2 In the first forecast hour of the pre-dispatch look-ahead period, a *resource's* current hours on shall determine any remaining *minimum generation block run-time* to enforce. If  $0 < InitOperHrs_b < MGBRTDG_{tod,b}$ , then the *resource* at bus  $b \in B^{NQS}$  has yet to complete its *minimum generation block run-time*, and:

$$ODG_{2,b}, ODG_{3,b}, \dots, ODG_{\min(n_{LAP}, MGBRTDG_{tod,b} - InitOperHrs_b + 1), b} = 1.$$

8.6.3.3 In the first forecast hour of the pre-dispatch look-ahead period (i.e. time-step 2), the number of hours a *resource* has been down shall determine any remaining *minimum generation block down-time* to enforce and shall respect the *minimum generation block down-time* for a hot *thermal state*. If  $0 < InitDownHrs_b < MGBDTDG_{tod,b}^{HOT}$ , then the *resource* at bus  $b \in B^{NQS}$  has yet to complete its *minimum generation block down-time*, and:

$$ODG_{2,b}, ODG_{3,b}, \dots, ODG_{\min(n_{LAP}, MGBDTDG_{tod,b}^{HOT} - InitDownHrs_b + 1), b} = 0.$$

8.6.3.4 If  $ODG_{t-1,b} = 0$  and  $ODG_{t,b} = 1$  for time-step  $t \in TS$ , then the *resource* at bus  $b \in B^{NQS}$  has been scheduled to start up during time-step  $t$  and shall be scheduled to remain in operation until it has completed its *minimum generation block run-time* or to the end of the pre-dispatch look-ahead period. Therefore:

$$ODG_{t+1,b}, ODG_{t+2,b}, \dots, ODG_{\min(n_{LAP}, t + MGBRTDGC_b - 1), b} = 1.$$

8.6.3.5 If  $ODG_{t-1,b} = 1$  and  $ODG_{t,b} = 0$  for time-step  $t \in TS$ , then the *resource* at bus  $b \in B^{NQS}$  has been scheduled to shut down during time-step  $t$  and shall be scheduled to remain off until it has completed its hot *minimum generation block down-time* or to the end of the pre-dispatch look-ahead period. Therefore:

$$ODG_{t+1,b}, ODG_{t+2,b}, \dots, ODG_{\min(n_{LAP}, t + MGBDTDGC_b^{HOT} - 1), b} = 0.$$

8.6.3.6 A Boolean variable  $IDG_{t,b}$  indicates that the *non-quick start resource* at bus  $b \in B^{NQS}$  is scheduled to reach its *minimum loading point* in time-step  $t \in TS$  after being scheduled below its *minimum loading point* in the preceding time-step. A value of zero indicates that a *resource* is not

scheduled to reach its *minimum loading point*, while a value of one indicates that it is scheduled to reach its *minimum loading point*. Therefore, for all time-steps  $t \in TS$  and all buses  $b \in B^{NQS}$ :

$$IDG_{t,b} = \begin{cases} 1 & \text{if } ODG_{t-1,b} = 0 \text{ and } ODG_{t,b} = 1 \\ 0 & \text{otherwise.} \end{cases}$$

8.6.3.7 A *non-quick start resource* shall not be scheduled more than its *maximum number of starts per day*. For all buses  $b \in B^{NQS}$ :

$$\sum_{t \in TS_{tod}} IDG_{t,b} \leq MaxStartsDG_{tod,b} - NumStarts_{tod,b}.$$

8.6.3.7.1 and if the pre-dispatch look-ahead period spans two *dispatch days* then:

$$\sum_{t \in TS_{tom}} IDG_{t,b} \leq MaxStartsDG_{tom,b}.$$

8.6.3.8 For a *non-quick start resource* at bus  $b \in B^{NQS}$  that has been offline  $InitDownHrs_b$  hours, and for future *minimum loading point* time-step  $t \in \{2, \dots, n_{LAP}\}$ , the *pre-dispatch calculation engine* shall assign a *start-up offer* and *ramp energy* to *minimum loading point* profile as follows:

8.6.3.8.1 If  $0 \leq InitDownHrs_b + t - 1 \leq MGBD TDGC_b^{HOT}$ , then the *resource* cannot be scheduled in time-step  $t$ ,

8.6.3.8.2 If  $MGBD TDGC_b^{HOT} < InitDownHrs_b + t - 1 \leq MGBD TDGC_b^{WARM}$ , then the *resource* will be assigned a “HOT” *thermal state* for time-step  $t$  and the *start-up offer*  $SUDG_{t,b}^{HOT}$  shall apply. The *ramp up energy to minimum loading point* profile shall be  $RampEC_{b,w}^{HOT}$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ ;

8.6.3.8.3 If  $MGBD TDGC_b^{WARM} < InitDownHrs_b + t - 1 \leq MGBD TDGC_b^{COLD}$ , then the *resource* will be assigned a “WARM” *thermal state* for time-step  $t$  and the *start-up offer*  $SUDG_{t,b}^{WARM}$  shall apply. The *ramp up energy to minimum loading point* profile shall be  $RampEC_{b,w}^{WARM}$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ ; and

8.6.3.8.4 If  $MGBD TDGC_b^{COLD} < InitDownHrs_b + t - 1$  then the *resource* will be assigned a “COLD” *thermal state* for time-step  $t$  and the *start-up offer*  $SUDG_{t,b}^{COLD}$  shall apply. The *ramp up energy to*

minimum loading point profile shall be  $RampEC_{b,w}^{COLD}$  for  $w \in \{1, \dots, RampHrsC_b^m\}$ .

- 8.6.3.9 For a *non-quick start resource* at bus  $b \in B^{NQS}$  that is in-service as determined by its initial condition, the *pre-dispatch calculation engine* shall assign a *start-up offer* and *ramp up energy to minimum loading point* profile associated with the future *thermal state* as specified in section 8.6.3.8.

## 8.6.4 Energy Limited Resources

- 8.6.4.1 An *energy limited resource* shall not be scheduled to provide:

- 8.6.4.1.1 more *energy* than the *maximum daily energy limit* specified for such *resource*; or
- 8.6.4.1.2 *energy* in amounts that would preclude such *resource* from providing *operating reserve* when activated;
- 8.6.4.1.3 for all buses  $b \in B^{ELR}$  where an *energy limited resource* is located and all time-steps  $T \in TS_{tod}$ :

$$\begin{aligned} & \sum_{t=2..T} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \\ & + 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k} \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k} \right) \\ & - \sum_{i=1..N_{MaxDelViol_T}} SMaxDelViol_{T,b,i} \\ & \leq MaxDEL_{tod,b} - EngyUsed_b. \end{aligned}$$

- 8.6.4.2 If the pre-dispatch look-ahead period spans two *dispatch days*, the constraints in section 8.6.4.1 shall apply to an *energy limited resource* for each *dispatch day*, and shall consider the amount of *energy* already provided by the *resource* for the current *dispatch day*. Therefore, for all buses  $b \in B^{ELR}$  where an *energy limited resource* is located and all time-steps  $T \in TS_{tom}$ :

$$\begin{aligned}
& \sum_{t=t_{tom}..T} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \\
& + 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k} \right) \\
& + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k} \right) \\
& - \sum_{i=1..N_{MaxDelViol_T}} SMaxDelViol_{T,b,i} \leq MaxDEL_{tom,b}.
\end{aligned}$$

where the factors 10 *ORConv* and 30 *ORConv* are applied to scheduled *ten-minute operating reserve* and *thirty-minute operating reserve* for *energy limited resources* to convert MW into MWh. Violation variables for over-scheduling a *resource's maximum daily energy limit* may be used to allow the *pre-dispatch calculation engine* to find a solution.

## 8.6.5 Dispatchable Hydroelectric Generation Resources

8.6.5.1 *Dispatchable hydroelectric generation resources* shall be scheduled for at least their *minimum daily energy limit*. If the pre-dispatch look-ahead period spans two *dispatch days*, the constraint shall be applied for both days. Violation variables for under-scheduling a *resource's minimum daily energy limit* may be used to allow the *pre-dispatch calculation engine* to find a solution. For all *dispatchable hydroelectric generation resource* buses  $b \in B^{HE}$ :

$$\begin{aligned}
& \sum_{t \in TS_{tod}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right. \\
& \quad \left. + \sum_{i=1..N_{MinDelViol_t}} SMinDelViol_{t,b,i} \right) \geq MinDEL_{tod,b} - EngyUsed_b.
\end{aligned}$$

8.6.5.1.1 and if the pre-dispatch look-ahead period spans two *dispatch days*, for all hydroelectric *resource* buses  $b \in B^{HE}$ :

$$\sum_{t \in TS_{tom}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{i=1..N_{MinDelViol_t}} SMinDelViol_{t,b,i} \right) \geq MinDEL_{tom,b}.$$

8.6.5.2 A Boolean variable  $IHE_{t,b,i}$  indicates that a start for the *dispatchable hydroelectric generation resource* at bus  $b \in B^{HE}$  was counted in time-step  $t \in TS$  as a result of the *resource* schedule increasing from below its  $i$ -th *start indication value* to at or above its  $i$ -th start indication for  $i \in \{1, \dots, NStartMW_b\}$ . A value of zero indicates that a start was not counted, while a value of one indicates that a start was counted. Therefore, for all time-steps  $t \in TS$ , buses  $b \in B^{HE}$  and *start indication values*  $i \in \{1, \dots, NStartMW_b\}$ :

$$IHE_{t,b,i} = \begin{cases} 1 & \text{if } \left( ODG_{t-1,b} \cdot MinQDGC_b + \sum_{k \in K_{t-1,b}^E} SDG_{t-1,b,k} < StartMW_{b,i} \right) \\ & \text{and } \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \geq StartMW_{b,i} \right) \\ 0 & \text{otherwise.} \end{cases}$$

8.6.5.3 *Dispatchable hydroelectric generation resources* shall not be scheduled to be started more times than permitted by their *maximum number of starts per day*. If the pre-dispatch look-ahead period spans two *dispatch days*, this constraint shall be applied for both days. The following constraint shall apply for all buses  $b \in B^{HE}$ :

$$\sum_{t \in TS_{tod}} \left( \sum_{i=1..NStartMW_b} IHE_{t,b,i} \right) \leq MaxStartsHE_{tod,b} - NumStartsHE_b.$$

8.6.5.3.1 and if the pre-dispatch look-ahead period spans two *dispatch days*, for buses  $b \in B^{HE}$ :

$$\sum_{t \in TS_{tom}} \left( \sum_{i=1..NStartMW_b} IHE_{t,b,i} \right) \leq MaxStartsHE_{tom,b}.$$

8.6.5.4 The schedules for multiple *dispatchable hydroelectric generation resources* with a registered *forebay* shall not exceed shared *maximum*

*daily energy limits*. If the pre-dispatch look-ahead period spans two *dispatch days*, the constraint shall be applied for both days, where the constraint for today shall consider the amount of *energy* already provided by *resources* with a registered *forebay*. Violation variables for over-scheduling the *maximum daily energy limit* may be used to allow the *pre-dispatch calculation engine* to find a solution. For all sets  $s \in SHE$  and all time-steps  $T \in TS_{tod}$ :

$$\begin{aligned} & \sum_{t=2..T} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \right) \\ & + \sum_{b \in B_s^{HE}} \left( 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k} \right) \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k} \right) \\ & - \sum_{i=1..N_{SMaxDelViol_T}} SSMaxDelViol_{T,s,i} \leq MaxSDEL_{tod,s} - EngyUsedSHE_s \end{aligned}$$

8.6.5.4.1 and if the look-ahead period spans two *dispatch days*, then for all sets  $s \in SHE$  and all time-steps  $T \in TS_{tom}$ :

$$\begin{aligned} & \sum_{t=t_{tom}..T} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \right) \\ & + \sum_{b \in B_s^{HE}} \left( 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k} \right) \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k} \right) \\ & - \sum_{i=1..N_{SMaxDelViol_T}} SSMaxDelViol_{T,s,i} \leq MaxSDEL_{tom,s} \end{aligned}$$

where the factors 10 *ORConv* and 30 *ORConv* shall be applied to scheduled *ten-minute operating reserve* and *thirty-minute operating reserve* to convert MW into MWh.



8.6.5.5 Schedules for multiple *dispatchable* hydroelectric *generation resources* with a registered *forebay* shall respect shared *minimum daily energy limits*. If the pre-dispatch look-ahead period spans two *dispatch days*, the constraint shall be applied for both days, where the constraint for today shall consider the amount of *energy* already provided by *resources* with a registered *forebay*. Violation variables for under-scheduling the *minimum daily energy limit* may be used to allow the *pre-dispatch calculation engine* to find a solution. For all sets  $s \in SHE$ :

$$\sum_{t \in TS_{tod}} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) + \sum_{i=1..N_{SMinDelViol_t}} SSMinDelViol_{t,s,i} \right) \geq MinSDEL_{tod,s} - EngyUsedSH$$

8.6.5.5.1 and if the pre-dispatch look-ahead period spans two *dispatch days*, then for all sets  $s \in SHE$ :

$$\sum_{t \in TS_{tom}} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) + \sum_{i=1..N_{SMinDelViol_t}} SSMinDelViol_{t,s,i} \right) \geq MinSDEL_{tom,s}$$

8.6.5.6 For linked *dispatchable* hydroelectric *generation resources* with a registered *forebay*, *energy* scheduled at the upstream *resource* in one time-step shall result in a proportional amount of *energy* being scheduled at the linked downstream *resource* in the time-step determined by the *time lag*.

8.6.5.7 For linked *dispatchable* hydroelectric *generation resources*, time-steps in which the upstream *resources* schedule is not determined in the *pre-dispatch calculation engine* optimization, the constraint shall link either the historical or time-step 1 anticipated production for the upstream *resources* to the schedule for the downstream *resources*.

8.6.5.8 For all linked *dispatchable* hydroelectric *generation resources* between upstream *resources*  $b_1 \in B_{up}^{HE}$  and downstream *resources*  $b_2 \in B_{dn}^{HE}$  for  $(b_1, b_2) \in LNKC$  and all time-steps  $t \in TS$  such that  $t \leq LagC_{b_1, b_2} + 1$ :

$$\begin{aligned}
& \sum_{b_2 \in B_{dn}^{HE}} \left( ODG_{t,b_2} \cdot MinQDGC_{b_2} + \sum_{k \in K_{t,b_2}^E} SDG_{t,b_2,k} \right) \\
& - \sum_{i=1..N_{OGenLnkViol_t}} SOGenLnkViol_{t,(b_1,b_2),i} \\
& + \sum_{i=1..N_{UGenLnkViol_t}} SUGenLnkViol_{t,(b_1,b_2),i} \\
& = MWhRatioC_{b_1,b_2} \cdot PastMWh_{t,b_1}.
\end{aligned}$$

8.6.5.9 For linked *dispatchable hydroelectric generation resources*, time-steps in which both the upstream and downstream *resource* schedules are determined in the *pre-dispatch calculation engine* optimization, the constraint will link the scheduling variables for both the upstream and downstream *resources*.

8.6.5.10 For all linked *dispatchable hydroelectric generation resources* between upstream *resources*  $b_1 \in B_{up}^{HE}$  and downstream *resources*  $b_2 \in B_{dn}^{HE}$  for  $(b_1, b_2) \in LNKC$  and time-steps  $t \in TS$  such that  $t + LagC_{b_1,b_2} \leq n_{LAP}$ :

$$\begin{aligned}
& \sum_{b_2 \in B_{dn}^{HE}} \left( ODG_{t+LagC_{b_1,b_2},b_2} \cdot MinQDGC_{b_2} + \sum_{k \in K_{t+LagC_{b_1,b_2},b_2}^E} SDG_{t+LagC_{b_1,b_2},b_2,k} \right) \\
& - \sum_{i=1..N_{OGenLnkViol_{t+Lag_{b_1,b_2}}}} SOGenLnkViol_{t+Lag_{b_1,b_2},(b_1,b_2),i} \\
& + \sum_{i=1..N_{UGenLnkViol_{t+Lag_{b_1,b_2}}}} SUGenLnkViol_{t+Lag_{b_1,b_2},(b_1,b_2),i} \\
& = MWhRatioC_{b_1,b_2} \cdot \sum_{b_1 \in B_{up}^{HE}} \left( ODG_{t,b_1} \cdot MinQDGC_{b_1} + \sum_{k \in K_{t,b_1}^E} SDG_{t,b_1,k} \right)
\end{aligned}$$

## 8.7 Constraints for Reliability Requirements

### 8.7.1 Energy Balance

8.7.1.1 The total amount of *energy* withdrawals scheduled at load bus  $b \in B$  in time-step  $t \in TS$ ,  $With_{t,b}$  shall be represented by:

$$With_{t,b} = \begin{cases} \sum_{j \in J_{t,b}^E} SDL_{t,b,j} & \text{if } b \in B^{DL} \\ \sum_{j \in J_{t,b}^E} (QHDR_{t,b,j} - SHDR_{t,b,j}) & \text{if } b \in B^{HDR} \end{cases}$$

8.7.1.2 The total amount of export *energy* scheduled at *intertie zone* bus  $d \in DX$  in time-step  $t \in TS$ ,  $With_{t,d}$ , as the exports from Ontario to the *intertie zone* bus shall be represented by:

$$With_{t,d} = \sum_{j \in J_{t,d}^E} SXL_{t,d,j}$$

8.7.1.3 The total amount of injections scheduled at internal bus  $b \in B$  in time-step  $t \in TS$ ,  $Inj_{t,b}$ , shall be represented by:

$$Inj_{t,b} = OfferInj_{t,b} + RampInj_{t,b}$$

where:

$$OfferInj_{t,b} = \begin{cases} \sum_{k \in K_{t,b}^E} SNDG_{t,b,k} & \text{if } b \in B^{NDG} \\ ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} & \text{if } b \in B^{DG} \end{cases}$$

and

$$RampInj_{t,b} = \begin{cases} \sum_{w=1..min(RampHrsC_b^m, n_{LAP}-t)} RampEC_{b,w}^m \cdot IDG_{t+w,b} & \text{if } b \in B^{NQS} \\ 0 & \text{otherwise} \end{cases}$$

8.7.1.4 The total amount of import *energy* scheduled at *intertie zone* bus  $d \in DI$  in time-step  $t \in TS$ ,  $Inj_{t,d}$ , as the imports into Ontario from that *intertie zone* bus shall be represented by:

$$Inj_{t,d} = \sum_{k \in K_{t,d}^E} SIG_{t,d,k}$$

8.7.1.5 Injections and withdrawals at each bus shall be multiplied by one plus the marginal loss factor calculated by the *security* assessment function to reflect the losses or reduction in losses that result when injections or withdrawals occur at locations other than the *reference bus*. These loss-

adjusted injections and withdrawals must then be equal to each other after taking into account the adjustment for any discrepancy between total and marginal losses. Load or generation reduction associated with the *demand* constraint violation shall be subtracted from the total load or generation for the *pre-dispatch calculation engine* to produce a solution. For time-step  $t \in TS$ , the *energy* balance shall be:

$$\begin{aligned}
FL_t + \sum_{b \in B^{DL} \cup B^{HDR}} (1 + MglLoss_{t,b}) \cdot With_{t,b} \\
+ \sum_{d \in DX} (1 + MglLoss_{t,d}) \cdot With_{t,d} - \sum_{i=1..N_{LdViol_t}} SLdViol_{t,i} \\
= \sum_{b \in B^{NDG} \cup B^{DG}} (1 + MglLoss_{t,b}) \cdot Inj_{t,b} \\
+ \sum_{d \in DI} (1 + MglLoss_{t,d}) \cdot Inj_{t,d} - \sum_{i=1..N_{GenViol_t}} SGenViol_{t,i} \\
+ LossAdj_t.
\end{aligned}$$

## 8.7.2 Operating Reserve Requirements

8.7.2.1 *Operating reserve* shall be scheduled to meet system-wide requirements for synchronized *ten-minute operating reserve*, total *ten-minute operating reserve*, and *thirty-minute operating reserve* while respecting all applicable regional minimum requirements and regional maximum restrictions for *operating reserve*.

8.7.2.2 Constraint violation penalty curves may be used to impose a penalty cost for not meeting the *IESO's* system-wide *operating reserve* requirements, not meeting a regional minimum requirement, or not adhering to a regional maximum restriction. Full *operating reserve* requirements shall be scheduled unless the cost of doing so would be higher than the applicable penalty cost. For each time-step  $t \in TS$ :

$$\begin{aligned}
\sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) + \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) + \sum_{i=1..N_{10SViol_t}} S10SViol_{t,i} \\
\geq TOT10S_t;
\end{aligned}$$

$$\begin{aligned}
& \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) + \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) \\
& + \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \right) + \sum_{d \in DX} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \right) \\
& + \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \right) + \sum_{d \in DI} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \right) \\
& + \sum_{i=1..N_{10RViol_t}} S10RViol_{t,i} \geq TOT10R_t;
\end{aligned}$$

and

$$\begin{aligned}
& \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) + \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) + \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \right) \\
& + \sum_{d \in DX} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \right) + \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \right) \\
& + \sum_{d \in DI} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \right) + \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \right) \\
& + \sum_{d \in DX} \left( \sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \right) + \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \right) \\
& + \sum_{d \in DI} \left( \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \right) + \sum_{i=1..N_{30RViol_t}} S30RViol_{t,i} \geq TOT30R_t.
\end{aligned}$$

8.7.2.3 The following constraints shall be applied for each time-step  $t \in TS$  and each region  $r \in ORREG$ :

$$\begin{aligned}
& \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \right) + \sum_{d \in D_r^{REG} \cap DX} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \right) + \sum_{d \in D_r^{REG} \cap DI} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \right) \\
& + \sum_{i=1..N_{REG10RViol_t}} SREG10RViol_{r,t,i} \geq REGMin10R_{t,r};
\end{aligned}$$

$$\begin{aligned}
& \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \right) + \sum_{d \in D_r^{REG} \cap DX} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \right) + \sum_{d \in D_r^{REG} \cap DI} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \right) \\
& - \sum_{i=1..N_{XREG10RViol_t}} SXREG10RViol_{r,t,i} \leq REGMax10R_{t,r};
\end{aligned}$$

$$\begin{aligned}
& \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \right) + \sum_{d \in D_r^{REG} \cap DX} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \right) + \sum_{d \in D_r^{REG} \cap DI} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,j} \right) + \sum_{d \in D_r^{REG} \cap DX} \left( \sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \right) + \sum_{d \in D_r^{REG} \cap DI} \left( \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \right) \\
& + \sum_{i=1..N_{REG30RViol_t}} SREG30RViol_{r,t,i} \geq REGMin30R_{t,r};
\end{aligned}$$

and

$$\begin{aligned}
& + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10N}} S10NDL_{t,b,j} \right) \\
& + \sum_{d \in D_r^{REG} \cap DX} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} \right) + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{10S}} S10SDL_{t,b,j} \right) \\
& + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} \right) + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} \right) \\
& + \sum_{d \in D_r^{REG} \cap DI} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} \right) + \sum_{b \in B_r^{REG} \cap B^{DL}} \left( \sum_{j \in J_{t,b}^{30R}} S30RDL_{t,b,k} \right) \\
& + \sum_{d \in D_r^{REG} \cap DX} \left( \sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \right) + \sum_{b \in B_r^{REG} \cap B^{DG}} \left( \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \right) \\
& + \sum_{d \in D_r^{REG} \cap DI} \left( \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \right) - \sum_{i=1..N_{XREG30RViol_t}} SXREG30RViol_{r,t,i} \\
& \leq REGMax30R_{t,r}.
\end{aligned}$$

### 8.7.3 IESO Internal Transmission Limits

- 8.7.3.1 The Pre-Dispatch Scheduling algorithm shall produce a set of *energy* schedules that do not violate any *security limits* in the pre-contingency state and the post-contingency state subject to the remainder of this section 8.7.3. The total amount of *energy* scheduled to be injected and withdrawn at each bus used by the *energy* balance constraint in section 8.7.1.5, shall be used to produce these schedules.
- 8.7.3.2 Pre-contingency,  $SPreITLViol_{f,t,i}$ , and post-contingency,  $SITLViol_{c,f,t,i}$ , transmission limit violation variables shall allow the *pre-dispatch calculation engine* to find a solution.
- 8.7.3.3 For all time-steps  $t \in TS$  and *facilities*  $f \in F_t$ , the linearized constraints for violated pre-contingency limits obtained from the *security* assesment function shall take the form:

$$\begin{aligned}
& \sum_{b \in B^{NDG} \cup B^{DG}} PreConSF_{t,f,b} \cdot Inj_{t,b} - \sum_{b \in B^{DL} \cup B^{HDR}} PreConSF_{t,f,b} \cdot With_{t,b} \\
& + \sum_{d \in DI} PreConSF_{t,f,d} \cdot Inj_{t,d} - \sum_{d \in DX} PreConSF_{t,f,d} \cdot With_{t,d} \\
& - \sum_{i=1..N_{PreITLViol_{f,t}}} SPreITLViol_{f,t,i} \leq AdjNormMaxFlow_{t,f}.
\end{aligned}$$

8.7.3.4 For all time-steps  $t \in TS$ , contingencies  $c \in C$ , and facilities  $f \in F_{t,c}$  the linearized constraints for violated post-contingency limits obtained from the *security* assesment function shall take the form:

$$\begin{aligned} & \sum_{b \in B^{NDG} \cup B^{DG}} SF_{t,c,f,b} \cdot Inj_{t,b} - \sum_{b \in B^{DL} \cup B^{HDR}} SF_{t,c,f,b} \cdot With_{t,b} + \sum_{d \in DI} SF_{t,c,f,d} \\ & \cdot Inj_{t,d} - \sum_{d \in DX} SF_{t,c,f,d} \cdot With_{t,d} \\ & - \sum_{i=1..N_{ITLViol_{c,f,t}}} SITLViol_{c,f,t,i} \leq AdjEmMaxFlow_{t,c,f}. \end{aligned}$$

## 8.7.4 Intertie Limits

8.7.4.1 The Pre-Dispatch Scheduling algorithm shall produce a set of *energy* and *operating reserve* schedules that respect any *security limits* associated with *interties* between Ontario and *intertie zones*. For all time-steps  $t \in TS$  and all constraints  $z \in Z_{Sch}$ :

$$\begin{aligned} & \sum_{a \in A: EnCoeff_{a,z} \neq 0} \left[ \begin{aligned} & EnCoeff_{a,z} \left( \sum_{d \in DI_a} \sum_{k \in K_{t,d}^E} SIG_{t,d,k} - \sum_{d \in DX_a} \sum_{j \in J_{t,d}^E} SXL_{t,d,j} \right) \\ & + 0.5 \cdot (EnCoeff_{a,z} + 1) \left( \sum_{d \in DI_a} \left( \sum_{k \in K_{t,d}^{10N}} S10NIG_{t,d,k} + \sum_{k \in K_{t,d}^{30R}} S30RIG_{t,d,k} \right) + \right. \\ & \left. \sum_{d \in DX_a} \left( \sum_{j \in J_{t,d}^{10N}} S10NXL_{t,d,j} + \sum_{j \in J_{t,d}^{30R}} S30RXL_{t,d,j} \right) \right) \end{aligned} \right] \\ & - \sum_{i=1..N_{PreConXTLViol_{z,t}}} SPreXTLViol_{z,t,i} \leq MaxExtSch_{t,z}. \end{aligned}$$

where for out-of-service *intertie zones*, the *intertie* limits shall be set to zero and all *boundary entity resources* shall receive a zero schedule for *energy* and *operating reserve*.

8.7.4.2 Changes in the hour-to-hour net *energy* schedule over all *interties* shall not exceed the net interchange scheduling limit. The net import schedule shall be summed over all *intertie zones* for a given time-step to obtain the net *interchange schedule* for the time-step, and shall not:

8.7.4.2.1 exceed the net *interchange schedule* for the previous time-step plus the net interchange scheduling limit; and



8.7.4.2.2 be less than the net *interchange schedule* for the previous time-step minus the net interchange scheduling limit.

8.7.4.3 Violation variables shall be provided for both the up and down ramp limits to allow the *pre-dispatch calculation engine* to find a solution and for all time-steps  $t \in TS$ :

$$\begin{aligned}
 & \sum_{d \in DI} \sum_{k \in K_{t-1,d}^E} SIG_{t-1,d,k} - \sum_{d \in DX} \sum_{j \in J_{t-1,d}^E} SXL_{t-1,d,j} - ExtDSC_t - \sum_{i=1..N_{NIDViol_t}} SNIDViol_{t,i} \\
 & \leq \sum_{d \in DI} \sum_{k \in K_{t,d}^E} SIG_{t,d,k} - \sum_{d \in DX} \sum_{j \in J_{t,d}^E} SXL_{t,d,j} \\
 & \leq \sum_{d \in DI} \sum_{k \in K_{t-1,d}^E} SIG_{t-1,d,k} - \sum_{d \in DX} \sum_{j \in J_{t-1,d}^E} SXL_{t-1,d,j} + ExtUSC_t \\
 & + \sum_{i=1..N_{NIUViol_t}} SNIUViol_{t,i}.
 \end{aligned}$$

## 8.7.5 Penalty Price Variable Bounds

8.7.5.1 Penalty price variables shall be restricted to the ranges determined by the constraint violation penalty curves for the Pre-Dispatch Scheduling algorithm and for time-steps  $t \in TS$ :

$$\begin{aligned}
0 \leq SLdViol_{t,i} &\leq QLdViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{LdViol_t}\}; \\
0 \leq SGenViol_{t,i} &\leq QGenViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{GenViol_t}\}; \\
0 \leq S10SViol_{t,i} &\leq Q10SViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{10SViol_t}\}; \\
0 \leq S10RViol_{t,i} &\leq Q10RViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{10RViol_t}\}; \\
0 \leq S30RViol_{t,i} &\leq Q30RViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{30RViol_t}\}; \\
0 \leq SREG10RViol_{r,t,i} &\leq QREG10RViolSch_{t,i} && \text{for all } r \in ORREG, i \in \{1, \dots, N_{REG10RViol_t}\}; \\
0 \leq SREG30RViol_{r,t,i} &\leq QREG30RViolSch_{t,i} && \text{for all } r \in ORREG, i \in \{1, \dots, N_{REG30RViol_t}\}; \\
0 \leq SXREG10RViol_{r,t,i} &\leq QXREG10RViolSch_{t,i} && \text{for all } r \in ORREG, i \in \{1, \dots, N_{XREG10RViol_t}\}; \\
0 \leq SXREG30RViol_{r,t,i} &\leq QXREG30RViolSch_{t,i} && \text{for all } r \in ORREG, i \in \{1, \dots, N_{XREG30RViol_t}\}; \\
0 \leq SPreITLViol_{f,t,i} &\leq QPreITLViolSch_{f,t,i} && \text{for all } f \in F_D, i \in \{1, \dots, N_{PreITLViol_{f,t}}\}; \\
0 \leq SITLViol_{c,f,t,i} &\leq QITLViolSch_{c,f,t,i} && \text{for all } c \in C, f \in F_{t,c}, i \in \{1, \dots, N_{ITLViol_{c,f,t}}\}; \\
0 \leq SPreXTLViol_{z,t,i} &\leq QPreXTLViolSch_{z,t,i} && \text{for all } z \in Z_{Sch}, i \in \{1, \dots, N_{PreXTLViol_{z,t}}\}; \\
0 \leq SNIUViol_{t,i} &\leq QNIUViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{NIUViol_t}\}; \\
0 \leq SNIDViol_{t,i} &\leq QNIDViolSch_{t,i} && \text{for all } i \in \{1, \dots, N_{NIDViol_t}\}; \\
0 \leq SMaxDelViol_{t,b,i} &\leq QMaxDelViolSch_{t,b,i} && \text{for all } b \in B^{ELR}, i \in \{1, \dots, N_{MaxDelViol_t}\}; \\
0 \leq SMinDelViol_{t,b,i} &\leq QMinDelViolSch_{t,b,i} && \text{for all } b \in B^{HE}, i \in \{1, \dots, N_{MinDelViol_t}\}; \\
0 \leq SSMaXDelViol_{t,s,i} &\leq QSMaXDelViolSch_{t,s,i} && \text{for all } s \in SHE, i \in \{1, \dots, N_{SMaXDelViol_t}\}; \\
0 \leq SSMiNDelViol_{t,s,i} &\leq QSMiNDelViolSch_{t,s,i} && \text{for all } s \in SHE, i \in \{1, \dots, N_{SMiNDelViol_t}\}; \\
0 \leq SOGenLnkViol_{t,(b_1,b_2),i} &\leq QOGenLnkViol_{t,(b_1,b_2),i} && \text{for all } (b_1, b_2) \in LNK, i \in \{1, \dots, N_{OGenLnkViol_t}\}; \\
\text{and} &&& \\
0 \leq SUGenLnkViol_{t,(b_1,b_2),i} &\leq QUGenLnkViol_{t,(b_1,b_2),i} && \text{for all } (b_1, b_2) \in LNK, i \in \{1, \dots, N_{UGenLnkViol_t}\}.
\end{aligned}$$

## 8.8 Outputs

8.8.1 Outputs for the Pre-Dispatch Scheduling algorithm include *resource* schedules and commitments.

# 9 Pre-Dispatch Pricing

## 9.1 Purpose

9.1.1 The Pre-Dispatch Pricing algorithm shall perform a *security*-constrained economic *dispatch* to maximize gains from trade using *dispatch data* submitted by *registered market participants*, subject to section 14.7.1.3, and *resource* schedules and commitments produced by the Pre-Dispatch Scheduling algorithm to meet the IESO's province-wide non-dispatchable *demand* forecast and IESO-specified *operating reserve* requirements for each hour of the pre-dispatch look-ahead period.

## 9.2 Information, Sets, Indices and Parameters

9.2.1 Information, sets, indices and parameters used by the Pre-Dispatch Pricing algorithm are described in section 3. In addition, the following *resource* schedules and commitments determined by the Pre-Dispatch Scheduling algorithm shall be used by the Pre-Dispatch Pricing algorithm:

- 9.2.1.1  $SDG_{t,b,k}^{PDS}$  designates the amount of *energy* that the *dispatchable generation resource* is scheduled to provide above  $MinQDGC_b$  at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^E$ ;
- 9.2.1.2  $ODG_{t,b}^{PDS}$  designates whether the *dispatchable generation resource* at bus  $b \in B^{DG}$  was scheduled at or above its *minimum loading point* in time-step  $t \in TS$ ;
- 9.2.1.3  $S10SDG_{t,b,k}^{PDS}$  designates the amount of *synchronized ten-minute operating reserve* that the *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{10S}$ ;
- 9.2.1.4  $S10NDG_{t,b,k}^{PDS}$  designates the amount of *non-synchronized ten-minute operating reserve* that the *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{10N}$ ;
- 9.2.1.5  $S30RDG_{t,b,k}^{PDS}$  designates the amount of *thirty-minute operating reserve* that the *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{30R}$ ;  
and

- 9.2.1.6  $OHO_{t,b}^{PDS}$  designates whether the *dispatchable hydroelectric generation resource* at bus  $b \in B^{HE}$  has been scheduled at or above  $MinHO_{t,b}$  in time-step  $t \in TS$ .

### 9.3 Variables and Objective Function

9.3.1 The Pre-Dispatch Pricing algorithm shall solve for the same variables as in the Pre-Dispatch Scheduling algorithm, section 8.3.1, with the following exceptions:

- 9.3.1.1  $IDG_{t,b}$  for bus  $b \in B^{DG}$  and time-step  $t \in TS$  shall not appear in the formulation;
- 9.3.1.2  $ODG_{t,b}$  for bus  $b \in B^{DG}$  and time-step  $t \in TS$  will be fixed to a constant value, as determined by the Pre-Dispatch Scheduling algorithm;
- 9.3.1.3  $OHO_{t,b}$  for bus  $b \in B^{HE}$  and time-step  $t \in TS$  will be fixed to a constant value, as determined by the Pre-Dispatch Scheduling algorithm;
- 9.3.1.4  $IHE_{t,b,i}$  for  $b \in B^{HE}$ , time-step  $t \in TS$  and *start indication value*  $i \in \{1, \dots, NStartMW_b\}$  shall not appear in the formulation;
- 9.3.1.5  $SOGenLnkViol_{t,(b_1,b_2),i}$  for  $(b_1,b_2) \in LNK$  such that  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$ , time-step  $t \in TS$  and  $i \in \{1, \dots, N_{OGenLnkViol_t}\}$  shall not appear in the formulation; and
- 9.3.1.6  $SUGenLnkViol_{t,(b_1,b_2),i}$  for  $(b_1,b_2) \in LNK$  such that  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$ , time-step  $t \in TS$  and  $i \in \{1, \dots, N_{UGenLnkViol_t}\}$  shall not appear in the formulation.

9.3.2 The objective function for the Pre-Dispatch Pricing algorithm shall maximize gains from trade by maximizing the following expression:

$$\sum_{t \in TS} \left( \text{ObjDL}_t - \text{ObjHDR}_t + \text{ObjXL}_t - \text{ObjNDG}_t \right. \\ \left. - \text{ObjDG}_t - \text{ObjIG}_t - \text{TB}_t - \text{ViolCost}_t \right)$$

where:

$$\text{ObjDL}_t = \sum_{b \in B^{DL}} \left( \sum_{j \in J_{t,b}^E} \text{SDL}_{t,b,j} \cdot \text{PDL}_{t,b,j} - \sum_{j \in J_{t,b}^{10S}} \text{S10SDL}_{t,b,j} \cdot \text{P10SDL}_{t,b,j} - \sum_{j \in J_{t,b}^{10N}} \text{S10NDL}_{t,b,j} \cdot \text{P10NDL}_{t,b,j} - \sum_{j \in J_{t,b}^{30R}} \text{S30RDL}_{t,b,j} \cdot \text{P30RDL}_{t,b,j} \right);$$

$$\text{ObjHDR}_t = \sum_{b \in B^{HDR}} \left( \sum_{j \in J_{t,b}^E} \text{SHDR}_{t,b,j} \cdot \text{PHDR}_{t,b,j} \right);$$

$$\text{ObjXL}_t = \sum_{d \in DX} \left( \sum_{j \in J_{t,d}^E} \text{SXL}_{t,d,j} \cdot \text{PXL}_{t,d,j} - \sum_{j \in J_{t,d}^{10N}} \text{S10NXL}_{t,d,j} \cdot \text{P10NXL}_{t,d,j} - \sum_{j \in J_{t,d}^{30R}} \text{S30RXL}_{t,d,j} \cdot \text{P30RXL}_{t,d,j} \right);$$

$$\text{ObjNDG}_t = \sum_{b \in B^{NDG}} \left( \sum_{k \in K_{t,b}^E} \text{SNDG}_{t,b,k} \cdot \text{PNDG}_{t,b,k} \right);$$

$$\text{ObjDG}_t = \sum_{b \in B^{DG}} \left( \sum_{k \in K_{t,b}^E} \text{SDG}_{t,b,k} \cdot \text{PDG}_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} \text{S10SDG}_{t,b,k} \cdot \text{P10SDG}_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} \text{S10NDG}_{t,b,k} \cdot \text{P10NDG}_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} \text{S30RDG}_{t,b,k} \cdot \text{P30RDG}_{t,b,k} \right);$$

$$\text{ObjIG}_t = \sum_{d \in DI} \left( \sum_{k \in K_{t,d}^E} \text{SIG}_{t,d,k} \cdot \text{PIG}_{t,d,k} + \sum_{k \in K_{t,d}^{10N}} \text{S10NIG}_{t,d,k} \cdot \text{P10NIG}_{t,d,k} + \sum_{k \in K_{t,d}^{30R}} \text{S30RIG}_{t,d,k} \cdot \text{P30RIG}_{t,d,k} \right).$$

9.3.2.1 The tie-breaking term,  $\text{TB}_t$ , shall be the same term described in section 8.3.2.1.

9.3.2.2  $\text{ViolCost}_t$  shall be calculated as follows:

$$\begin{aligned}
ViolCost_t = & \sum_{i=1..N_{LdViol_t}} S_{LdViol_{t,i}} \cdot P_{LdViolPrC_{t,i}} \\
& - \sum_{i=1..N_{GenViol_t}} S_{GenViol_{t,i}} \cdot P_{GenViolPrC_{t,i}} \\
& + \sum_{i=1..N_{10SViol_t}} S_{10SViol_{t,i}} \cdot P_{10SViolPrC_{t,i}} \\
& + \sum_{i=1..N_{10RViol_t}} S_{10RViol_{t,i}} \cdot P_{10RViolPrC_{t,i}} \\
& + \sum_{i=1..N_{30RViol_t}} S_{30RViol_{t,i}} \cdot P_{30RViolPrC_{t,i}} \\
& + \sum_{r \in ORREG} \left( \sum_{i=1..N_{REG10RViol_t}} S_{REG10RViol_{r,t,i}} \cdot P_{REG10RViolPrC_{t,i}} \right) \\
& + \sum_{r \in ORREG} \left( \sum_{i=1..N_{REG30RViol_t}} S_{REG30RViol_{r,t,i}} \cdot P_{REG30RViolPrC_{t,i}} \right) \\
& + \sum_{r \in ORREG} \left( \sum_{i=1..N_{XREG10RViol_t}} S_{XREG10RViol_{r,t,i}} \cdot P_{XREG10RViolPrC_{t,i}} \right) \\
& + \sum_{r \in ORREG} \left( \sum_{i=1..N_{XREG30RViol_t}} S_{XREG30RViol_{r,t,i}} \cdot P_{XREG30RViolPrC_{t,i}} \right) \\
& + \sum_{f \in F_t} \left( \sum_{i=1..N_{PreITLViol_{f,t}}} S_{PreITLViol_{f,t,i}} \cdot P_{PreITLViolPrC_{f,t,i}} \right) \\
& + \sum_{c \in C} \sum_{f \in F_{t,c}} \left( \sum_{i=1..N_{ITLViol_{c,f,t}}} S_{ITLViol_{c,f,t,i}} \cdot P_{ITLViolPrC_{c,f,t,i}} \right) \\
& + \sum_{z \in Z_{Sch}} \left( \sum_{i=1..N_{PreXTLViol_t}} S_{PreXTLViol_{z,t,i}} \cdot P_{PreXTLViolPrC_{z,t,i}} \right) \\
& + \sum_{i=1..N_{NIUViol_t}} S_{NIUViol_{t,i}} \cdot P_{NIUViolPrC_{t,i}} \\
& + \sum_{i=1..N_{NIDViol_t}} S_{NIDViol_{t,i}} \cdot P_{NIDViolPrC_{t,i}} \\
& + \sum_{b \in BELR} \left( \sum_{i=1..N_{MaxDelViol_t}} S_{MaxDelViol_{t,b,i}} \cdot P_{MaxDelViolPrC_{t,b,i}} \right)
\end{aligned}$$

$$\begin{aligned}
& + \sum_{b \in B^{HE}} \left( \sum_{i=1..N_{MinDelViol_t}} SMinDelViol_{t,b,i} \cdot PMinDelViolPr_{t,b,i} \right) \\
& + \sum_{s \in SHE} \left( \sum_{i=1..N_{SMaxDelViol_t}} SSMaxDelViol_{t,s,i} \cdot PSMaxDelViolPr_{t,s,i} \right) \\
& + \sum_{s \in SHE} \left( \sum_{i=1..N_{SMinDelViol_t}} SMinDelViol_{t,s,i} \cdot PMinDelViolPr_{t,s,i} \right)
\end{aligned}$$

9.3.2.3 The objective function of the Pre-Dispatch Pricing algorithm in section 9.3.2 shall be subject to the constraints described in sections 9.4 - 9.8.

## 9.4 Constraints

9.4.1 The constraints described in sections 9.5, 9.6, 9.7 and 9.8 apply to the optimization function in the Pre-Dispatch Pricing algorithm.

## 9.5 Dispatch Data Constraints Applying to Individual Hours

9.5.1 Scheduling Variable Bounds

9.5.1.1 *Energy and operating reserve* schedules shall not be negative and shall not exceed the quantity respectively offered for *energy* and *operating reserve*. For all time-steps  $t \in TS$ :

$$\begin{aligned}
0 \leq SDL_{t,b,j} &\leq QDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^E; \\
0 \leq S10SDL_{t,b,j} &\leq Q10SDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^{10S}; \\
0 \leq S10NDL_{t,b,j} &\leq Q10NDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^{10N}; \\
0 \leq S30RDL_{t,b,j} &\leq Q30RDL_{t,b,j} && \text{for all } b \in B^{DL}, j \in \mathcal{J}_{t,b}^{30R}; \\
0 \leq SHDR_{t,b,j} &\leq QHDR_{t,b,j} && \text{for all } b \in B^{HDR}, j \in \mathcal{J}_{t,b}^E; \\
0 \leq SXL_{t,d,j} &\leq QXL_{t,d,j} && \text{for all } d \in DX, j \in \mathcal{J}_{t,d}^E; \\
0 \leq S10NXL_{t,d,j} &\leq Q10NXL_{t,d,j} && \text{for all } d \in DX, j \in \mathcal{J}_{t,d}^{10N}; \\
0 \leq S30RXL_{t,d,j} &\leq Q30RXL_{t,d,j} && \text{for all } d \in DX, j \in \mathcal{J}_{t,d}^{30R}; \\
0 \leq SNDG_{t,b,k} &\leq QNDG_{t,b,k} && \text{for all } b \in B^{NDG}, k \in K_{t,b}^E; \\
0 \leq SIG_{t,d,k} &\leq QIG_{t,d,k} && \text{for all } d \in DI, k \in K_{t,d}^E; \\
0 \leq S10NIG_{t,d,k} &\leq Q10NIG_{t,d,k} && \text{for all } d \in DI, k \in K_{t,d}^{10N}; \text{ and} \\
0 \leq S30RIG_{t,d,k} &\leq Q30RIG_{t,d,k} && \text{for all } d \in DI, k \in K_{t,d}^{30R}.
\end{aligned}$$

9.5.1.2 A dispatchable generation resource may be scheduled for energy and operating reserve only if its commitment status variable, as determined by the Pre-Dispatch Scheduling algorithm, is equal to 1. For all time-steps  $t \in TS$ :

$$\begin{aligned}
0 \leq SDG_{t,b,k} &\leq ODG_{t,b}^{PDS} \cdot QDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^E; \\
0 \leq S10SDG_{t,b,k} &\leq ODG_{t,b}^{PDS} \cdot Q10SDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^{10S}; \\
0 \leq S10NDG_{t,b,k} &\leq ODG_{t,b}^{PDS} \cdot Q10NDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^{10N}; \text{ and} \\
0 \leq S30RDG_{t,b,k} &\leq ODG_{t,b}^{PDS} \cdot Q30RDG_{t,b,k} && \text{for all } b \in B^{DG}, k \in K_{t,b}^{30R}.
\end{aligned}$$

where

$ODG_{t,b}^{PDS}$  is a fixed constant in the above constraints, per section 9.8.1.1.

## 9.5.2 Resource Minimums and Maximums

9.5.2.1 The constraints in section 8.5.2 shall apply in the Pre-Dispatch Pricing algorithm.



### 9.5.3 Off-Market Transactions

- 9.5.3.1 The constraints in sections 8.5.3.1 and 8.5.3.2 for inadvertent payback transactions shall apply in the Pre-Dispatch Pricing algorithm.
- 9.5.3.2 In the case of *emergency energy* transactions, subject to section 9.5.3.3, the constraints in sections 8.5.3.3 and 8.5.3.4 shall apply in the Pre-Dispatch Pricing algorithm.
- 9.5.3.3 For all time-steps  $t \in TS$  and all *boundary entity resources* scheduled to import *emergency energy* that does not support an export  $d \in DI_t^{EMNS}$ :

$$\sum_{k \in K_{t,d}^E} SIG_{t,d,k} = 0.$$

### 9.5.4 Intertie Minimum and Maximum Constraints

- 9.5.4.1 The constraints in section 8.5.4 shall apply in the Pre-Dispatch Pricing algorithm as well.

### 9.5.5 Operating Reserve Scheduling

- 9.5.5.1 The constraints in section 8.5.5 shall apply in the Pre-Dispatch Pricing algorithm as well.

### 9.5.6 Pseudo-Units

- 9.5.6.1 The constraints in section 8.5.6 shall apply in the Pre-Dispatch Pricing algorithm as well.

### 9.5.7 Dispatchable Hydroelectric Generation Resources

- 9.5.7.1 The constraints in section 8.5.7 shall apply in the Pre-Dispatch Pricing algorithm as well, with the following exceptions:
- 9.5.7.1.1 *energy offer* laminations corresponding to the *hourly must-run* amount shall be ineligible to set prices;
- 9.5.7.1.2 *minimum hourly output* constraints shall be replaced by the constraints in section 9.8; and
- 9.5.7.1.3 a *dispatchable hydroelectric generation resource's* schedule shall respect its *forbidden regions* and may only set prices within the operating range determined by the adjacent *forbidden regions* between which the *resource* was scheduled.

9.5.8 Linked Wheeling Through Transactions

9.5.8.1 The constraints in section 8.5.8 shall apply in the Pre-Dispatch Pricing algorithm as well.

## 9.6 Dispatch Data Inter-Hour/Multi-Hour Constraints

9.6.1 Energy Ramping

9.6.1.1 The constraints in section 8.6.1 shall apply in the Pre-Dispatch Pricing algorithm as well.

9.6.2 Operating Reserve Ramping

9.6.2.1 The constraints in section 8.6.2 shall apply in the Pre-Dispatch Pricing algorithm as well.

9.6.3 Energy Limited Resources

9.6.3.1 The constraints in section 8.6.4 shall apply to *energy limited resources*. If a *resource's maximum daily energy limit* is binding, then the constraints in section 9.8 shall also apply.

9.6.4 Dispatchable Hydroelectric Generation Resources

9.6.4.1 A *dispatchable hydroelectric generation resource* shall be scheduled for *energy* to at least its *minimum daily energy limit*. Violation variables for under-scheduling a *resource's minimum daily energy limit* shall be provided to allow the *pre-dispatch calculation engine* to find a solution. For all *dispatchable hydroelectric generation resource* buses  $b \in B^{HE}$ :

$$\sum_{t \in TS_{tod}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{i=1..N_{MinDelViol_t}} SMinDelViol_{t,b,i} \right) \geq MinDEL_{tod,b} - EngyUsed_b.$$

9.6.4.1.1 If the pre-dispatch look-ahead period spans two *dispatch days*, for all hydroelectric *resource* buses  $b \in B^{HE}$ :

$$\sum_{t \in TS_{tom}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{i=1..N_{MinDelViol_t}} SMinDelViol_{t,b,i} \right) \geq MinDEL_{tom,b}.$$

9.6.4.2 The constraints in section 9.8.3.3 shall apply to a *dispatchable* hydroelectric *generation resource* with a binding *minimum daily energy limit* in the Pre-Dispatch Scheduling algorithm.

9.6.4.3 The schedules for multiple *dispatchable* hydroelectric *generation resources* with a registered *forebay* shall respect shared *maximum daily energy limits*. Violation variables for scheduling *resources* above the *maximum daily energy limit* may be used to allow the *pre-dispatch calculation engine* to find a solution. For all sets  $s \in SHE$  and all time-steps  $T \in TS_{tod}$ :

$$\begin{aligned} & \sum_{t=2..T} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \right) \\ & + \sum_{b \in B_s^{HE}} \left( 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k} \right) \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k} \right) \\ & - \sum_{i=1..N_{SMaxDelViol_T}} SMaxDelViol_{T,s,i} \leq MaxSDEL_{tod,s} - EngyUsedSHE_s. \end{aligned}$$

9.6.4.3.1 If the look-ahead period spans two *dispatch days*, then for all sets  $s \in SHE$  and all time-steps  $T \in TS_{tom}$ :

$$\begin{aligned}
& \sum_{t=t_{tom}..T} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \right) \\
& + \sum_{b \in B_s^{HE}} \left( 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k} \right) \right) \\
& + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k} \right) \\
& - \sum_{i=1..N_{SMaxDelViol_T}} SMaxDelViol_{T,s,i} \leq MaxSDEL_{tom,s}
\end{aligned}$$

where the factors 10 *ORConv* and 30 *ORConv* shall be applied to scheduled *ten-minute operating reserve* and *thirty-minute operating reserve* to convert MW into MWh.

- 9.6.4.4 The schedules for multiple *dispatchable hydroelectric generation resources* with a registered *forebay* shall not violate shared *minimum daily energy limits*. Violation variables for scheduling *resources* below the *minimum daily energy limit* may be used to allow the *pre-dispatch calculation engine* to find a solution. For all sets  $s \in SHE_{tod}$  and all time-steps  $t \in TS_{tod}$ :

$$\begin{aligned}
& \sum_{t \in TS_{tod}} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \right) \\
& + \sum_{i=1..N_{SMinDelViol_t}} SMinDelViol_{t,s,i} \\
& \geq MinSDEL_{tod,s} - EngyUsedSHE_s.
\end{aligned}$$

- 9.6.4.4.1 If the look-ahead period spans two *dispatch days*, then for all sets  $s \in SHE$  and all time-steps  $t \in TS_{tom}$ :

$$\begin{aligned}
& \sum_{t \in TS_{tom}} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \right) \\
& + \sum_{i=1..N_{SMinDelViol_t}} SMinDelViol_{t,s,i} \geq MinSDEL_{tom,s}.
\end{aligned}$$

## 9.7 Constraints for Reliability Requirements

### 9.7.1 Energy Balance

9.7.1.1 The constraint in section 8.7.1 shall also apply in the Pre-Dispatch Pricing algorithm, except the marginal loss factors used in the *energy* balance constraint in the Pre-Dispatch Pricing algorithm shall be fixed to the marginal loss factors used in the last optimization function iteration of the Pre-Dispatch Scheduling algorithm.

### 9.7.2 Operating Reserve Requirements

9.7.2.1 The constraints in section 8.7.2 shall also apply in the Pre-Dispatch Pricing algorithm.

### 9.7.3 IESO Internal Transmission Limits

9.7.3.1 The constraints in section 8.7.3 shall also apply in the Pre-Dispatch Pricing algorithm, except the sensitivities and limits considered shall be those provided by the most recent *security* assessment function iteration of the Pre-Dispatch Pricing algorithm.

### 9.7.4 Intertie Limits

9.7.4.1 The constraints in section 8.7.4 shall also apply in the Pre-Dispatch Pricing algorithm.

### 9.7.5 Penalty Price Variable Bounds

9.7.5.1 The following constraints shall restrict the penalty price variables to the ranges determined by the constraint violation penalty curves for the pricing algorithm. For all time-steps  $t \in TS$ :

$0 \leq SLdViol_{t,i} \leq QLdViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{LdViol_t}\}$ ;
$0 \leq SGenViol_{t,i} \leq QGenViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{GenViol_t}\}$ ;
$0 \leq S10SViol_{t,i} \leq Q10SViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{10SViol_t}\}$ ;
$0 \leq S10RViol_{t,i} \leq Q10RViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{10RPrct}\}$ ;
$0 \leq S30RViol_{t,i} \leq Q30RViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{30RPrct}\}$ ;
$0 \leq SREG10RViol_{r,t,i} \leq QREG10RViolPrc_{t,i}$	for all $r \in ORREG, i \in \{1, \dots, N_{REG10RPrct}\}$ ;
$0 \leq SREG30RViol_{r,t,i} \leq QREG30RViolPrc_{t,i}$	for all $r \in ORREG, i \in \{1, \dots, N_{REG30RPrct}\}$ ;
$0 \leq SXREG10RViol_{r,t,i} \leq QXREG10RViolPrc_{t,i}$	for all $r \in ORREG, i \in \{1, \dots, N_{XREG10RPrct}\}$ ;
$0 \leq SXREG30RViol_{r,t,i} \leq QXREG30RViolPrc_{t,i}$	for all $r \in ORREG, i \in \{1, \dots, N_{XREG30RPrct}\}$ ;
$0 \leq SPreITLViol_{f,t,i} \leq QPreITLViolPrc_{f,t,i}$	for all $f \in F_v, i \in \{1, \dots, N_{PreITLPrc_{f,t}}\}$ ;
$0 \leq SITLViol_{f,c,t,i} \leq QITLViolPrc_{f,c,t,i}$	for all $c \in C, f \in F_{c,v}, i \in \{1, \dots, N_{PITLPrc_{c,f,t}}\}$ ;
$0 \leq SPreXTLViol_{z,t,i} \leq QPreXTLViolPrc_{z,t,i}$	for all $z \in Z_{Sch}, i \in \{1, \dots, N_{PreXTLPrc_{z,t}}\}$ ;
$0 \leq SNIUViol_{t,i} \leq QNIUViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{NIUPrc_t}\}$ ;
$0 \leq SNIDViol_{t,i} \leq QNIDViolPrc_{t,i}$	for all $i \in \{1, \dots, N_{NIDPrct}\}$ ;
$0 \leq SMaxDelViol_{t,b,i} \leq QMaxDelViolPrc_{t,b,i}$	for all $b \in B^{ELR}, i \in \{1, \dots, N_{MaxDelViol_t}\}$ ;
$0 \leq SMinDelViol_{t,b,i} \leq QMinDelViolPrc_{t,b,i}$	for all $b \in B^{HE}, i \in \{1, \dots, N_{MinDelViol_t}\}$ ;
$0 \leq SMaxDelViol_{t,s,i} \leq QMaxDelViolPrc_{t,s,i}$	for all $s \in SHE, i \in \{1, \dots, N_{SMaxDelViol_t}\}$ ; and
$0 \leq SMinDelViol_{t,s,i} \leq QMinDelViolPrc_{t,s,i}$	for all $s \in SHE, i \in \{1, \dots, N_{SMinDelViol_t}\}$ .

## 9.8 Constraints to Ensure the Price Setting Eligibility of Offer/Bid Laminations

### 9.8.1 Commitment Status Variables

- 9.8.1.1 Commitment decisions shall be fixed to the commitment statuses of *resources* calculated by the Pre-Dispatch Scheduling algorithm in section 8. For all time-steps  $t \in TS$  and all buses  $b \in B^{DG}$ :

$$ODG_{t,b} = ODG_{t,b}^{PDS}.$$

### 9.8.2 Energy Limited Resources

- 9.8.2.1 For an *energy limited resource* with a *maximum daily energy limit* that was binding in the Pre-Dispatch Scheduling algorithm, the schedules

calculated by the Pre-Dispatch Scheduling algorithm shall determine the price-setting eligibility of the *resource's energy* and *operating reserve offer* laminations. In each time-step, *energy* or *operating reserve* laminations up to the total amount of *energy* and *operating reserve* scheduled in the Pre-Dispatch Scheduling algorithm shall be eligible to set prices. For bus  $b \in B^{ELR}$ , if there exists a time-step  $T \in TS_{tod}$  such that:

$$\begin{aligned} & \sum_{t=2..T} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \\ & + 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k}^{PDS} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k}^{PDS} \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k}^{PDS} \right) = MaxDEL_{tod,b} - EngyUsed_b \end{aligned}$$

9.8.2.1.1 then the *maximum daily energy limit* constraint shall be considered binding in the Pre-Dispatch Scheduling algorithm. In such circumstances, the following constraints must hold for bus  $b \in B^{ELR}$  for all time-steps  $t \in TS_{tod}$ :

$$\begin{aligned} & \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} + \epsilon, \\ & \sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \\ & \leq MaxDEL_{tod,b} - EngyUsed_b - \sum_{\tau=2}^{t-1} \sum_{k \in K_{\tau,b}^E} SDG_{\tau,b,k}^{PDS} \end{aligned}$$

where  $\epsilon$  is a small positive constant.

9.8.2.2 If the pre-dispatch look-ahead period spans two *dispatch days*, then for bus  $b \in B^{ELR}$ , if there exists a time-step  $T \in TS_{tom}$  such that:

$$\begin{aligned} & \sum_{t=t_{tom}..T} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \\ & + 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k}^{PDS} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k}^{PDS} \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k}^{PDS} \right) = MaxDEL_{tom,b} \end{aligned}$$

9.8.2.2.1 then the *maximum daily energy limit* constraint is considered to be binding for the next *dispatch day* in Pre-Dispatch Scheduling algorithm. In such circumstances, the following constraints must hold for bus  $b \in B^{ELR}$  for all time-steps  $t \in TS_{tom}$ :

$$\sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} + \epsilon,$$

$$\sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k}$$

$$\leq MaxDEL_{tom,b} - \sum_{\tau=tom}^{t-1} \sum_{k \in K_{\tau,b}^E} SDG_{\tau,b,k}^{PDS}.$$

where  $\epsilon$  is a small positive constant.

### 9.8.3 Dispatchable Hydroelectric Generation Resources

9.8.3.1 If a *dispatchable hydroelectric generation resource* is scheduled to provide *energy* at or above its *minimum hourly output* in the Pre-Dispatch Scheduling algorithm, such *resource* shall also be scheduled at or above its *minimum hourly output* in the Pre-Dispatch Pricing algorithm. The *energy offer* laminations corresponding to the *minimum hourly output* amount shall be ineligible to set prices. If a *dispatchable hydroelectric generation resource* with a *minimum hourly output* amount receives a zero schedule in the Pre-Dispatch Scheduling algorithm, the *resource* shall also receive a zero schedule in the Pre-Dispatch Pricing algorithm and shall be ineligible to set prices in the *energy market*. For all time-steps  $t \in TS$  and *dispatchable hydroelectric generation resource* buses  $b \in B^{HE}$ :

$$ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \geq MinHO_{t,b} \cdot OHO_{t,b}^{PDS}$$

and for all  $k \in K_{t,b}^E$ :

$$0 \leq SDG_{t,b,k} \leq OHO_{t,b}^{PDS} \cdot QDG_{t,b,k}.$$

9.8.3.2 For a *dispatchable hydroelectric generation resource* with a limited number of starts, such *resource* shall be scheduled such that it is limited to set prices within an operating range consistent with the number of starts utilized by the *resource's* schedule determined by the Pre-Dispatch Scheduling algorithm. The *resource's* schedule shall be between the same *start indication values* as determined in the Pre-Dispatch Scheduling



algorithm. For all *dispatchable* hydroelectric generation resource buses  $b \in B^{HE}$  and all time-steps  $t \in TS$ :

$$\text{If } 0 \leq ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} < StartMW_{b,1},$$

then

$$0 \leq ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq StartMW_{b,1} - 0.1$$

If  $StartMW_{b,i} \leq ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} < StartMW_{b,i+1}$  for  $i \in \{1, \dots, (NStartMW_b - 1)\}$ ,

then

$$StartMW_{b,i} \leq ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq StartMW_{b,i+1} - 0.1$$

If  $ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \geq StartMW_{b,NStartMW_b}$ ,

then

$$ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \geq StartMW_{b,NStartMW_b}.$$

9.8.3.3 For a *dispatchable* hydroelectric generation resource with a *minimum daily energy limit* that was binding in the Pre-Dispatch Scheduling algorithm, the *offer* laminations corresponding to the *energy* schedules calculated in the Pre-Dispatch Scheduling algorithm shall be ineligible to set prices. For all *dispatchable* hydroelectric generation resource buses  $b \in B^{HE}$  such that  $MinDEL_{tod,b} > 0$  and

$$\sum_{t \in TS_{tod}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \leq MinDEL_{tod,b} - EngyUsed_b,$$

9.8.3.3.1 the following constraints must hold for all time-steps  $t \in TS_{tod}$  and *offer* laminations  $k \in K_{t,b}^E$ :

$$SDG_{t,b,k} \geq SDG_{t,b,k}^{PDS}.$$

9.8.3.3.2 If the pre-dispatch look-ahead period spans two *dispatch days*, for all *dispatchable* hydroelectric generation resource buses  $b \in B^{HE}$  such that  $MinDEL_{tom,b} > 0$  and

$$\sum_{t \in TS_{tom}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \leq MinDEL_{tom,b},$$

9.8.3.3.3 the following constraints must hold for all time-steps  $t \in TS_{tom}$  and offer laminations  $k \in K_{t,b}^E$ :

$$SDG_{t,b,k} \geq SDG_{t,b,k}^{PDS}.$$

9.8.3.4 For a *dispatchable hydroelectric generation resource* with a *shared minimum daily energy limit* that was binding in the Pre-Dispatch Scheduling algorithm, the *offer laminations* corresponding to the *energy schedules* calculated for all *resources* in the set  $s \in SHE$  in the Pre-Dispatch Scheduling algorithm shall be ineligible to set prices. Thus, for each set  $s \in SHE$ :

$$\sum_{t \in TS_{tod}} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \right) \leq MinSDEL_{tod,s} - EngyUsedSHE_s,$$

9.8.3.4.1 the following constraints must hold for all time-steps  $t \in TS_{tod} \in :$

$$\sum_{b \in B_s^{HE}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \geq \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right).$$

9.8.3.4.2 If the pre-dispatch look-ahead period spans two *dispatch days*, then for each set  $s \in SHE$ :

$$\sum_{t \in TS_{tom}} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \right) \leq MinSDEL_{tom,s}$$

9.8.3.4.3 the following constraints must hold for all time-steps  $t \in TS_{tom}$ :

$$\sum_{b \in B_s^{HE}} \left( ODG_{t,b} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \right) \geq \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right).$$

9.8.3.5 For a *dispatchable hydroelectric generation resource* with a binding *maximum daily energy limit* in the Pre-Dispatch Scheduling algorithm, the schedules calculated in the Pre-Dispatch Scheduling algorithm shall determine the price-setting eligibility of the *resource's energy* and *operating reserve offer* laminations as described in section 9.8.2.

9.8.3.6 For a *dispatchable hydroelectric generation resource* with a shared *maximum daily energy limit* that was binding in the Pre-Dispatch Scheduling algorithm, in each hour, the *offer* laminations up to the sum of *energy* and *operating reserve* schedules calculated in Pre-Dispatch Scheduling algorithm for all *resources* in each set  $s \in SHE$  will be eligible to set prices. For each set  $s \in SHE$ , if there exists  $T \in TS_{tod}$  such that:

$$\begin{aligned} & \sum_{t=2..T} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \right) \\ & + \sum_{b \in B_s^{HE}} \left( 10ORConv \left( \sum_{k \in K_{T,b}^{1oS}} S10SDG_{T,b,k}^{PDS} + \sum_{k \in K_{T,b}^{1oN}} S10NDG_{T,b,k}^{PDS} \right) \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{3oR}} S30RDG_{T,b,k}^{PDS} \right) \Big) = MaxSDEL_{tod,s} - EngyUsedSHE_s. \end{aligned}$$

9.8.3.6.1 then the *maximum daily energy limit* constraint is considered to be binding for the current *dispatch day* in the Pre-Dispatch Scheduling algorithm. In such circumstances, the following constraints shall apply for all time-steps  $t \in TS_{tod}$ :

$$\begin{aligned} & \sum_{b \in B_s^{HE}} \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq \sum_{b \in B_s^{HE}} \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} + \epsilon, \\ & \sum_{b \in B_s^{HE}} \left( \sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{k \in K_{t,b}^{1oS}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{1oN}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{3oR}} S30RDG_{t,b,k} \right) \\ & \leq MaxSDEL_{tod,s} - EngyUsedSHE_s - \sum_{b \in B_s^{HE}} \sum_{\tau=2}^{t-1} \sum_{k \in K_{\tau,b}^E} SDG_{\tau,b,k}^{PDS}. \end{aligned}$$

where  $\epsilon$  is a small positive constant.

9.8.3.6.2 If the pre-dispatch look-ahead period spans two *dispatch days*, if there exists a time-step  $T \in TS_{tom}$  such that:

$$\begin{aligned} & \sum_{t=t_{tom}..T} \left( \sum_{b \in B_s^{HE}} \left( ODG_{t,b}^{PDS} \cdot MinQDGC_b + \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} \right) \right) \\ & + \sum_{b \in B_s^{HE}} \left( 10ORConv \left( \sum_{k \in K_{T,b}^{10S}} S10SDG_{T,b,k}^{PDS} + \sum_{k \in K_{T,b}^{10N}} S10NDG_{T,b,k}^{PDS} \right) \right) \\ & + 30ORConv \left( \sum_{k \in K_{T,b}^{30R}} S30RDG_{T,b,k}^{PDS} \right) = MaxSDEL_{tom,s} \end{aligned}$$

9.8.3.6.3 then the *maximum daily energy limit* constraint is considered to be binding for the next *dispatch day* in the Pre-Dispatch Scheduling algorithm. In such circumstances, the following constraints shall apply for all time-steps  $t \in TS_{tom}$ :

$$\begin{aligned} & \sum_{b \in B_s^{HE}} \sum_{k \in K_{t,b}^E} SDG_{t,b,k} \leq \sum_{b \in B_s^{HE}} \sum_{k \in K_{t,b}^E} SDG_{t,b,k}^{PDS} + \epsilon, \\ & \sum_{b \in B_s^{HE}} \left( \sum_{k \in K_{t,b}^E} SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10S}} S10SDG_{t,b,k} + \sum_{k \in K_{t,b}^{10N}} S10NDG_{t,b,k} + \sum_{k \in K_{t,b}^{30R}} S30RDG_{t,b,k} \right) \\ & \leq MaxSDEL_{tom,s} - \sum_{b \in B_s^{HE}} \sum_{\tau=t_{tom}}^{t-1} \sum_{k \in K_{\tau,b}^E} SDG_{\tau,b,k}^{PDS}. \end{aligned}$$

where  $\epsilon$  is a small positive constant.

9.8.3.7 For a *dispatchable hydroelectric generation resource* for which a *MWh ratio* was respected in the Pre-Dispatch Scheduling algorithm, such *resource* shall be scheduled between its Pre-Dispatch Scheduling algorithm schedule plus or minus a tolerance  $\Delta$  specified by the *IESO*. The *resource* schedule shall be limited by its *offer* quantity bounds, in section 9.5.1, and any applicable *resource* minimum or maximum constraints, in section 9.5.2. For all linked downstream *dispatchable hydroelectric generation resources*  $b_2$  such that  $(b_1, b_2) \in LNKC$  where  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$  and all time-steps  $t \in TS$ :

$$\begin{aligned}
ODG_{t,b_2}^{PDS} \cdot MinQDGC_{b_2} + \sum_{k \in K_{t,b_2}^E} SDG_{t,b_2,k}^{PDS} - \Delta &\leq ODG_{t,b_2}^{PDS} \cdot MinQDGC_{b_2} + \sum_{k \in K_{t,b_2}^E} SDG_{t,b_2,k} \\
&\leq ODG_{t,b_2}^{PDS} \cdot MinQDGC_{b_2} + \sum_{k \in K_{t,b_2}^E} SDG_{t,b_2,k}^{PDS} + \Delta.
\end{aligned}$$

9.8.3.7.1 For all linked *dispatchable hydroelectric generation resources*  $b_1$  such that  $(b_1, b_2) \in LNKC$  where  $b_1 \in B_{up}^{HE}$  and  $b_2 \in B_{dn}^{HE}$  and all time-steps  $t \in TS$  such that  $t + LagC_{b_1, b_2} \leq n_{LAP}$ :

$$\begin{aligned}
ODG_{t,b_1}^{PDS} \cdot MinQDGC_{b_1} + \sum_{k \in K_{t,b_1}^E} SDG_{t,b_1,k}^{PDS} - \Delta &\leq ODG_{t,b_1}^{PDS} \cdot MinQDGC_{b_1} + \sum_{k \in K_{t,b_1}^E} SDG_{t,b_1,k} \\
&\leq ODG_{t,b_1}^{PDS} \cdot MinQDGC_{b_1} + \sum_{k \in K_{t,b_1}^E} SDG_{t,b_1,k}^{PDS} + \Delta.
\end{aligned}$$

## 9.9 Outputs

9.9.1 Outputs for the Pre-Dispatch Pricing algorithm include the following:

9.9.1.1 shadow prices;

9.9.1.2 *locational marginal prices* and their components; and

9.9.1.3 sensitivity factors.

# 10 Constrained Area Conditions Test

## 10.1 Purpose

10.1.1 The Constrained Area Conditions Test shall:

10.1.1.1 identify when and where competition is restricted; and

10.1.1.2 determine which *resources* shall have their *financial dispatch data parameters* be subject to the Conduct Test in section 11 and the thresholds above the *reference levels* that shall be used in the Conduct Test.

## 10.2 Information, Sets, Indices and Parameters

- 10.2.1 The *narrow constrained areas* and *dynamic constrained areas* and the information published therein in accordance with section 22 of Chapter 7 shall be inputs for the Constrained Area Conditions Test.
- 10.2.2 Information, sets, indices and parameters for the Constrained Area Conditions Test are described in sections 3 and 4. In addition, the following prices produced by the Pre-Dispatch Pricing algorithm shall be used by the Constrained Area Conditions Test:
- 10.2.2.1  $LMP_{t,b}^{PDP}$ , which designates the *locational marginal price* for bus  $b \in B$  in time-step  $t \in TS$ ;
  - 10.2.2.2  $PCong_{t,b}^{PDP}$ , which designates the congestion component of the *locational marginal price* for bus  $b \in B$  in time-step  $t \in TS$ ;
  - 10.2.2.3  $ExtLMP_{t,d}^{PDP}$ , which designates the locational marginal price for intertie bus  $d \in D$  in time-step  $t \in TS$ ;
  - 10.2.2.4  $PExtCong_{t,d}^{PDP}$ , which designates the *intertie* congestion component of the *locational marginal price* for *intertie* bus  $d \in D$  in time-step  $t \in TS$ ;
  - 10.2.2.5  $PIntCong_{t,d}^{PDP}$ , which designates the internal congestion component of the *locational marginal price* for *intertie* bus  $d \in D$  in time-step  $t \in TS$ ;
  - 10.2.2.6  $IntLMP_{t,d}^{PDP}$ , which designates the *intertie border price* for *intertie* bus  $d \in D$  in time-step  $t \in TS$ ;
  - 10.2.2.7  $SPNormT_{t,f}^{PDP}$ , which designates the shadow price for the pre-contingency transmission constraint for *facility*  $f \in F$  in time-step  $t \in TS$ ;
  - 10.2.2.8  $SPEmT_{h,c,f}^{PDP}$ , which designates the shadow price for the post-contingency transmission constraint for *facility*  $f \in F$  in contingency  $c \in C$  in time-step  $t \in TS$ ;
  - 10.2.2.9  $SPNIUExtBwdT_t^{PDP}$ , which designates the shadow price for the net *interchange schedule* limit constraint limiting increases in net imports between time-step  $(t - 1)$  and time-step  $t$ ;
  - 10.2.2.10  $L30RP_{t,b}^{PDP}$ , which designates the *locational marginal price* for *thirty-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$ ;

- 10.2.2.11  $L10NP_{t,b}^{DDP}$ , which designates the *locational marginal price* for non-synchronized *ten-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$ ; and
- 10.2.2.12  $L10SP_{t,b}^{DDP}$ , which designates the *locational marginal price* for synchronized *ten-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$ .

## 10.3 Variables

- 10.3.1 The *pre-dispatch calculation engine* shall use the constrained area conditions tests in sections 10.4 and 10.5 to identify the *resources* that are part of the following data sets:
  - 10.3.1.1  $BCond_t^{NCA}$ , which designates the *resources* in a *narrow constrained area* that must be checked for local market power for *energy* in time-step  $t \in TS$ ;
  - 10.3.1.2  $BCond_t^{DCA}$ , which designates the *resources* in a *dynamic constrained area* that must be checked for local market power for *energy* in time-step  $t \in TS$ ;
  - 10.3.1.3  $BCond_t^{BCA}$ , which designates the *resources* in a broad constrained area to be checked for local market power for *energy* in time-step  $t \in TS$ ;
  - 10.3.1.4  $BCond_t^{GMP}$ , which designates the *resources* to be checked for global market power for *energy* in time-step  $t \in TS$ ;
  - 10.3.1.5  $BCond_t^{10S}$ , which designates that *resources* to be checked for local market power for synchronized *ten-minute operating reserve* in time-step  $t \in TS$ ;
  - 10.3.1.6  $BCond_t^{10N}$ , which designates that *resources* to be checked for local market power for non-synchronized *ten-minute operating reserve* in time-step  $t \in TS$ ;
  - 10.3.1.7  $BCond_t^{30R}$ , which designates that *resources* to be checked for local market power for *thirty-minute operating reserve* in time-step  $t \in TS$ ;
  - 10.3.1.8  $BCond_t^{GMP10S}$ , which designates that *resources* to be checked for global market power for synchronized *ten-minute operating reserve* in time-step  $t \in TS$ ;
  - 10.3.1.9  $BCond_t^{GMP10N}$ , which designates that *resources* to be checked for global market power for non-synchronized *ten-minute operating reserve* in time-step  $t \in TS$ ; and

10.3.1.10  $BCond_t^{GMP30R}$ , which designates that *resources* to be checked for global market power for *thirty-minute operating reserve* in time-step  $t \in TS$ .

## 10.4 Constrained Area Conditions Test for Local Market Power (Energy)

10.4.1 Constrained Area Conditions Test for *narrow constrained areas* and *dynamic constrained area*

10.4.1.1 If at least one transmission constraint for a *narrow constrained area* or *dynamic constrained area* is binding in the Pre-Dispatch Pricing algorithm, then all *resources* identified within the *narrow constrained area* or *dynamic constrained area* shall undergo the applicable Conduct Test in section 11 and:

10.4.1.1.1 For each  $n \in NCA$  and time-step  $t \in TS$ : For each transmission facility that transmits flow into  $n$ ,  $f \in F_n^{NCA}$ , if  $SPNormT_{t,f}^{PDP} \neq 0$  or  $SPEmT_{t,c,f}^{PDP} \neq 0$  for the inbound flow limit, the *pre-dispatch calculation engine* will place  $n$  in the set  $NCA_t'$  and assign the *resources* in  $n$  to the set  $BCond_t^{NCA}$ ; and

10.4.1.1.2 For each  $d \in DCA$  and time-step  $t \in TS$ : For each transmission facility that transmits flow into  $d$ ,  $f \in F_d^{DCA}$ , if  $SPNormT_{t,f}^{PDP} \neq 0$  or  $SPEmT_{t,c,f}^{PDP} \neq 0$  for the inbound flow limit, the *pre-dispatch calculation engine* will place  $d$  in the set  $DCA_t'$  and assign the *resources* in  $n$  to the set  $BCond_t^{DCA}$ .

10.4.1.2 Each *narrow constrained area* and *dynamic constrained area* that meets the criteria in section 10.4.1.1 shall be assigned to one of the following subsets, as appropriate:

10.4.1.2.1  $NCA_t'$ , which designates the *narrow constrained areas* that qualify for market power mitigation for *energy* in time-step  $t \in TS$ ; and

10.4.1.2.2  $DCA_t'$ , which designates the *dynamic constrained areas* that qualify for market power mitigation for *energy* in time-step  $t \in TS$ .

10.4.2 Constrained Area Conditions Test for the Broad Constrained Area

10.4.2.1 If the congestion component of the *locational marginal price* of a *resource* is greater than  $BCACondThresh$  and the *resource* is not part of a *narrow constrained area* or *dynamic constrained area* that has a binding transmission constraint, then the *resource* shall be tested using the broad



constrained area thresholds. For each time-step  $t \in TS$  and bus  $b \in B^{DG}$  such that  $b \notin BCond_t^{NCA} \cup BCond_t^{DCA}$ , if  $PCong_{t,b}^{DDP} > BCACondThresh$ , the *pre-dispatch calculation engine* will then place resource  $b$  in the set  $BCond_t^{BCA}$ .

## 10.5 Constrained Area Conditions Test for Global Market Power (Energy)

10.5.1 The *pre-dispatch calculation engine* shall test resources that can meet incremental load within Ontario for global market power, subject to section 10.5.2, if:

10.5.1.1 the *intertie border prices* at the *global market power reference intertie zones* are greater than the *IBPThresh* threshold value, indicated in time-step  $t \in TS$  by:

10.5.1.1.1  $IntLMP_{t,d}^{DDP} > IBPThresh$  for bids and offers,  $d \in D^{GMPRef}$ , corresponding to the *boundary entity resource bus* for the *global market power reference intertie zones*; and

10.5.1.2 at least one of the following conditions is met:

10.5.1.2.1 import congestion, represented by a negative *intertie congestion component*, is present on all of the *global market power reference intertie zones*, indicated in time-steps  $t = \{2,3\}$  by:

10.5.1.2.1.1  $PExtCong_{t,d}^{DDP} < 0$  for bids and offers,  $d \in D^{GMPRef}$ , corresponding to the *boundary entity resource bus* for the *global market power reference intertie zone*; or

10.5.1.2.1.2 the net *interchange schedule limit* is binding for imports, represented by a non-zero net *interchange schedule limit shadow price* for incremental imports, indicated in time-steps  $t = \{2,3\}$  by:

$$SPNIUExtBwdT_t^{DDP} \neq 0$$

10.5.2 If the conditions in sections 10.5.1 are met, then the *pre-dispatch calculation engine* shall test resources that can meet incremental load within Ontario for global market power, for each time-step  $t \in TS$ , place all  $b \in B^{DG}$  in the set  $BCond_t^{GMP}$ , unless they are excluded because one of the following two conditions:

10.5.2.1 the *resources* in any zone have congestion components at least \$1/MWh below the internal congestion component at all of the *global market power reference intertie zones*:

10.5.2.1.1 if  $PCong_{t,b}^{DDP} < PIntCong_{t,d}^{DDP} - \$1/\text{MWh}$  where  $d \in D^{\text{GMPRef}}$  is true for all *global market power reference intertie zones*; or

10.5.2.2 the *resources* cannot meet the incremental load because of a binding transmission constraint:

10.5.2.2.1 if *resources* cannot meet incremental load because of any binding transmission *facility* where  $SPNormT_{t,f}^{DDP} \neq 0$  or  $SPEmT_{t,c,f}^{DDP} \neq 0$ .

## 10.6 Constrained Area Conditions Test for Local Market Power (Operating Reserve)

10.6.1 Subject to section 10.6.2, for a regional minimum requirement of greater than zero for a specific class of *operating reserve*, then all *resources* within the region with *offers* for classes of *operating reserve* that can satisfy the requirements of the specific class of *operating reserve* shall be tested for local market power:

10.6.1.1 if *b* is in a region with a non-zero minimum requirement, then *b* is subject to the Conduct Test and is placed in the set  $BCond_t^{10S}$ ,  $BCond_t^{10N}$ , or  $BCond_t^{30R}$

10.6.2 A *resource* shall not qualify for local market power mitigation testing for *operating reserve* if the *resource* is located in a region with a binding maximum constraint and for each *resource*  $b \in B^{DG} \cup B^{DL}$  and time-step  $t \in TS$ :

10.6.2.1 if *b* is in a region with a binding maximum restriction constraint, then *b* is exempt from the Conduct Test.

## 10.7 Constrained Area Conditions Test for Global Market Power (Operating Reserve)

10.7.1 A *resource* shall be subject to global market power mitigation testing for *operating reserve* if its *offers* for a class of *operating reserve* where the *locational marginal price* for that class of *operating reserve* is greater than  $ORGCondThresh$ .

10.7.2 Subject to section 10.7.3, if the condition in section 10.7.1 has been met for a class of *operating reserve*, then all *resources* with *offers* for classes of *operating reserve* that

can satisfy the requirements of that class of *operating reserve* shall be tested and for each  $b \in B^{DG} \cup B^{DL}$  and time-step  $t \in TS$ :

10.7.2.1 if  $L10SP_{t,b}^{PDP} > ORGCondThresh$ , the *pre-dispatch calculation engine* shall add *resource b* to  $BCond_t^{GMP10S}$ ;

10.7.2.2 if  $L10NP_{t,b}^{PDP} > ORGCondThresh$ , the *pre-dispatch calculation engine* shall add *resource b* to  $BCond_t^{GMP10N}$ ; and

10.7.2.2 if  $L30RP_{t,b}^{PDP} > ORGCondThresh$ , the *pre-dispatch calculation engine* shall add *resource b* to  $BCond_t^{GMP30R}$ .

10.7.3 If a *resource* is located in a region with a binding regional maximum constraint, then the *resource* shall not qualify for global market power mitigation testing for *operating reserve*:

10.7.3.1 if *b* is in a region with a binding maximum constraint, then *b* shall be exempt from the Conduct Test.

## 10.8 Outputs

10.8.1 Outputs of the Constrained Area Conditions Test include the list of *resources* that will be subject to the Conduct Test in section 11 and the thresholds that will be used in the Conduct Test for those *resources*.

# 11 Conduct Test

## 11.1 Purpose

11.1.1 The Conduct Test shall verify whether the *financial dispatch data parameter* values submitted by *registered market participants* for *resources* identified in section 10.8.1 are within the applicable threshold level of the *reference level values* for those *resources*.

## 11.2 Information, Sets, Indices and Parameters

11.2.1 Information, sets, indices and parameters for the Conduct Test are described in sections 3 and 4. In addition, the list of *resources* produced pursuant to section 10.8.1 shall be used by the Conduct Test.

## 11.3 Variables

11.3.1 The *pre-dispatch calculation engine* shall apply the Conduct Test set out in sections 11.4 and 11.5 to the *resources* identified by the Constrained Area Conditions Test in accordance with section 10.8, to identify the following data sets:

11.3.1.1 The sets of *resources* that failed the Conduct Test for at least one *financial dispatch data parameter*, where:

11.3.1.1.1  $BCT_t^{NCA}$  designates the *resources* in a *narrow constrained area* that failed the Conduct Test for at least one *financial dispatch data parameter* in time-step  $t \in TS$ ;

11.3.1.1.2  $BCT_t^{DCA}$  designates the *resources* in a *dynamic constrained area* that failed the Conduct Test for at least one *financial dispatch data parameter* in time-step  $t \in TS$ ;

11.3.1.1.3  $BCT_t^{BCA}$  designates the *resources* in a *broad constrained area* that failed the Conduct Test for at least one *financial dispatch data parameter* in time-step  $t \in TS$ ;

11.3.1.1.4  $BCT_t^{GMP}$  designates the *resources* that failed the global market power for *energy* Conduct Test for at least one *financial dispatch data parameter* in time-step  $t \in TS$ ;

11.3.1.1.5  $BCT_t^{ORL}$  designates the *resources* that failed the local market power for *operating reserve* Conduct Test for at least one *dispatch data parameter* in time-step  $t \in TS$ ; and

11.3.1.1.6  $BCT_t^{ORG}$  designates the *resources* that failed the global market power Conduct Test for *operating reserve* for at least one *financial dispatch data parameter* in time-step  $t \in TS$ .

11.3.1.2 The following *financial dispatch data parameters* for all time-steps  $t \in TS$ :

11.3.1.2.1  $PARAME_{t,b}$ , which designates the set of *dispatch data parameters* that failed the *energy* Conduct Test at bus  $b \in \{BCT_t^{NCA} \cup BCT_t^{DCA} \cup BCT_t^{BCA} \cup BCT_t^{GMP}\}$  in time-step  $t$ , and may include the following *financial dispatch data parameters*:

11.3.1.2.1.1  $EnergyOffer_k$ , which designates a non-zero quantity of *energy* above the *minimum*

*loading point* in association with *offer* lamination  $k \in K_{t,b}^E$  failed the Conduct Test;

- 11.3.1.2.2 For all hours prior to and including the last hour where conditions are met for the *energy* Conduct Test:
- 11.3.1.2.2.1 *EnergyToMLP<sub>k</sub>*, which designates the non-zero quantity of *energy* up to the *minimum loading point* in association with *offer* lamination  $k \in K_{t,b}^{LTMPL}$  failed the Conduct Test;
  - 11.3.1.2.2.2 *SUOffer*, which designates the *start-up offer* failed the Conduct Test; and
  - 11.3.1.2.2.3 *SNLOffer*, which designates the *speed no-load offer* failed the Conduct Test.
- 11.3.1.2.3 *PARAMOR<sub>t,b</sub>* designates the set of *financial dispatch data parameter* that failed the *operating reserve* Conduct Test for bus  $b \in \{BCT_t^{ORL} \cup BCT_t^{ORG}\}$  in time-step *t*, and may include the following *financial dispatch data parameter*:
- 11.3.1.2.3.1 *OR10SOffer<sub>k</sub>*, which designates the non-zero quantity of synchronized *ten-minute operating reserve* in association with *offer* lamination  $k \in K_{t,b}^{10S}$  failed the Conduct Test;
  - 11.3.1.2.3.2 *OR10NOffer<sub>k</sub>*, which designates the non-zero quantity of non-synchronized *ten-minute operating reserve* in association with *offer* lamination  $k \in K_{t,b}^{10N}$  failed the Conduct Test; and
  - 11.3.1.2.3.3 *OR30ROffer<sub>k</sub>*, which designates the non-zero quantity of *thirty-minute operating reserve* in association with *offer* lamination  $k \in K_{t,b}^{30R}$  failed the Conduct Test;
- 11.3.1.2.4 For all hours prior to and including the last hour where conditions are met for the *operating reserve* Conduct Test:
- 11.3.1.2.4.1 *SUOffer*, which designates the *start-up offer* failed the Conduct Test;

- 11.3.1.2.4.2 *SNLOffer*, which designates the *speed no-load offer* failed the Conduct Test; and
- 11.3.1.2.4.3 *EnergyToMLP<sub>k</sub>*, which designates the non-zero quantity of up to the *minimum loading point* in association with *offer* lamination  $k \in K_{t,b}^E$  failed the Conduct Test.

## 11.4 Conduct Test for Energy

11.4.1 The *pre-dispatch calculation engine* shall perform the Conduct Test for *energy* for *resources* in a *narrow constrained area* that were identified pursuant to section 10.8.1 as follows, subject to sections 11.4.2 and 11.4.3. For each time-step  $t \in TS$  and  $b \in BCond_t^{NCA}$ , the *pre-dispatch calculation engine* shall:

- 11.4.1.1 Evaluate *energy offers above minimum loading point*: For all  $k \in K_{t,b}^E$ , if  $PDG_{t,b,k} > \min(PDGRef_{t,b,k'} + (abs(PDGRef_{t,b,k'}) * CTEnThresh1^{NCA}), PDGRef_{t,b,k'} + CTEnThresh2^{NCA})$ , where  $k' \in K_{t,b}^E$ , then the Conduct Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{NCA}$  and add *EnergyOffer<sub>k</sub>* to  $PARAME_{t,b}$ ;
- 11.4.1.2 Evaluate *offers for energy* for the range of production up to *minimum loading point*: For all time-steps prior to and including the last time-step where conditions are met for the Constrained Area Conditions Test, for all  $k \in K_{t,b}^{LTMPLP}$ , if  $PLTMPLP_{t,b,k} > CTEnMinOffer$  and  $PLTMPLP_{t,b,k} > \min(PLTMPLPRef_{t,b,k'} + (abs(PLTMPLPRef_{t,b,k'}) * CTEnThresh1^{NCA}), PLTMPLPRef_{t,b,k'} + CTEnThresh2^{NCA})$ , where  $k' \in K_{t,b}^E$ , then the Conduct Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{NCA}$  and add *EnergyToMLP<sub>k</sub>* to  $PARAME_{t,b}$  and  $PARAMOR_{t,b}$ ;
- 11.4.1.3 Evaluate *start-up offers*: For all time-steps prior to and including the last time-step  $t$  where conditions are met for the Constrained Area Conditions Test in section 10, if  $SUDG_{t,b} > SUDGRef_{t,b} + (abs(SUDGRef_{t,b}) * CTSUThresh^{NCA})$ , then the Conduct Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{NCA}$  and add *SUOffer* to  $PARAME_{t,b}$  and  $PARAMOR_{t,b}$ ; and
- 11.4.1.4 Evaluate *speed no-load offers*: For all time-steps prior to and including the last time-step where conditions are met for the Constrained Area Conditions Test, if  $SNL_{t,b} > SNLRef_{t,b} + (abs(SNLRef_{t,b}) * CTSNLThresh^{NCA})$ , then the Conduct Test was failed by the *resource* at

bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{NCA}$  and add  $SNLOffer$  to  $PARAME_{t,b}$  and  $PARAMOR_{t,b}$ .

- 11.4.2 For *resources* identified pursuant to section 10.8.1 in a *dynamic constrained area* or broad constrained area, the *pre-dispatch calculation engine* shall use the steps in section 11.4.1, using *resources* in  $BCond_t^{DCA}$  or  $BCond_t^{BCA}$ , as the case may be, in place of  $BCond_t^{NCA}$  and using the applicable Conduct Test thresholds  $CTEnThresh1^{DCA}$ ,  $CTEnThresh2^{DCA}$ ,  $CTEnThresh1^{BCA}$ ,  $CTEnThresh2^{BCA}$ ,  $CTSUThresh^{DCA}$ ,  $CTSUThresh^{BCA}$ ,  $CTSNTLThresh^{DCA}$ ,  $CTSNTLThresh^{BCA}$ . If any of the *financial dispatch data parameters* of a *resource* fail the Conduct Test, the *resource* shall be assigned to subset  $BCT_h^{DCA}$  or  $BCT_h^{BCA}$ , as the case may be.
- 11.4.3 For *resources* identified pursuant to section 10.8.1 that were selected for global market power mitigation testing for *energy*, the *pre-dispatch calculation engine* shall use the steps in section 11.4.1, using *resources* in  $BCond_t^{GMP}$  in place of  $BCond_t^{NCA}$  and the applicable global market power Conduct Test thresholds  $CTEnThresh1^{GMP}$ ,  $CTEnThresh2^{GMP}$ ,  $CTSUThresh^{GMP}$ ,  $CTSNTLThresh^{GMP}$ . If any of the applicable *financial dispatch data parameters* of a *resource* fails the Conduct Test, the *resource* shall be assigned to subset  $BCT_h^{GMP}$ .
- 11.4.4 If a *resource* is assigned to more than one of the sets,  $BCond_t^{NCA}$ ,  $BCond_t^{DCA}$ ,  $BCond_t^{BCA}$ , and  $BCond_t^{GMP}$ , only the Conduct Test with the most restrictive threshold levels shall be performed for that *resource*.

## 11.5 Conduct Test for Operating Reserve

- 11.5.1 The *pre-dispatch calculation engine* shall perform the Conduct Test for local market power for *operating reserve* for *resources* that were identified pursuant to section 10.8.1, as follows, subject to 11.5.3. For each time-step  $t \in TS$  and  $b \in BCond_t^{10S} \cup BCond_t^{10N} \cup BCond_t^{80R}$ , the *pre-dispatch calculation engine* shall:

11.5.1.1 Evaluate *offers* for *operating reserve* as follows:

- 11.5.1.1.1 for all  $k \in K_{t,b}^{10S}$  such that  $P10SDG_{t,b,k} > CTORMinOffer$  and  $P10SDG_{t,b,k} > \min(P10SDGRef_{t,b,k} + (abs(P10SDGRef_{t,b,k}) * CTORThresh1^{ORL}), P10SDGRef_{t,b,k} + CTORThresh2^{ORL})$ , where  $k' \in K_{h,b}^{10S}$ , then the Conduct Test was failed for the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{ORL}$  and add  $OR10SOffer_k$  to  $PARAMOR_{t,b}$ ;
- 11.5.1.1.2 for all  $k \in K_{t,b}^{10N}$  such that  $P10NDG_{t,b,k} > CTORMinOffer$  and

$P10NDG_{t,b,k} > \min(P10NDGRef_{t,b,k} + (abs(P10NDGRef_{t,b,k}) * CTORThresh1^{ORL}), P10NDGRef_{t,b,k} + CTORThresh2^{ORL})$ , where  $k' \in K_{h,b}^{10N}$ , then the Conduct Test was failed for the resource at bus  $b$  and the pre-dispatch calculation engine shall assign the resource to subset  $BCT_t^{ORL}$  and add  $OR10NOffer_k$  to  $PARAMOR_{t,b}$ ;

11.5.1.1.3 for all  $k \in K_{t,b}^{30R}$  such that  $P30RDG_{t,b,k} > CTORMinOffer$  and  
 $P30RDG_{t,b,k} > \min(P30RDGRef_{t,b,k} + (abs(P30RDGRef_{t,b,k}) * CTORThresh1^{ORL}), P30RDGRef_{t,b,k} + CTORThresh2^{ORL})$ , where  $k' \in K_{h,b}^{30R}$ , then the Conduct Test was failed for the resource at bus  $b$  and the pre-dispatch calculation engine shall assign the resource to subset  $BCT_t^{ORL}$  and add  $OR30ROffer_k$  to  $PARAMOR_{t,b}$ ;

11.5.1.1.4 for all  $j \in J_{t,b}^{10S}$  if  $P10SDL_{t,b,j} > CTORMinOffer$  and  
 $P10SDL_{t,b,j} > \min(P10SDLRef_{t,b,j} + (abs(P10SDLRef_{t,b,j}) * CTORThresh1^{ORL}), P10SDLRef_{t,b,j} + CTORThresh2^{ORL})$ , where  $j' \in J_{t,b}^{10S}$ , then the Conduct Test was failed for the dispatchable load at bus  $b$  and the day-ahead market calculation engine shall assign the resource to subset  $BCT_t^{ORL}$  and add  $OR10SOffer_k$  to  $PARAMOR_{t,b}$ ;

11.5.1.1.5 for all  $j \in J_{t,b}^{10N}$  if  $P10NDL_{t,b,j} > CTORMinOffer$  and  
 $P10NDL_{t,b,j} > \min(P10NDLRef_{t,b,j} + (abs(P10NDLRef_{t,b,j}) * CTORThresh1^{ORL}), P10NDLRef_{t,b,j} + CTORThresh2^{ORL})$ , where  $j' \in J_{t,b}^{10N}$ , then the Conduct Test was failed for the dispatchable load at bus  $b$  and the day-ahead market calculation engine shall assign the resource to subset  $BCT_t^{ORL}$  and add  $OR10NOffer_k$  to  $PARAMOR_{t,b}$ ; and

11.5.1.1.6 for all  $j \in J_{t,b}^{30R}$  if  $P30RDL_{t,b,j} > CTORMinOffer$  and  
 $P30RDL_{t,b,j} > \min(P30RDLRef_{t,b,j} + (abs(P30RDLRef_{t,b,j}) * CTORThresh1^{ORL}), P30RDLRef_{t,b,j} + CTORThresh2^{ORL})$ , where  $j' \in J_{t,b}^{30R}$ , then the Conduct Test was failed for the dispatchable load at bus  $b$  and the day-ahead market calculation engine shall



assign the *resource* to subset  $BCT_t^{ORL}$  and add  $OR30ROffer_k$  to  $PARAMOR_{t,b}$ ;

- 11.5.1.2 Evaluate *start-up offers*: For all time-steps prior to and including the last time-step where conditions are met for the Constrained Area Conditions Test, if  $SUDG_{t,b} > SUDGRef_{t,b} + (abs(SUDGRef_{t,b}) * CTSUThresh^{ORL})$ , then the Conduct Test failed for the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{ORL}$  and add  $SUOffer$  to  $PARAMOR_{t,b}$  and  $PARAME_{t,b}$ ;
- 11.5.1.3 Evaluate *speed no-load offers*: For all time-steps prior to and including the last time-step where conditions are met for the Constrained Area Conditions Test, if  $SNL_{t,b} > SNLRef_{t,b} + (abs(SNLRef_{t,b}) * CTSNLThresh^{ORL})$ , then the Conduct Test was failed for the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{ORL}$  and add  $SNLOffer$  to  $PARAMOR_{t,b}$  and  $PARAME_{t,b}$ ; and
- 11.5.1.4 Evaluate *offers for energy* for the range of production up to the *minimum loading point*: For all time-steps prior to and including the last time-step where conditions are met for the Constrained Area Conditions Test, for all  $k \in K_{t,b}^{LTMLP}$ , if  $PLTMLP_{t,b,k} > \min(PLTMLPRef_{t,b,k} + (abs(PLTMLPRef_{t,b,k}) * CTEntThresh1^{ORL}), PLTMLPRef_{t,b,k} + CTEntThresh2^{ORL})$ , where  $k' \in K_{t,b}^{LE}$ , then the Conduct Test was failed for the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BCT_t^{ORL}$  and add  $EnergyToMLP_k$  to  $PARAMOR_{t,b}$  and  $PARAME_{t,b}$ .

11.5.2 The *pre-dispatch calculation engine* shall perform the Conduct Test for global market power for *operating reserve* for *resources* that were identified pursuant to section 10.8.1. The *pre-dispatch calculation engine* shall use the steps set out in section 11.5.1 using *resources* in  $BCond_t^{GMP10S}$ ,  $BCond_t^{GMP10N}$ , and  $BCond_t^{GMP30R}$  in place of  $BCond_t^{10S}$ ,  $BCond_t^{10N}$ , and  $BCond_t^{30R}$ , respectively, and the applicable Conduct Test thresholds ( $CTORThresh1^{ORG}$ ,  $CTORThresh2^{ORG}$ ,  $CTSUThresh^{ORG}$ ,  $CTSNLThresh^{ORG}$ ,  $CTEnThresh1^{ORG}$ ,  $CTEnThresh2^{ORG}$ ). The *resources* shall be assigned to the subset  $BCT_h^{ORG}$ .

11.5.3 If a *resource* is assigned to more than one of  $BCond_t^{GMP10S}$ ,  $BCond_t^{GMP10N}$ , and  $BCond_t^{GMP30R}$ , only the Conduct Test with the most restrictive threshold levels shall be performed for that *resource*.

## 11.6 Outputs

11.6.1 Subject to section 11.6.2, the outputs of the Conduct Test shall include the following for each time-step  $t \in TS$ :

- 11.6.1.1 The set of *resources* that failed the Conduct Test for at least one *financial dispatch data parameter* by condition type;
- 11.6.1.2 The *financial dispatch data parameters* that failed the Conduct Test for the *resource* at bus *b*; and
- 11.6.1.3 A revised set of *financial dispatch data parameters* replaced with *reference level values* for *resources* that:
  - 11.6.1.3.1 has one or more *financial dispatch data parameters* that failed a Conduct Test for the current *pre-dispatch calculation engine* run; and
  - 11.6.1.3.2 has one or more *financial dispatch data parameters* that failed both the Conduct Test and failed the Price Impact Test in previous *pre-dispatch calculation engine* runs.
- 11.6.1.4 For *offers* for *energy* and *operating reserve* with multiple laminations:
  - 11.6.1.4.1 if the *offer* lamination for *energy* that corresponds to the *minimum loading point* fails the Conduct Test, the *pre-dispatch calculation engine* shall replace all *offer* laminations for *energy* up to the *minimum loading point*;
  - 11.6.1.4.2 if one or more offer laminations for *energy* above the *minimum loading point* fails the Conduct Test, the *pre-dispatch calculation engine* shall replace all *offer* laminations for *energy* up to and above the *minimum loading point*; and
  - 11.6.1.4.3 if one or more *offer* laminations for *operating reserve* fails the Conduct Test, the *pre-dispatch calculation engine* shall replace all *offer* laminations for *operating reserve*.
- 11.6.1.5 For a *non-quick start resource* whose *start-up offer* failed the Conduct Test, identified in section 11.6.1.1, the *pre-dispatch calculation engine* shall use the *start-up offer reference level value* to evaluate any advancements pursuant to section 5.7.
- 11.6.2 The *pre-dispatch calculation engine* shall not replace the *financial dispatch data parameter* for a *resource* with that *resource's* applicable *reference level value* if the *financial dispatch data parameter* is less than the corresponding *reference level value*.

# 12 Reference Level Scheduling

## 12.1 Purpose

- 12.1.1 The *pre-dispatch calculation engine* shall perform the Reference Level Scheduling algorithm where at least one *financial dispatch data parameter* for a *resource* failed the Conduct Test in section 11.
- 12.1.2 The Reference Level Scheduling algorithm shall perform a *security*-constrained unit commitment and economic *dispatch* to maximize gains from trade using *dispatch data* submitted by *registered market participants*, including *reference level value* for *resources* subject to 14.7.1.3 and 12.2.2, to meet the *IESO*'s province-wide non-*dispatchable demand* forecast and *IESO*-specified *operating reserve* requirements for each hour of the pre-dispatch look-ahead period.

## 12.2 Information, Sets, Indices and Parameters

- 12.2.1 Information, sets, indices and parameters used by the Reference Level Scheduling algorithm are described in section 3 and section 4. In addition, the list of *resources* that failed the Conduct Test from section 11.6.1.1 and a revised set of *financial dispatch data parameters* from section 11.6.1.3, for those *resources* shall be used by the Reference Level Scheduling algorithm
- 12.2.2 The Reference Level Scheduling algorithm shall use the *reference level value* that corresponds to any *financial dispatch data parameter* submitted for a *resource* that failed the Conduct Test.

## 12.3 Variables and Objective Function

- 12.3.1 The *pre-dispatch calculation engine* shall solve for the variables listed in section 8.3.1.
- 12.3.2 The objective function for the Reference Level Scheduling algorithm shall be the same as the objective function in section 8.3.2, subject to section 12.4.

## 12.4 Constraints

- 12.4.1 The constraints in sections 8.4 through 8.7 apply in the Reference Level Scheduling algorithm, except that the sensitivities and limits considered for *IESO* internal transmission limits shall be those provided by the most recent *security* assessment function iteration of the Reference Level Scheduling algorithm.

## 12.5 Outputs

- 12.5.1 Outputs of the Reference Level Scheduling algorithm include *resource* schedules and commitments.

# 13 Reference Level Pricing

## 13.1 Purpose

- 13.1.1 The *pre-dispatch calculation engine* shall perform the Reference Level Pricing algorithm whenever the Reference Level Scheduling algorithm has been performed.
- 13.1.2 The Reference Level Pricing algorithm shall perform a *security-constrained economic dispatch* to maximize gains from trade using *dispatch data* submitted by *registered market participants*, *reference level value* for *resources* subject to 14.7.1.3 and 13.2.2, and *resource* schedules and commitments produced by the Reference Level Scheduling algorithm, to meet the *IESO's* province-wide *non-dispatchable demand* forecast and *IESO-specified operating reserve* requirements for each hour of the pre-dispatch look-ahead period.

## 13.2 Information, Sets, Indices and Parameters

- 13.2.1 Information, sets, indices and parameters used by the Reference Level Pricing algorithm are described in sections 3 and 4. In addition, the following *resource* schedule and commitments from the Reference Level Scheduling algorithm shall be used by the Reference Level Pricing algorithm:
- 13.2.1.1  $SDG_{t,b,k}^{RLS}$ , which designates the amount of *energy* that a *dispatchable generation resource* is scheduled to provide above  $MinQDGC_b$  at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^E$ ;
- 13.2.1.2  $ODG_{t,b}^{RLS}$ , which designates whether a *dispatchable generation resource* at bus  $b \in B^{DG}$  was scheduled at or above its *minimum loading point* in time-step  $t \in TS$ ;
- 13.2.1.3  $S10SDG_{t,b,k}^{RLS}$ , which designates the amount of synchronized *ten-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{AOS}$ ;
- 13.2.1.4  $S10NDG_{t,b,k}^{RLS}$ , which designates the amount of non-synchronized *ten-minute operating reserve* that a *dispatchable generation resource* is scheduled to

provide at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{10N}$ ;

13.2.1.5  $SDG_{t,b,k}^{RLS}$ , which designates the amount of *thirty-minute operating reserve* that a *dispatchable generation resource* is scheduled to provide at bus  $b \in B^{ELR} \cup B^{HE}$  in time-step  $t \in TS$  in association with lamination  $k \in K_{t,b}^{30R}$ , and

13.2.1.6  $OHO_{t,b}^{RLS}$ , which designates whether the *dispatchable hydroelectric generation resource* at bus  $b \in B^{HE}$  has been scheduled at or above  $MinHO_{t,b}$  in time-step  $t \in TS$ .

13.2.2 The Reference Level Pricing algorithm shall use a *resource's reference level value* for any *financial dispatch data parameters* submitted by *registered market participants* that failed the Conduct Test in Section 11.

### 13.3 Variables and Objective Function

13.3.1 The *pre-dispatch calculation engine* shall solve for the variables set out in section 9.3.1.

13.3.2 The objective function used in the Reference Level Pricing algorithm shall be the same as the objective function set out in section 9.3.2, subject to section 13.4.

### 13.4 Constraints

13.4.1 The constraints that apply in the Reference Level Pricing algorithm shall be the same as the constraints in sections 9.4 through 9.8, with the following exceptions:

13.4.1.1 the marginal loss factors used in the *energy balance constraint* in section 9.7.1 shall be fixed to the marginal loss factors used in the last optimization function iteration of the Reference Level Scheduling algorithm;

13.4.1.2 the sensitivities and limits in section 9.7.3 shall be replaced with the most recent *security assessment function* iteration of the Reference Level Pricing algorithm; and

13.4.1.3 for the constraints in section 9.8, the outputs from the Pre-Dispatch Scheduling algorithm shall be replaced with the outputs from the Reference Level Scheduling algorithm as follows:

13.4.1.3.1  $SDG_{t,b,k}^{PDS}$  shall be replaced by  $SDG_{t,b,k}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{ELR} \cup B^{HE}$ ,  $k \in K_{t,d}^E$ ;

13.4.1.3.2  $ODG_{t,b}^{PDS}$  shall be replaced by  $ODG_{t,b}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{DG}$ ;

13.4.1.3.3  $IDG_{t,b}^{PDS}$  shall be replaced by  $IDG_{t,b}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{DG}$ ;

13.4.1.3.4  $S10SDG_{t,b,k}^{PDS}$  shall be replaced by  $S10SDG_{t,b,k}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{ELR} \cup B^{HE}$ ,  $k \in K_{t,b}^{10S}$ ;

13.4.1.3.5  $S10NDG_{t,b,k}^{PDS}$  shall be replaced by  $S10NDG_{t,b,k}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{ELR} \cup B^{HE}$ ,  $k \in K_{t,b}^{10N}$ ;

13.4.1.3.6  $S30RDG_{t,b,k}^{PDS}$  shall be replaced by  $S30RDG_{t,b,k}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{ELR} \cup B^{HE}$ ,  $k \in K_{t,b}^{30R}$ ; and

13.4.1.3.7  $OHO_{t,b}^{PDS}$  shall be replaced by  $OHO_{t,b}^{RLS}$  for all  $t \in TS$ ,  $b \in B^{HE}$ .

## 13.5 Outputs

13.5.1 Outputs of the Reference Level Pricing algorithm include the following:

13.5.1.1 shadow prices; and

13.5.1.2 *locational marginal prices* and their components.

# 14 Price Impact Test

## 14.1 Purpose

14.1.1 The *pre-dispatch calculation engine* shall perform the Price Impact Test whenever at least one *financial dispatch data parameter* for a *resource* failed the Conduct Test.

14.1.2 The Price Impact Test shall:

14.1.2.1 compare the *locational marginal prices* for *energy* or *operating reserve* produced by the Pre-Dispatch Pricing algorithm with those produced by the Reference Level Pricing algorithm; and

14.1.2.2 consider the corresponding *offer* parameters to have failed the price impact test if the difference in price in section 14.1.2.1 is greater than the applicable impact threshold in section 4.3.9.

## 14.2 Information, Sets, Indices and Parameters

- 14.2.1 Information, sets, indices and parameters for the Price Impact Test are described in sections 3 and 4. In addition, the following *locational marginal prices* from the Pre-Dispatch Pricing algorithm and the Reference Level Pricing algorithm shall be used:
- 14.2.1.1  $LMP_{t,b}^{DDP}$ , which designates the *locational marginal price for energy* at bus  $b \in B$  in time-step  $t \in TS$  from the Pre-Dispatch Pricing algorithm;
  - 14.2.1.2  $L30RP_{t,b}^{DDP}$ , which designates the *locational marginal price for thirty-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$  from the Pre-Dispatch Pricing algorithm;
  - 14.2.1.3  $L10NP_{t,b}^{DDP}$ , which designates the *locational marginal price for non-synchronized ten-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$  from the Pre-Dispatch Pricing algorithm;
  - 14.2.1.4  $L10SP_{t,b}^{DDP}$ , which designates the *locational marginal price for synchronized ten-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$  from the Pre-Dispatch Pricing algorithm;
  - 14.2.1.5  $LMP_{t,b}^{RLP}$ , which designates the *locational marginal price for energy* at bus  $b \in B$  in time-step  $t \in TS$  from the Reference Level Pricing algorithm;
  - 14.2.1.6  $L30RP_{t,b}^{RLP}$ , which designates the *locational marginal price for thirty-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$  from the Reference Level Pricing algorithm;
  - 14.2.1.7  $L10NP_{t,b}^{RLP}$ , which designates the *locational marginal price for non-synchronized ten-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$  from the Reference Level Pricing algorithm; and
  - 14.2.1.8  $L10SP_{t,b}^{RLP}$ , which designates the *locational marginal price for synchronized ten-minute operating reserve* at bus  $b \in B$  in time-step  $t \in TS$  from the Reference Level Pricing algorithm.

## 14.3 Variables

- 14.3.1 The *pre-dispatch calculation engine* shall apply the Price Impact Test as set out in sections 14.4 and 14.5 for the *resources* identified in accordance with section 10.3.1, to identify:
- 14.3.1.1 A set of *resources* that failed the Price Impact Test for each condition for all time-steps  $t \in TS$ , where:

- 14.3.1.1.1  $BIT_t^{NCA}$  designates the *resources* in a *narrow constrained area* that failed the Price Impact Test for the *locational marginal price* for *energy*;
  - 14.3.1.1.2  $BIT_t^{DCA}$  designates the *resources* in a *dynamic constrained area* that failed the Price Impact Test for *energy locational marginal price*;
  - 14.3.1.1.3  $BIT_t^{BCA}$  designates the *resources* in a *broad constrained area* that failed Price Impact Test for *energy locational marginal price*;
  - 14.3.1.1.4  $BIT_t^{GMP}$  designates the *resources* that failed the Global Market Power (*energy*) Price Impact Test for *energy locational marginal price*;
  - 14.3.1.1.5  $BIT_t^{ORL}$  designates the *resources* that failed the Local Market Power (*operating reserve*) Price Impact Test for at least one type of *operating reserve locational marginal price*;
  - 14.3.1.1.6  $BIT_t^{ORG}$  designates the *resources* that failed the Global Market Power (*operating reserve*) Price Impact Test for at least one type of *operating reserve locational marginal price*; and
  - 14.3.1.1.7  $LMPIT_{t,b}$  designates the *locational marginal price* that failed the Price Impact Test for bus  $b \in BIT_t^{NCA} \cup BIT_t^{DCA} \cup BIT_t^{BCA} \cup BIT_t^{GMP} \cup BIT_t^{ORL} \cup BIT_t^{ORG}$  in time-step  $t \in TS$  and
- 14.3.1.2 *Locational marginal prices* for *energy* and *operating reserve* for each *resource* at bus  $b \in B^{DG} \cup B^{DL}$  that failed the Price Impact Test, where:
- 14.3.1.2.1  $EnergyLMP$  designates that the *locational marginal price* for *energy* failed the Price Impact Test;
  - 14.3.1.2.2  $OR10SLMP$  designates that the *synchronized ten-minute operating reserve locational marginal price* failed the Price Impact Test;
  - 14.3.1.2.3  $OR10NLMP$  designates that the *non-synchronized ten-minute operating reserve locational marginal price* failed the Price Impact Test; and



- 14.3.1.2.4 *OR30RLMP* designates that the *thirty-minute operating reserve locational marginal price* failed the Price Impact Test.

## 14.4 Price Impact Test for Energy

14.4.1 The *pre-dispatch calculation engine* shall perform the Price Impact Test for *resources* that were identified in the corresponding Conduct Test for *energy* in section 11.6.1.1, as follows:

14.4.1.1 For local market power for *energy*:

14.4.1.1.1 For each time-step  $t \in TS$  and  $b \in BCT_t^{NCA}$ , if  $LMP_{t,b}^{PDP} > \min(LMP_{t,b}^{RLP} + (abs(LMP_{t,b}^{RLP}) * ITThresh1^{NCA}), LMP_{t,b}^{RLP} + ITThresh2^{NCA})$ , the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{NCA}$  and add *EnergyLMP* to  $LMPIT_{t,b}$ ;

14.4.1.1.2 For each time-step  $t \in TS$  and  $b \in BCT_t^{DCA}$ , if  $LMP_{t,b}^{PDP} > \min(LMP_{t,b}^{RLP} + (abs(LMP_{t,b}^{RLP}) * ITThresh1^{DCA}), LMP_{t,b}^{RLP} + ITThresh2^{DCA})$ , the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{DCA}$  and add *EnergyLMP* to  $LMPIT_{t,b}$ ; and

14.4.1.1.3 For each time-step  $t \in TS$  and  $b \in BCT_t^{BCA}$ , if  $LMP_{t,b}^{PDP} > \min(LMP_{t,b}^{RLP} + (abs(LMP_{t,b}^{RLP}) * ITThresh1^{BCA}), LMP_{t,b}^{RLP} + ITThresh2^{BCA})$ , the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{BCA}$  and add *EnergyLMP* to  $LMPIT_{t,b}$ ; and

14.4.1.2 For global market power for *energy*:

14.4.1.2.1 For each time-step  $t \in TS$  and  $b \in BCT_t^{GMP}$ , if  $LMP_{t,b}^{PDP} > \min(LMP_{t,b}^{RLP} + (abs(LMP_{t,b}^{RLP}) * ITThresh1^{GMP}), LMP_{t,b}^{RLP} + ITThresh2^{GMP})$ , the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{GMP}$  and add *EnergyLMP* to  $LMPIT_{t,b}$ .

## 14.5 Price Impact Test for Operating Reserve

14.5.1 The *pre-dispatch calculation engine* shall perform the Price Impact Test for *resources* that were identified in the corresponding Conduct Test for *operating reserve* in section 11.6.1.1, as follows:

14.5.1.1 For local market power for *operating reserve*, for each time-step  $t \in TS$  and  $b \in BCT_t^{ORL}$ :

14.5.1.1.1 If  $L30RP_{t,b}^{DDP} > L30RP_{t,b}^{RLP}$ , then the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{ORL}$  and add  $OR30RLMP$  to  $LMPIT_{t,b}$ ;

14.5.1.1.2 If  $L10NP_{t,b}^{DDP} > L10NP_{t,b}^{RLP}$ , then the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{ORL}$  and add  $OR10NLMP$  to  $LMPIT_{t,b}$ ; and

14.5.1.1.3 If  $L10SP_{t,b}^{DDP} > L10SP_{t,b}^{RLP}$ , then the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{ORL}$  and add  $OR10SLMP$  to  $LMPIT_{t,b}$ ; and

14.5.1.2 For global market power for *operating reserve*, for each time-step  $t \in TS$  and  $b \in BCT_t^{ORG}$ :

14.5.1.2.1 If  $L30RP_{t,b}^{DDP} > \min(L30RP_{t,b}^{RLP} + (abs(L30RP_{t,b}^{RLP}) * ITThresh1^{ORG}), L30RP_{t,b}^{RLP} + ITThresh2^{ORG})$ , then the Price Impact Test was failed by *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{ORG}$  and add  $OR30RLMP$  to  $LMPIT_{t,b}$ ;

14.5.1.2.2 If  $L10NP_{t,b}^{DDP} > \min(L10NP_{t,b}^{RLP} + (abs(L10NP_{t,b}^{RLP}) * ITThresh1^{ORG}), L10NP_{t,b}^{RLP} + ITThresh2^{ORG})$ , then the Price Impact Test was failed by the *resource* at bus  $b$  and the *pre-dispatch calculation engine* shall assign the *resource* to subset  $BIT_t^{ORG}$  and add  $OR10NLMP$  to  $LMPIT_{t,b}$ ; and

14.5.1.2.3 If  $L10SP_{t,b}^{DDP} > \min(L10SP_{t,b}^{RLP} + (abs(L10SP_{t,b}^{RLP}) * ITThresh1^{ORG}), L10SP_{t,b}^{RLP} + ITThresh2^{ORG})$ , then the Price Impact Test was failed by the *resource* at bus  $b$  and

the *pre-dispatch calculation engine* shall assign resource to subset  $BIT_t^{ORG}$  and add  $OR10SLMP$  to  $LMPIT_{t,b}$ .

## 14.6 Revised Financial Dispatch Data Parameter Determination

- 14.6.1 A resource that fails the Price Impact Test in a time-step ( $t$ ) shall have its *financial dispatch data parameters* revised as follows:
- 14.6.1.1 If the resource has failed a Price Impact Test for energy and is in  $BIT_t^{NCA}$ ,  $BIT_t^{DCA}$ ,  $BIT_t^{BCA}$ ,  $BIT_t^{GMP}$ , the *financial dispatch data parameters* in  $PARAME_{t,b}$  shall be used to determine the *financial dispatch data parameters* that shall be replaced with the resource's applicable reference level value.
  - 14.6.1.2 If the resource has failed a Price Impact Test for operating reserve and is in  $BIT_t^{ORL}$  or  $BIT_t^{ORG}$ , the *financial dispatch data parameters* in  $PARAMOR_{t,b}$  shall be used to determine the *financial dispatch data parameters* that shall be replaced with the resource's applicable reference level value.
  - 14.6.1.3 If a non-quick-start resource has failed a Price Impact Test in any time-step, the *commitment cost parameters* (start-up offer, speed-no-load offer, or energy offer associated with the minimum loading point) that failed the corresponding Conduct Test shall be replaced with the resource's applicable reference level value for that time-step. For any time-steps prior, any *commitment cost parameters* for that resource that failed the Conduct Test shall be replaced with the resource's applicable reference level value in those time-steps. This is expressed as:
    - 14.6.1.3.1 For each time-step  $t \in TS$  and all  $b \in B^{NQS} \cap (BIT_t^{NCA} \cup BIT_t^{DCA} \cup BIT_t^{BCA} \cup BIT_t^{GMP})$ , for hours prior to and including the hour that failed the Price Impact Test,  $T \in \{1, \dots, t\}$ , if  $b \in BCT_T^{NCA} \cup BCT_T^{DCA} \cup BCT_T^{BCA} \cup BCT_T^{GMP}$  and  $PARAME_{T,b}$  contains any of the *commitment cost parameters*  $SUOffer$ ,  $SNLOffer$ , or  $EnergyToMLP_k$ , replace these parameters with reference level values.
  - 14.6.1.4 Section 14.6.1.3 shall apply to the tests for local market power and global market power for operating reserve, except  $PARAMOR_{T,b}$  shall be checked in place of  $PARAME_{T,b}$ .
  - 14.6.1.5 If a resource is in a narrow constrained area or a dynamic constrained area and has failed a Price Impact Test, each resource in the same narrow constrained area or dynamic constrained area that also failed the

corresponding Conduct Test shall have its *offer* data replaced with its applicable *reference level value* for that hour. For each time-step  $t \in TS$ :

- 14.6.1.5.1 if  $BIT_t^{NCA}$  includes one or more *resources* in a *narrow constrained area, n*, each *resource*  $b \in BCT_t^{NCA}$  for *narrow constrained area, n*, shall have the parameters in  $PARAME_{t,b}$  replaced with its *reference level values*; and
  - 14.6.1.5.2 if  $BIT_t^{DCA}$  includes one or more *resources* in a *dynamic constrained area, d*, each *resource*  $b \in BCT_t^{DCA}$  for *dynamic constrained area, d*, shall have the parameters in  $PARAME_{t,b}$  replaced with its *reference level values*.
- 14.6.1.6 If a *non-quick-start resource* in a *narrow constrained area* or a *dynamic constrained area* has failed a Price Impact Test, each *non-quick-start resource* in the *narrow constrained area* or *dynamic constrained area* that also failed the corresponding Conduct Test shall have its commitment cost parameters replaced with its applicable *reference level value* for that time-step. For any time-steps prior, if a *non-quick-start resource* in that *narrow constrained area* or *dynamic constrained area* has a commitment cost parameter that failed the Conduct Test, that commitment cost parameter shall be replaced with the *resource's* applicable *reference level value* in those time-steps. This is expressed as:
- 14.6.1.6.1 For all time-steps up to the time-step in which a *resource* failed the Price Impact Test for a *narrow constrained area*, for all  $b \in BCT_t^{NCA}$ , if  $PARAME_{t,b}$  contains any of the *commitment cost parameters*  $SUOffer$ ,  $SNLOffer$ , or  $EnergyToMLP_k$ , replace these parameters with *reference level values*.
  - 14.6.1.6.2 For all time-steps up to the time-step in which a *resource* failed the Price Impact Test for a *dynamic constrained area*, for all  $b \in BCT_t^{DCA}$ , if  $PARAME_{t,b}$  contains any of the *commitment cost parameters*  $SUOffer$ ,  $SNLOffer$ , or  $EnergyToMLP_k$ , replace these parameters with *reference level values*.
- 14.6.1.7 If a *resource* fails the local market power for *operating reserve* Price Impact Test, all *resources* in the same *operating reserve* region with a non-zero *operating reserve* minimum requirement that failed the corresponding Conduct Test for at least one parameter shall have the parameter that failed the Conduct Test replaced with the *resource's* applicable *reference level value* for that hour. This is expressed as:

- 14.6.1.7.1 For each time-step  $t \in TS$ , if  $BIT_t^{ORL}$  includes one or more resource in operating reserve region,  $r$ , all resources,  $b \in BIT_t^{ORL}$  for operating reserve region  $r$ , shall have the parameters in  $PARAMOR_{t,b}$  replaced with reference level values.
- 14.6.1.8 If a non-quick-start resource fails the local market power for operating reserve Price Impact Test in any time-step, the commitment cost parameters for all non-quick-start resources in the same operating reserve region with a non-zero operating reserve minimum requirement that failed the corresponding Conduct Test shall be replaced with the resource's applicable reference level value for that time-step. For any time-steps prior, any commitment cost parameters of non-quick-start resources that failed the Conduct Test shall be replaced with the resource's applicable reference level value in those time-steps. This is expressed as:
  - 14.6.1.8.1 For all time-steps up to the time-step in which a resource failed the Price Impact Test for  $r$ , for all  $b \in BCT_t^{ORL}$ , if  $PARAME_{t,b}$  contains any of the commitment cost parameters  $SUOffer$ ,  $SNLOffer$ , or  $EnergyToMLP_k$ , replace these parameters with reference level values.

## 14.7 Outputs

- 14.7 The pre-dispatch calculation engine shall prepare the following outputs, subject to section 14.7.2, for each time-step  $t \in TS$ :
  - 14.7.1.1 The set of resources that failed the Price Impact Test for all time-steps in the pre-dispatch look ahead period, by condition, in accordance to sections 14.4 and 14.5. Those resources shall be added to the accumulated set of resources from previous pre-dispatch calculation engine runs which failed the Price Impact Test in the current time-step  $t \in TS$ ;
  - 14.7.1.2 The locational marginal prices for energy and operating reserve that failed the Price Impact Test for each resource at bus  $b$  in accordance to sections 14.4 and 14.5;
  - 14.7.1.3 A revised set of offer data to be used by the next pre-dispatch calculation engine run and next real-time hour. The revised set of offer data will be for the resources that failed the Price Impact Test:
    - 14.7.1.3.1 in current pre-dispatch calculation engine run replacing offer data that failed the Conduct Test with the applicable reference level values, in accordance with section 14.6; and

14.7.1.3.2 in previous *pre-dispatch calculation engine* runs with *financial dispatch data parameters* that were decided to be mitigated in previous *pre-dispatch calculation engine* runs replaced with *reference level values*.

14.7.2 The *pre-dispatch calculation engine* shall not replace *financial dispatch data parameters* from a *resource* with that *resource's* applicable *reference level value* if the *financial dispatch data parameters* is less than the *reference level value*.

## 15 Pseudo-Unit Modelling

### 15.1 Pseudo-Unit Model Parameters

15.1.1 The *pre-dispatch calculation engine* shall use the following registration and daily *dispatch data* to determine the underlying relationship between a *pseudo-unit* and the associated physical *resources* for a *combined cycle plant* with  $K$  combustion turbine *resources* and one steam turbine *resource*:

15.1.1.1  $CMCR_k$  designates the registered *maximum continuous rating* of combustion turbine *resource*  $k \in \{1, \dots, K\}$  in MW;

15.1.1.2  $CMLP_k$  designates the *minimum loading point* of combustion turbine *resource*  $k \in \{1, \dots, K\}$  in MW;

15.1.1.3  $SMCR$  designates the registered *maximum continuous rating* of the steam turbine *resource* in MW;

15.1.1.4  $SMLP$  designates the *minimum loading point* of the steam turbine *resource* in MW for a 1x1 configuration;

15.1.1.5  $SDF$  designates the amount of duct firing capacity available on the steam turbine *resource* in MW;

15.1.1.6  $STPortion_k$  designates the percentage of the steam turbine *resource* capacity attributed to *pseudo-unit*  $k \in \{1, \dots, K\}$ ; and

15.1.1.7  $CSCM_k \in \{0, 1\}$  designates whether *pseudo-unit*  $k \in \{1, \dots, K\}$  is flagged to operate in *single cycle mode*, subject to section 15.5.

15.1.2 The *pre-dispatch calculation engine* shall calculate the following model parameters for each *pseudo-unit*  $k \in \{1, \dots, K\}$ :

15.1.2.1  $MMCR_k$  designates the maximum continuous rating of *pseudo-unit*  $k$  and is calculated as follows:

$$CMCR_k + SMCR \cdot STPortion_k \cdot (1 - CSCM_k)$$

- 15.1.2.2  $MMLP_k$  designates the *minimum loading point* of *pseudo-unit k* and is calculated as follows:

$$CMLP_k + SMLP \cdot (1 - CSCM_k)$$

- 15.1.2.3  $MDF_k$  designates the duct firing capacity of *pseudo-unit k* and is calculated as follows:

$$SDF \cdot STPortion_k \cdot (1 - CSCM_k)$$

- 15.1.2.4  $MDR_k$  designates the *dispatchable* capacity of *pseudo-unit k* and is calculated as follows:

$$MMCR_k - MMLP_k - MDF_k$$

- 15.1.3 The *pre-dispatch calculation engine* shall define three operating regions of *pseudo-unit k*  $k \in \{1,..K\}$ , as follows:

- 15.1.3.1 The *minimum loading point* region shall be the capacity between 0 and  $MMLP_k$ ;

- 15.1.3.2 The *dispatchable* region shall be the capacity between  $MMLP_k$  and  $MMLP_k + MDR_k$ ;

- 15.1.3.3 The duct firing region shall be the capacity between  $MMLP_k + MDR_k$  and  $MMCR_k$ .

- 15.1.4 The *pre-dispatch calculation engine* shall calculate the associated combustion turbine *resource* and steam turbine *resource* shares for the three operating regions of *pseudo-unit k*  $k \in \{1,..K\}$ , as follows:

- 15.1.4.1 For the *minimum loading point* region:

15.1.4.1.1 Steam turbine *resource* share:  $STShareMLP_k = \frac{SMLP \cdot (1 - CSCM_k)}{MMLP_k}$ ;

15.1.4.1.2 Combustion turbine *resource* share:  $CTShareMLP_k = \frac{CMLP_k}{MMLP_k}$ ; and

- 15.1.4.2 For the *dispatchable* region:

- 15.1.4.2.1 Steam turbine *resource* share:

$$STShareDR_k = \frac{(1 - CSCM_k)(SMCR \cdot STPortion_k - SMLP - SDF \cdot STPortion_k)}{MDR_k}$$

and

15.1.4.2.2 Combustion turbine *resource* share:

$$CTShareDR_k = \frac{CMCR_k - CMLP_k}{MDR_k}; \text{ and}$$

15.1.4.3 For the duct firing region:

15.1.4.3.1 Steam turbine *resource* share shall be equal to 1; and

15.1.4.3.2 Combustion turbine *resource* share shall be equal to 0.

## 15.2 Application of Physical Resource Deratings to the Pseudo-Unit Model

15.2.1 The *pre-dispatch calculation engine* shall apply deratings submitted by *market participants* to the applicable *dispatchable* capacity and duct firing capacity parameters for a *pseudo-unit*, where:

15.2.1.1  $CTCap_{t,k}$  designates the capacity of combustion turbine *resource*  $k \in \{1, \dots, K\}$  in time-step  $t$  as determined by submitted deratings;

15.2.1.2  $STCap_t$  designates the capacity of the steam turbine *resource* in time-step  $t$  as determined by submitted deratings; and

15.2.1.3  $TotalQ_{t,k}$  designates the total quantity of *energy* for *pseudo-unit*  $k \in \{1, \dots, K\}$  in time-step  $t$ .

15.2.2 The *pre-dispatch calculation engine* shall solve for the following operating region parameters for each *pseudo-unit*  $k \in \{1, \dots, K\}$ :

15.2.2.1  $MLP_{t,k}$ , which designates the *minimum loading point* of *pseudo-unit*  $k$  in time-step  $t$ ;

15.2.2.2  $DR_{t,k}$ , which designates the *dispatchable* region capacity of *pseudo-unit*  $k$  in time-step  $t$ ; and

15.2.2.3  $DF_{t,k}$ , which designates the duct firing region capacity of *pseudo-unit*  $k$  in time-step  $t$ .

15.2.3 Pre-Processing of De-rates

15.2.3.1 The *pre-dispatch calculation engine* shall perform the following pre-processing steps to determine the available operating regions for a *pseudo-unit* based on the combustion turbine *resource*'s and steam turbine *resource*'s share and the application of the *pseudo-unit* deratings. For *pseudo-unit*  $k \in \{1, \dots, K\}$  for time-step  $t \in TS$ :



15.2.3.1.1 Step 1: Calculate the amount of *offered energy* attributed to each combustion turbine *resource* ( $CTAmt_{t,k}$ ) and steam turbine *resource* portion ( $STAmt_{t,k}$ ):

If  $TotalQ_{t,k} < MMLP_k$  then:

Calculate  $CTAmt_{t,k} = 0$ ; and

Calculate  $STAmt_{t,k} = 0$ .

Otherwise:

$CTAmtMPL = MMLP_k \cdot CTShareMPL_k$ ; and

$STAmtMPL = MMLP_k \cdot STShareMPL_k$ .

If  $TotalQ_{t,k} > MMLP_k + MDR_k$ , then:

$CTAmtDR = MDR_k \cdot CTShareDR_k$ ;

$STAmtDR = MDR_k \cdot STShareDR_k$ ; and

$STAmtDF = (1 - CSCM_k) \cdot (TotalQ_{t,k} - MMLP_k - MDR_k)$ .

Otherwise:

$CTAmtDR = (TotalQ_{t,k} - MMLP_k) \cdot CTShareDR_k$ ;

$STAmtDR = (TotalQ_{t,k} - MMLP_k) \cdot STShareDR_k$ ;

$STAmtDF = 0$ ;

$CTAmt_{t,k} = CTAmtMPL + CTAmtDR$ ; and

$STAmt_{t,k} = STAmtMPL + STAmtDR + STAmtDF$ .

15.2.3.1.2 Step 2: Allocate the steam turbine *resource's* capacity to each *pseudo-unit*:

$$PRSTCap_{t,k} = \left( \frac{STAmt_{t,k}}{\sum_{w \in \{1, \dots, K\}} STAmt_{t,w}} \right) \cdot STCap_t$$

15.2.3.1.3 Step 3: Determine if the *pseudo-unit* is available:

If  $CTAmt_{t,k} < CMLP_k$ , then the *pseudo-unit* is unavailable.

If  $STAmt_{t,k} < SMLP \cdot (1 - CSCM_k)$ , then the *pseudo-unit* is unavailable.

If  $CTCap_{t,k} < CMLP_k$ , then the *pseudo-unit* is unavailable.

If  $PRSTCap_{t,k} < SMLP \cdot (1 - CSCM_k)$ , then the *pseudo-unit* is unavailable.

15.2.3.1.4 Step 4: Initialize the operating region parameters for time-step  $t \in TS$  to the model parameter values:

Set  $MLP_{t,k} = MMLP_k$ .

Set  $DR_{t,k} = MDR_k$ .

Set  $DF_{t,k} = MDF_k$ .

15.2.3.1.5 Step 5: Apply the derating on the combustion turbine *resource* to the *dispatchable* region:

Calculate  $P$  so that  $CMLP_k + P \cdot CTShareDR_k \cdot MDR_k = CTCap_{t,k}$ ; and

Set  $DR_{t,k} = \min(DR_{t,k}, P \cdot MDR_k)$ .

15.2.3.1.6 Step 6: Apply the derating on the steam turbine *resource* to the duct firing and *dispatchable* regions for *pseudo-units* not operating in *single-cycle mode*:

Calculate  $R$  so that  $SMLP + R \cdot STShareDR_k \cdot MDR_k = PRSTCap_{t,k}$ .

If  $R \leq 1$ , update  $DF_{t,k} = 0$ , and  $DR_{t,k} = \min(DR_{t,k}, R \cdot MDR_k)$ .

If  $R > 1$ , update  $DF_{t,k} = \min(DF_{t,k}, PRSTCap_{t,k} - SMLP - STShareDR_k \cdot MDR_k)$ .

## 15.2.4 Available Energy Laminations

15.2.4.1 The *pre-dispatch calculation engine* shall determine the *offer* quantity laminations that may be scheduled for *energy* and *operating reserve* in each operating region for time-step  $t \in TS$  for each *pseudo-unit*  $k \in \{1, \dots, K\}$ , subject to section 15.2.4.2, where:

15.2.4.1.1  $QMLP_{t,k}$  designates the total quantity that may be scheduled in the *minimum loading point* region;

15.2.4.1.2  $QDR_{t,k}$  designates the total quantity that may be scheduled in the *dispatchable* region; and

15.2.4.1.3  $QDF_{t,k}$  designates the total quantity that may be scheduled in the duct firing region.

15.2.4.2 The available *offered* quantity laminations shall be subject to the following conditions:

$$0 \leq QMLP_{t,k} \leq MLP_{t,k};$$

$$0 \leq QDR_{t,k} \leq DR_{t,k};$$

$$0 \leq QDF_{t,k} \leq DF_{t,k};$$

if  $QMLP_{t,k} < MLP_{t,k}$ , then the *pseudo-unit* is unavailable and  $QDR_{t,k} = QDF_{t,k} = 0$ ; and

if  $QDR_{t,k} < DR_{t,k}$ , then  $QDF_{t,k} = 0$ .

### 15.3 Convert Physical Resource Constraints to Pseudo-Unit Constraints

15.3.1 The *pre-dispatch calculation engine* shall convert physical *resource* constraints to *pseudo-unit* constraints, where:

15.3.1.1  $PSUMin_{t,k}^q$  designates the minimum limitation on *pseudo-unit*  $k$  determined by translating constraint  $q$ . When constraint  $q$  does not provide a minimum limitation on *pseudo-unit*  $k$ , then  $PSUMin_{t,k}^q$  shall be set equal to 0;

15.3.1.2  $PSUMax_{t,k}^q$  designates the maximum limitation on *pseudo-unit*  $k$  determined by translating constraint  $q$ . When constraint  $q$  does not provide a maximum limitation on *pseudo-unit*  $k$ , then  $PSUMax_{t,k}^q$  shall be set equal to  $MLP_{t,k} + DR_{t,k} + DF_{t,k}$ ;

15.3.1.3  $CTCmtd_{t,k} \in \{0,1\}$  designates whether combustion turbine *resource*  $k \in \{1,..K\}$  is considered committed in time-step  $t \in TS$ .

15.3.2 The *pre-dispatch calculation engine* shall calculate the minimum and maximum limitations, subject to section 15.3.3.1, as follows:

15.3.2.1 Minimum limitation:  $MinDG_{t,k} = \max_{q \in \{1,..Q\}} PSUMin_{t,k}^q$

15.3.2.2 Maximum limitation:  $MaxDG_{t,k} = \min_{q \in \{1,..Q\}} PSUMax_{t,k}^q$

where  $Q$  designates the number of constraints impacting a *combined cycle plant* that have been provided to the *pre-dispatch calculation engine*.

### 15.3.3 Pseudo-Unit Minimum and Maximum Constraints

15.3.3.1 *Pseudo-unit* minimum and maximum constraints shall be calculated as follows:

15.3.3.1.1  $PSUMin_{t,k} = PMin$ , where  $PMin$  shall be a minimum constraint provided on *pseudo-unit*  $k \in \{1,..,K\}$  for time-step  $t \in TS$ ; and

15.3.3.1.2  $PSUMax_{t,k} = PMax$ ,  $PMax$  shall be a maximum constraint provided on *pseudo-unit*  $k \in \{1,..,K\}$  for time-step  $t \in TS$ .

### 15.3.4 Combustion Turbine Resource Minimum and Maximum Constraints

15.3.4.1 If the *pseudo-unit* is not flagged to operate in *single cycle mode*, then the combustion turbine *resource*'s minimum constraint shall be converted to a *pseudo-unit* constraint as follows:

If  $CTMin < MLP_{t,k} \cdot CTShareMLP_k$ , then set

$$STMinMLP = CTMin \cdot \left( \frac{STShareMLP_k}{CTShareMLP_k} \right); \text{ and}$$

$$STMinDR = 0.$$

Otherwise, if  $CTMin \geq MLP_{t,k} \cdot CTShareMLP_k$ , then set

$$STMinMLP = MLP_{t,k} \cdot STShareMLP_k; \text{ and}$$

$$STMinDR = (CTMin - MLP_{t,k} \cdot CTShareMLP_k) \cdot \left( \frac{STShareDR_k}{CTShareDR_k} \right).$$

Therefore:

$$PSUMin_{t,k} = CTMin + STMinMLP + STMinDR.$$

15.3.4.2 If a *pseudo-unit* is flagged to operate in *single cycle mode*, then the combustion turbine *resource*'s minimum constraint shall be converted to a *pseudo-unit* constraint as follows:

$$PSUMin_{t,k} = CTMin.$$

15.3.4.3 If the *pseudo-unit* is not flagged to operate in *single cycle mode*, then the combustion turbine *resource*'s maximum constraint shall be converted to a *pseudo-unit* constraint as follows:

If  $CTMax < MLP_{t,k} \cdot CTShareMLP_k$ , then the *pseudo-unit* is unavailable (i.e.  $PSUMax_{t,k} = 0$ ).

Otherwise, calculate the effect of the constraint on the steam turbine resource within the *minimum loading point* and *dispatchable* regions:

$$STMaxMLP = MLP_{t,k} \cdot STShareMLP_k$$

$$STMaxDR = (CTMax - MLP_{t,k} \cdot CTShareMLP_k) \cdot \left( \frac{STShareDR_k}{CTShareDR_k} \right)$$

$$PSUMax_{t,k} = CTMax + STMaxMLP + STMaxDR$$

- 15.3.4.4 If a *pseudo-unit* is flagged to operate in *single cycle mode*, then the combustion turbine resource's maximum constraint shall be converted to a *pseudo-unit* constraint as follows:

$$PSUMax_{t,k} = CTMax.$$

### 15.3.5 Steam Turbine Resource Minimum and Maximum Constraints

- 15.3.5.1 The *pre-dispatch calculation engine* shall convert a steam turbine resource's minimum constraint to a *pseudo-unit* constraints as follows:

- 15.3.5.1.1 Step 1: Identify  $A \subseteq \{1, \dots, K\}$ , which designates the set of *pseudo-units* to which the constraint may be allocated where *pseudo-unit*  $k \in \{1, \dots, K\}$  is placed in set  $A$  if and only if  $CSCM_k = 0$  and  $CTCmtd_{t,k} = 1$ . If the set  $A$  is empty, then no further steps are required, otherwise proceed to Step 2.

- 15.3.5.1.2 Step 2: Determine the steam turbine resource's portion of the capacity of *pseudo-unit*  $k \in A$ :

$$STCap_k = QMLP_{t,k} \cdot STShareMLP_k + QDR_{t,k} \cdot STShareDR_k + QDF_{t,k}.$$

- 15.3.5.1.3 Step 3: Allocate the *STMin* constraint to each *pseudo-unit*  $k \in A$ , where *STMin* constraint shall be allocated equally to each *pseudo-unit*  $k \in A$  and *STPMin<sub>k</sub>* is limited by *STCap<sub>k</sub>*.

- 15.3.5.1.4 Step 4: The steam turbine resource portion minimum constraint shall be converted to a *pseudo-unit* constraint, where for each *pseudo-unit*  $k \in A$ :

If  $STPMin_k < MLP_{t,k} \cdot STShareMLP_k$ , then set

$$CTMinMLP_k = STPMin_k \cdot \left( \frac{CTShareMLP_k}{STShareMLP_k} \right); \text{ and}$$

$$CTMinDR_k = 0.$$

Otherwise, if  $STPMin_k \geq MLP_{t,k} \cdot STShareMLP_k$ , then set

$$CTMinMLP_k = MLP_{t,k} \cdot CTShareMLP_k; \text{ and}$$

$$CTMinDR_k = (STPMin_k - MLP_{t,k} \cdot STShareMLP_k) \cdot \left( \frac{CTShareDR_k}{STShareDR_k} \right).$$

Therefore:

$$PSUMin_{t,k} = STPMin_k + CTMinMLP_k + CTMinDR_k.$$

15.3.5.2 If *pseudo-units* with sufficient steam turbine *resource* capacity are not committed, then the *pre-dispatch calculation engine* shall not convert the entire quantity of the steam turbine *resource*'s minimum constraint to *pseudo-unit* constraints.

15.3.5.3 The steam turbine *resource*'s maximum constraint shall be converted to a *pseudo-unit* constraint as follows:

$$PRSTMax_{t,k} = \left( \frac{STAmt_{t,k}}{\sum_{w \in \{1, \dots, K\}} STAmt_{t,w}} \right) \cdot STMax.$$

15.3.5.3.1 If the converted steam turbine *resource* maximum constraint limits the steam turbine *resource* portion to below its *minimum loading point*, then

$$PSUMax_{t,k} = 0.$$

15.3.5.3.2 Otherwise, calculate R so that  $SMLP + R \cdot STShareDR_k \cdot MDR_k = PRSTMax_{t,k}$ :

If  $R \leq 1$ , set  $PSUMax_{t,k} = MLP_{t,k} + \min(DR_{t,k}, R \cdot MDR_k)$ .

If  $R > 1$ , set  $PSUMax_{t,k} = MLP_{t,k} + DR_{t,k} + PRSTMax_{t,k} - SMLP - STShareDR_k \cdot MDR_k$ .

15.3.5.4 If the steam turbine *resource*'s minimum and maximum constraints are equal but do not convert to equal *pseudo-unit* minimum and maximum constraints, then the steam turbine *resource* minimum constraint

conversion in section 15.3.5.1 shall be used to determine equal *pseudo-unit* minimum and maximum constraints.

## 15.4 Steam Turbine Resource Forced Outages

- 15.4.1 If the steam turbine *resource* experiences a *forced outage*, the *pre-dispatch calculation engine* shall evaluate the corresponding *pseudo-units* as *resources* being offered in *single cycle mode*.

## 15.5 Single-Cycle Mode Flag Across Two Dispatch Days

- 15.5.1 If the pre-dispatch look-ahead period spans two *dispatch days* and the *single cycle mode* flag across the two *dispatch days* differs, then the *pre-dispatch calculation engine* shall apply the following:
- 15.5.1.1 If there are no future minimum constraints for the *pseudo-unit* before the end of the first *dispatch day* and if the *IESO's energy* management system indicates that the combustion turbine *resource* associated with the *pseudo-unit* is not online, then the *pre-dispatch calculation engine* shall use the *single cycle mode* flag of the second *dispatch day* for the entire pre-dispatch look-ahead period.
  - 15.5.1.2 If there are no minimum *reliability* or commitment constraints on the *pseudo-unit* which cross into the next *dispatch day* and either there is a future minimum *reliability* or commitment constraint on the *pseudo-unit* that ends before the end of the first *dispatch day* or if the *IESO's energy* management system indicates that the combustion turbine *resource* associated with the *pseudo-unit* is online, then the *pre-dispatch calculation engine* shall:
    - 15.5.1.2.1 use the *single cycle mode* flag of the first *dispatch day* for the pre-dispatch look-ahead period in the first *dispatch day* and use the *single cycle mode* flag of the second *dispatch day* for the pre-dispatch look-ahead period in the second *dispatch day*; and
    - 15.5.1.2.2 schedule the *pseudo-unit* to 0 MW in the first hour of the second *dispatch day*.
  - 15.5.1.3 If there is a minimum *reliability* or commitment constraint on the *pseudo-unit* that crosses into the next *dispatch day*, then the *pre-dispatch calculation engine* shall:
    - 15.5.1.3.1 use the *single cycle mode* flag of the first *dispatch day* for the pre-dispatch look-ahead period in the first *dispatch day* and the beginning hours of the second *dispatch day* to meet such constraint;

- 15.5.1.3.2 use the *single cycle mode* flag of the second *dispatch day* for pre-dispatch look-ahead period in the second *disptch day* after such constraint for the *pseudo-unit* has completed; and
- 15.5.1.3.3 schedule the *pseudo-unit* to 0 MW in the first hour for which no *reliability* or commitment constraint applies in the second *dispatch day*.

## 15.6 Conversion of Pseudo-Unit Schedules to Physical Resource Schedules

- 15.6.1 For a *combined cycle plant* with  $K$  combustion turbine *resources* and one steam turbine *resource*, the *pre-dispatch calculation engine* shall compute the following *energy* and *operating reserve* schedules for time-step  $t \in TS$ :
  - 15.6.1.1  $CTE_{t,k}$ , which designates the *energy* schedule for combustion turbine *resource*  $k \in \{1,..,K\}$ ;
  - 15.6.1.2  $STPE_{t,k}$ , which designates the *energy* schedule for the steam turbine *resource*'s portion of *pseudo-unit*  $k \in \{1,..,K\}$ ;
  - 15.6.1.3  $STE_t$ , which designates the *energy* schedule for the steam turbine *resource*;
  - 15.6.1.4  $CT10S_{t,k}$ , which designates the synchronized *ten-minute operating reserve* schedule for combustion turbine *resource*  $k \in \{1,..,K\}$ ;
  - 15.6.1.5  $STP10S_{t,k}$ , which designates the synchronized *ten-minute operating reserve* schedule for the steam turbine *resource*'s portion of *pseudo-unit*  $k \in \{1,..,K\}$ ;
  - 15.6.1.6  $ST10S_p$ , which designates the synchronized *ten-minute operating reserve* schedule for the steam turbine *resource*;
  - 15.6.1.7  $CT10N_{t,k}$ , which designates the non-synchronized *ten-minute operating reserve* schedule for combustion turbine *resource*  $k \in \{1,..,K\}$ ;
  - 15.6.1.8  $STP10N_{t,k}$ , which designates the non-synchronized *ten-minute operating reserve* schedule for the steam turbine *resource*'s portion of *pseudo-unit*  $k \in \{1,..,K\}$ ;
  - 15.6.1.9  $ST10N_t$ , which designates the non-synchronized *ten-minute operating reserve* schedule for the steam turbine *resource*;



- 15.6.1.10  $CT30R_{t,k}$ , which designates the *thirty-minute operating reserve* schedule for combustion turbine *resource*  $k \in \{1, \dots, K\}$ ;
- 15.6.1.11  $STP30R_{t,k}$ , which designates the *thirty-minute operating reserve* schedule for the steam turbine *resource*'s portion of *pseudo-unit*  $k \in \{1, \dots, K\}$ ; and
- 15.6.1.12  $ST30R_t$ , which designates the *thirty-minute operating reserve* schedule for the steam turbine *resource*.
- 15.6.2 The *pre-dispatch calculation engine* shall determine the following *energy* and *operating reserve* schedules for *pseudo-unit*  $k \in \{1, \dots, K\}$  in time-step  $t \in TS$ :
- 15.6.2.1  $SE_{t,k}$ , which designates the total amount of *energy* scheduled and  $SE_{t,k} = SEMLP_{t,k} + SEDR_{t,k} + SEDF_{t,k}$  where:
- 15.6.2.1.1  $SEMLP_{t,k}$  designates the portion of the schedule corresponding to the *minimum loading point* region, where  $0 \leq SEMLP_{t,k} \leq QMLP_{t,k}$ ;
- 15.6.2.1.2  $SEDR_{t,k}$  designates the portion of the schedule corresponding to the *dispatchable* region, where  $0 \leq SEDR_{t,k} \leq QDR_{t,k}$  and  $SEDR_{t,k} > 0$  only if  $SEMLP_{t,k} = QMLP_{t,k}$ ;
- 15.6.2.1.3  $SEDF_{t,k}$  designates the portion of the schedule corresponding to the *duct firing* region, where  $0 \leq SEDF_{t,k} \leq QDF_{t,k}$  and  $SEDF_{t,k} > 0$  only if  $SEDR_{t,k} = QDR_{t,k}$ ;
- 15.6.2.2  $S10S_{t,k}$ , which designates the total amount of *synchronized ten-minute operating reserve* scheduled;
- 15.6.2.3  $S10N_{t,k}$ , which designates the total amount of *non-synchronized ten-minute operating reserve* scheduled. If the *pseudo-unit* cannot provide *operating reserve* from its *duct firing* region, then  $0 \leq SE_{t,k} + S10S_{t,k} + S10N_{t,k} \leq QMLP_{t,k} + QDR_{t,k}$ ; and
- 15.6.2.4  $S30R_{t,k}$ , which designates the total amount of *thirty-minute operating reserve* scheduled, where  $0 \leq SE_{t,k} + S10S_{t,k} + S10N_{t,k} + S30R_{t,k} \leq QMLP_{t,k} + QDR_{t,k} + QDF_{t,k}$
- 15.6.3 The *pre-dispatch calculation engine* shall convert *pseudo-unit* schedules to physical *generation resource* schedules for *energy* and *operating reserve*, as follows:
- 15.6.3.1 If  $SE_{h,k} \geq MLP_{h,k}$ , then:

$$CTE_{t,k} = SEMLP_{t,k} \cdot CTShareMLP_k + SEDR_{h,k} \cdot CTShareDR_k;$$

$$STPE_{t,k} = SEMLP_{t,k} \cdot STShareMLP_k + SEDR_{t,k} \cdot STShareDR_k + SEDF_{t,k};$$

$$RoomDR_{t,k} = QDR_{t,k} - SEDR_{t,k};$$

$$10SDR_{t,k} = \min(RoomDR_{t,k}, S10S_{t,k});$$

$$10NDR_{t,k} = \min(RoomDR_{t,k} - 10SDR_{t,k}, S10N_{t,k});$$

$$30RDR_{t,k} = \min(RoomDR_{t,k} - 10SDR_{t,k} - 10NDR_{t,k}, S30R_{t,k});$$

$$CT10S_{t,k} = 10SDR_{t,k} \cdot CTShareDR_k;$$

$$STP10S_{t,k} = 10SDR_{t,k} \cdot STShareDR_k + (S10S_{t,k} - 10SDR_{t,k});$$

$$CT10N_{t,k} = 10NDR_{t,k} \cdot CTShareDR_k;$$

$$STP10N_{t,k} = 10NDR_{t,k} \cdot STShareDR_k + (S10N_{t,k} - 10NDR_{t,k});$$

$$CT30R_{t,k} = 30RDR_{t,k} \cdot CTShareDR_k; \text{ and}$$

$$STP30R_{t,k} = 30RDR_{t,k} \cdot STShareDR_k + (S30R_{t,k} - 30RDR_{t,k})$$

- 15.6.3.2 If  $SE_{t,k} < MLP_{t,k}$  and is ramping to *minimum loading point*, then the conversion shall be determined by the *ramp up energy to minimum loading point*.
- 15.6.3.3 The steam turbine *resources* portion schedules from section 15.6.3.1 shall be summed to obtain the steam turbine *resource* schedule as follows:

$$STE_t = \sum_{k=1,..,K} STPE_{t,k};$$

$$ST10S_t = \sum_{k=1,..,K} STP10S_{t,k};$$

$$ST10N_t = \sum_{k=1,..,K} STP10N_{t,k}; \text{ and}$$

$$ST30R_t = \sum_{k=1,..,K} STP30R_{t,k}.$$

## 16 Pricing Formulas

### 16.1 Purpose

- 16.1.1 The *pre-dispatch calculation engine* shall calculate *locational marginal prices* using shadow prices, constraint sensitivities and marginal loss factors.

## 16.2 Sets, Indices and Parameters

- 16.2.1 The sets, indices and parameters used to calculate *locational marginal prices* are described in section 4. In addition, the following shadow prices from Pass 1 shall be used:
- 16.2.1.1  $SPEmT_{t,c,f}^1$ , which designates the Pass 1 shadow price for the post-contingency transmission constraint for *facility*  $f \in F$  in contingency  $c \in C$  in time-step  $t$ ;
  - 16.2.1.2  $SPExtT_{t,z}^1$ , which designates the Pass 1 shadow price for the import or export limit constraint  $z \in Z_{Sch}$  in time-step  $t$ ;
  - 16.2.1.3  $SPL_t^1$ , which designates the Pass 1 shadow price for the *energy* balance constraint in time-step  $t$ ;
  - 16.2.1.4  $SPNIUExtBwdT_t^1$ , which designates the Pass 1 shadow price for the net interchange scheduling limit constraint limiting increases in net imports between time-step  $(t - 1)$  and time-step  $t$ ;
  - 16.2.1.5  $SPNIDExtBwdT_t^1$ , which designates the Pass 1 shadow price for the net interchange scheduling limit constraint limiting decreases in net imports between time-step  $(t - 1)$  and time-step  $t$ ;
  - 16.2.1.6  $SPNIUExtFwdT_t^1$ , which designates the Pass 1 shadow price for the net interchange scheduling limit constraint limiting increases in net imports between time-step  $t$  and time-step  $(t + 1)$ ;
  - 16.2.1.7  $SPNIDExtFwdT_t^1$ , which designates the Pass 1 shadow price for the net interchange scheduling limit constraint limiting decreases in net imports between time-step  $t$  and time-step  $(t + 1)$ ;
  - 16.2.1.8  $SPNormT_{t,f}^1$ , which designates the Pass 1 shadow price for the pre-contingency transmission constraint for *facility*  $f \in F$  in time-step  $t$ ;
  - 16.2.1.9  $SP10S_t^1$ , which designates the Pass 1 shadow price for the total synchronized *ten-minute operating reserve* requirement constraint in time-step  $t$ ;
  - 16.2.1.10  $SP10R_t^1$ , which designates the Pass 1 shadow price for the total *ten-minute operating reserve* requirement constraint in time-step  $t$ ;
  - 16.2.1.11  $SP30R_t^1$ , which designates the Pass 1 shadow price for the total *thirty-minute operating reserve* requirement constraint in time-step  $t$ ;

- 16.2.1.12  $SPREGMin10R_{r,t}^1$ , which designates the Pass 1 shadow price for the minimum *ten-minute operating reserve* constraint for region  $r \in ORREG$  in time-step  $t$ ;
- 16.2.1.13  $SPREGMin30R_{r,t}^1$ , which designates the Pass 1 shadow price for the minimum *thirty-minute operating reserve* constraint for region  $r \in ORREG$  in time-step  $t$ ;
- 16.2.1.14  $SPREGMax10R_{r,t}^1$ , which designates the Pass 1 shadow price for the maximum *ten-minute operating reserve* constraint for region  $r \in ORREG$  in time-step  $t$ ; and
- 16.2.1.15  $SPREGMax30R_{r,t}^1$ , which designates the Pass 1 shadow price for the maximum *thirty-minute operating reserve* constraint for region  $r \in ORREG$  in time-step  $t$ .

## 16.3 Locational Marginal Prices for Energy

### 16.3.1 Energy Locational Marginal Prices for Delivery Points

16.3.1.1 The *pre-dispatch calculation engine* shall calculate a *locational marginal price* and components for *energy* for Pass 1 and each time-step  $t \in TS$  for every bus  $b \in L$  where a *non-dispatchable generation resource* or *dispatchable generation resource*, a *dispatchable load*, an *hourly demand response resource*, or a *non-dispatchable load* is sited and:

16.3.1.1.1  $LMP_{t,b}^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *energy*;

16.3.1.1.2  $PRef_t^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *energy* at the *reference bus*;

16.3.1.1.3  $PLoss_{t,b}^1$  designates the Pass 1 time-step  $t$  *loss component*; and

16.3.1.1.4  $PCong_{t,b}^1$  designates the Pass 1 time-step  $t$  *congestion component*.

16.3.1.2 The *pre-dispatch calculation engine* shall calculate an initial *locational marginal price* for *energy*, a *locational marginal price* for *energy* at the *reference bus*, a *loss component* and a *congestion component* for Pass 1 at bus  $b \in L$  in time-step  $t \in TS$ , as follows:

$$InitLMP_{t,b}^1 = InitPRef_t^1 + InitPLoss_{t,b}^1 + InitPCong_{t,b}^1$$

where:

$$InitPRef_t^1 = SPL_t^1;$$

$$InitPLoss_{t,b}^1 = MglLoss_{t,b}^1 \cdot SPL_t^1;$$

and

$$InitPCong_{t,b}^1 = \sum_{f \in F_t} PreConSF_{t,f,b} \cdot SPNormT_{t,f}^1 + \sum_{c \in C} \sum_{f \in F_{t,c}} SF_{t,c,f,b} \cdot SPEmT_{t,c,f}^1.$$

- 16.3.1.3 If the initial locational marginal price for energy at the reference bus ( $InitPRef_t^1$ ) is not within the settlement bounds ( $EngyPrcFlr$ ,  $EngyPrcCeil$ ), then the pre-dispatch calculation engine shall modify the locational marginal price for energy at the reference bus as follows:

If  $InitPRef_t^1 > EngyPrcCeil$ , set  $PRef_t^1 = EngyPrcCeil$

If  $InitPRef_t^1 < EngyPrcFlr$ , set  $PRef_t^1 = EngyPrcFlr$

Otherwise, set  $PRef_t^1 = InitPRef_t^1$

- 16.3.1.4 If the initial locational marginal price for energy ( $InitLMP_{t,b}^1$ ) is not within the settlement bounds ( $EngyPrcFlr$ ,  $EngyPrcCeil$ ), then the pre-dispatch calculation engine shall modify the locational marginal price for energy as follows:

If  $InitLMP_{t,b}^1 > EngyPrcCeil$ , set  $LMP_{t,b}^1 = EngyPrcCeil$

If  $InitLMP_{t,b}^1 < EngyPrcFlr$ , set  $LMP_{t,b}^1 = EngyPrcFlr$

Otherwise, set  $LMP_{t,b}^1 = InitLMP_{t,b}^1$

- 16.3.1.5 The pre-dispatch calculation engine shall modify the loss component as follows:

If  $PRef_t^1 \neq InitPRef_t^1$ , set  $PLoss_{t,b}^1 = MglLoss_{t,b}^1 \cdot PRef_t^1$

Otherwise, set  $PLoss_{t,b}^1 = InitPLoss_{t,b}^1$

- 16.3.1.6 The pre-dispatch calculation engine shall modify the congestion component as follows:

If  $LMP_{t,b}^1 - PRef_t^1 - PLoss_{t,b}^1$  and  $InitPCong_{t,b}^1$  have the same mathematical sign, then set  $PCong_{t,b}^1 = LMP_{t,b}^1 - PRef_t^1 - PLoss_{t,b}^1$

Otherwise, set  $PCong_{t,b}^1 = 0$  and set  $P_{Loss}_{t,b}^1 = LMP_{t,b}^1 - P_{Ref}_t^1$

## 16.3.2 Energy Locational Marginal Prices for Intertie Metering Points

16.3.2.1 The *pre-dispatch calculation engine* shall calculate a *locational marginal price* and components for *energy* for Pass 1 and each time-step  $t \in TS$  for *intertie zone* bus  $d \in D$ , where:

16.3.2.1.1  $ExtLMP_{t,d}^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *energy*;

16.3.2.1.2  $IntLMP_{t,d}^1$  designates the Pass 1 time-step  $t$  *intertie border price* for *energy*;

16.3.2.1.3  $ICP_{t,d}^1$  designates the Pass 1 time-step  $t$  *intertie congestion price*;

16.3.2.1.4  $P_{Ref}_t^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *energy* at the *reference bus*;

16.3.2.1.5  $P_{Loss}_{t,d}^1$  designates the Pass 1 time-step  $t$  *loss component*;

16.3.2.1.6  $P_{IntCong}_{t,d}^1$  designates the Pass 1 time-step  $t$  *internal congestion component* for *energy*;

16.3.2.1.7  $P_{ExtCong}_{t,d}^1$  designates the Pass 1 time-step  $t$  *external congestion component* for the *intertie congestion price*; and

16.3.2.1.8  $P_{NISL}_{t,d}^1$  designates the Pass 1 time-step  $t$  *net interchange scheduling limit congestion component* for the *intertie congestion price*.

16.3.2.2 The *pre-dispatch calculation engine* shall calculate an *initial locational marginal price* for *energy*, a *locational marginal price* for *energy* for the *reference bus*, a *loss components* and a *congestion components* for *energy* for Pass 1 at *intertie zone* bus  $d \in D_a$  in *intertie zone*  $a \in A$  in time-step  $t$ , subject to sections 16.3.2.8 and 16.3.2.9, as follows:

$$InitExtLMP_{t,d}^1 = InitIntLMP_{t,d}^1 + InitICP_{t,d}^1$$

where:

$$InitPRef_t^1 = SPL_t^1;$$

$$InitPLoss_{t,d}^1 = MglLoss_{t,d}^1 \cdot SPL_t^1;$$

$$InitPIntCong_{t,d}^1$$

$$\triangleleft = \sum_{f \in F_t} PreConSF_{t,f,d} \cdot$$

$$SPNormT_{t,f}^1 + \sum_{c \in C} \sum_{f \in F_{t,c}} SF_{t,c,f,d} \cdot SPEmT_{t,c,f}^1;$$

$$InitIntLMP_{t,d}^1 = InitPRef_t^1 + InitPLoss_{t,d}^1 + InitPIntCong_{t,d}^1;$$

$$InitPExtCong_{t,d}^1 = \sum_{z \in Z_{sch}} EnCoeff_{a,z} \cdot SPExtT_{t,z}^1;$$

and

$$InitPNISL_{t,d}^1 = SPNIUExtBwdT_t^1 - SPNIUExtFwdT_t^1 - SPNIDExtBwdT_t^1 + SPNIDExtFwdT_t^1;$$

$$InitICP_{t,d}^1 = InitPExtCong_{t,d}^1 + InitPNISL_{t,d}^1$$

- 16.3.2.3 If the initial *locational marginal price* for energy ( $InitExtLMP_{t,d}^1$ ) is not within the *settlement bounds* ( $EngyPrcFlr$ ,  $EngyPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the *intertie border price* for energy, and its components, as follows:
- 16.3.2.3.1 The initial *locational marginal price* for the *reference bus* ( $InitPRef_t^1$ ) shall be modified as per section 16.3.1.3;
- 16.3.2.3.2 The initial *intertie border price* ( $InitIntLMP_{t,d}^1$ ) shall be modified as per section 16.3.1.4, where  $InitLMP_{t,b}^1 = InitIntLMP_{t,d}^1$ ;
- 16.3.2.3.3 The initial loss component ( $InitPLoss_{t,d}^1$ ) shall be modified as per section 16.3.1.5; and
- 16.3.2.3.4 The initial internal congestion component ( $InitPIntCong_{t,d}^1$ ) shall be modified as per section 16.3.1.6, where  $InitPCong_{t,b}^1 = InitPIntCong_{t,d}^1$ .
- 16.3.2.4 If the initial *locational marginal price* for energy ( $InitExtLMP_{t,d}^1$ ) is not within the *settlement bounds* ( $EngyPrcFlr$ ,  $EngyPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the *locational marginal price* for energy, as follows:

If  $InitExtLMP_{t,d}^1 > EngyPrCceil$ , set  $ExtLMP_{t,d}^1 = EngyPrCceil$

If  $InitExtLMP_{t,d}^1 < EngyPrCflr$ , set  $ExtLMP_{t,d}^1 = EngyPrCflr$

Otherwise, set  $ExtLMP_{t,d}^1 = InitExtLMP_{t,d}^1$

- 16.3.2.5 If the modified *locational marginal price* for energy ( $ExtLMP_{t,d}^1$ ) is equal to the *intertie border price* for energy ( $IntLMP_{t,d}^1$ ), then the *pre-dispatch calculation engine* shall modify the external congestion component for the *intertie congestion price* and net interchange scheduling limit congestion component for the *intertie congestion price*, as follows:

If  $ExtLMP_{t,d}^1 = IntLMP_{t,d}^1$ , set  $PExtCong_{t,d}^1 = 0$  and  $PNISL_{t,d}^1 = 0$

- 16.3.2.6 If the modified *locational marginal price* for energy ( $ExtLMP_{t,d}^1$ ) is not equal to the *intertie border price* for energy ( $IntLMP_{t,d}^1$ ), then the *pre-dispatch calculation engine* shall modify the external congestion component for the *intertie congestion price* and net interchange scheduling limit congestion component for the *intertie congestion price*, as follows:

If  $ExtLMP_{t,d}^1 \neq IntLMP_{t,d}^1$ , set

$$PNISL_{t,d}^1 = (ExtLMP_{t,d}^1 - IntLMP_{t,d}^1) \cdot \left( \frac{InitPNISL_{h,d}^1}{InitPNISL_{t,d}^1 + InitPExtCong_{t,d}^1} \right)$$

If  $PNISL_{t,d}^1 > NISLPen$ , set  $PNISL_{t,d}^1 = NISLPen$

If  $PNISL_{t,d}^1 < (-1) \cdot NISLPen$ , set  $PNISL_{t,d}^1 = (-1) \cdot NISLPen$

Then  $PExtCong_{t,d}^1 = ExtLMP_{t,d}^1 - IntLMP_{t,d}^1 - PNISL_{t,d}^1$

- 16.3.2.7 The *pre-dispatch calculation engine* shall calculate the *intertie congestion price* as follows:

$$ICP_{t,d}^1 = PExtCong_{t,d}^1 + PNISL_{t,d}^1$$

- 16.3.2.8 The *locational marginal price* for energy calculated by the *pre-dispatch calculation engine* shall be the same for all *boundary entity resource* buses at the same *intertie zone*. *Intertie* transactions associated with the same *boundary entity resource* bus, but specified as occurring at different



*intertie zones*, subject to phase shifter operation, shall be modelled as flowing across independent paths. Pricing of these transactions shall utilize shadow prices associated with the internal transmission constraints, *intertie* limits and transmission losses applicable to the path associated to the relevant *intertie* zone.

- 16.3.2.9 When an *intertie zone* is out-of-service, the *intertie* limits for that *intertie zone* will be set to zero and all import and export *boundary entity resources* for that *intertie zone* will receive a zero schedule and the *locational marginal price for energy* shall be set to the *intertie border price for energy*.

### 16.3.3 Zonal Prices for Energy

- 16.3.3.1 The *pre-dispatch calculation engine* shall calculate the zonal price for *energy* and its components for Pass 1 and each time-step  $t$  for each *virtual transaction zone*  $m \in M$ , as follows:

$$VZonalP_{t,m}^1 = PRef_t^1 + VZonalP_{Loss,t,m}^1 + VZonalPCong_{t,m}^1$$

where

$$VZonalP_{Loss,t,m}^1 = \sum_{b \in L_m^{VIRT}} WF_{t,m,b}^{VIRT} \cdot P_{Loss,t,b}^1$$

and

$$VZonalPCong_{t,m}^1 = \sum_{b \in L_m^{VIRT}} WF_{t,m,b}^{VIRT} \cdot PCong_{t,b}^1$$

- 16.3.3.2 The *pre-dispatch calculation engine* shall calculate the zonal price for *energy* and its components for Pass 1 and each time-step  $t$  for each *non-dispatchable load zone*  $y \in Y$ , as follows:

$$ZonalP_{t,y}^1 = PRef_t^1 + ZonalP_{Loss,t,y}^1 + ZonalPCong_{t,y}^1$$

where:

$$ZonalP_{Loss,t,y}^1 = \sum_{b \in L_y^{NDL}} WF_{t,y,b}^{NDL} \cdot P_{Loss,t,b}^1$$

and

$$ZonalPCong_{t,y}^1 = \sum_{b \in L_y^{NDL}} WF_{t,y,b}^{NDL} \cdot PCong_{t,b}^1$$

16.3.3.3 The *Ontario zonal price* is calculated per section 16.3.3.2 where the *non-dispatchable load zone* is comprised of all *non-dispatchable loads* within Ontario.

#### 16.3.4 Pseudo-Unit Pricing

16.3.4.1 The *pre-dispatch calculation engine* shall calculate a *locational marginal price* and components for *energy* for Pass 1 and each time-step *t* for every *pseudo-unit*  $k \in \{1, \dots, K\}$ , where:

16.3.4.1.1  $CTMglLoss_{t,k}^1$  designates the marginal loss factor for the combustion turbine *resource* identified by *pseudo-unit* *k* for time-step *t* in Pass 1;

16.3.4.1.2  $STMglLoss_{t,k}^p$  designates the marginal loss factor for the steam turbine *resource* identified by *pseudo-unit* *k* for time-step *t* in Pass 1;

16.3.4.1.3  $CTPreConSF_{t,f,k}$  designates the pre-contingency sensitivity factor for the combustion turbine *resource* identified by *pseudo-unit* *k* on *facility* *f* during time-step *t* under pre-contingency conditions;

16.3.4.1.4  $STPreConSF_{t,f,k}$  designates the pre-contingency sensitivity factor for the steam turbine *resource* identified by *pseudo-unit* *k* on *facility* *f* during time-step *t* under pre-contingency conditions;

16.3.4.1.5  $CTSF_{t,c,f,k}$  designates the post-contingency sensitivity factor for the combustion turbine *resource* identified by *pseudo-unit* *k* on *facility* *f* during time-step *t* under post-contingency conditions for contingency *c*; and

16.3.4.1.6  $STSF_{t,c,f,k}$  designates the post-contingency sensitivity factor for the steam turbine *resource* identified by *pseudo-unit* *k* on *facility* *f* during time-step *t* under post-contingency conditions for contingency *c*.

16.3.4.2 The *pre-dispatch calculation engine* shall calculate an initial *locational marginal price* for *energy*, a *locational marginal price* for *energy* at the *reference bus*, a loss component and a congestion component for Pass 1 and each time-step *t* for every *pseudo-unit*  $k \in \{1, \dots, K\}$ , as follows:

$$InitLMP_{t,k}^1 = InitPRef_t^1 + InitPLoss_{t,k}^1 + InitPCong_{t,k}^1$$

where:

$$InitPRef_t^1 = SPL_t^1;$$

$$InitPLoss_{t,k}^1 = MglLoss_{t,k}^1 \cdot SPL_t^1;$$

and

$$InitPCong_{t,k}^1 = \sum_{f \in F_t} PreConSF_{t,f,k} \cdot SPNorm_{t,f}^1 + \sum_{c \in C} \sum_{f \in F_{t,c}} SF_{t,c,f,k} \cdot SPEm_{t,c,f}^1$$

16.3.4.3 If *pseudo-unit*  $k \in \{1, \dots, K\}$  is scheduled within its *minimum loading point range* or not scheduled at all, its marginal loss and sensitivity factors shall be:

$$MglLoss_{t,k}^1 = CTShareMLP_k \cdot CTMglLoss_{t,k}^1 + STShareMLP_k \cdot STMglLoss_{t,k}^1$$

$$\begin{aligned} PreConSF_{t,f,k} &= CTShareMLP_k \cdot CTPreConSF_{t,f,k} + STShareMLP_k \cdot STPreConSF_{t,f,k} \end{aligned}$$

$$SF_{t,c,f,k} = CTShareMLP_k \cdot CTSF_{t,c,f,k} + STShareMLP_k \cdot STSF_{t,c,f,k}$$

16.3.4.4 If *pseudo-unit*  $k \in \{1, \dots, K\}$  is scheduled within its *dispatchable region*, its marginal loss and sensitivity factors shall be:

$$MglLoss_{t,k}^1 = CTShareDR_k \cdot CTMglLoss_{t,k}^1 + STShareDR_k \cdot STMglLoss_{t,k}^1$$

$$\begin{aligned} PreConSF_{t,f,k} &= CTShareDR_k \cdot CTPreConSF_{t,f,k} + STShareDR_k \cdot STPreConSF_{t,f,k} \end{aligned}$$

$$SF_{t,c,f,k} = CTShareDR_k \cdot CTSF_{t,c,f,k} + STShareDR_k \cdot STSF_{t,c,f,k}$$

16.3.4.5 If *pseudo-unit*  $k \in \{1, \dots, K\}$  is scheduled within its *duct firing region*, its marginal loss and sensitivity factors shall be:

$$MglLoss_{t,k}^1 = STMglLoss_{t,k}^1$$

$$PreConSF_{t,f,k} = STPreConSF_{t,f,k}$$

$$SF_{t,c,f,k} = STSF_{t,c,f,k}$$

## 16.4 Locational Marginal Prices for Operating Reserve

### 16.4.1 Operating Reserve Locational Marginal Prices for Delivery Points

16.4.1.1 The *pre-dispatch calculation engine* shall calculate a *locational marginal price* and components for *operating reserve* for Pass 1 and each time-step  $t$  for a *delivery point* associated with the *dispatchable generation resource* and *dispatchable load* at bus  $b \in B$ , where:

16.4.1.1.1  $L30RP_{t,b}^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *thirty-minute operating reserve*;

16.4.1.1.2  $P30RRef_t^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *thirty-minute operating reserve* at the *reference bus*;

16.4.1.1.3  $P30RCong_{t,b}^1$  designates the Pass 1 time-step  $t$  congestion component for *thirty-minute operating reserve*;

16.4.1.1.4  $L10NP_{t,b}^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for non-synchronized *ten-minute operating reserve*;

16.4.1.1.5  $P10NRef_t^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for non-synchronized *ten-minute operating reserve* at the *reference bus*;

16.4.1.1.6  $P10NCong_{t,b}^1$  designates the Pass 1 time-step  $t$  congestion component for non-synchronized *ten-minute operating reserve*;

16.4.1.1.7  $L10SP_{t,b}^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for synchronized *ten-minute operating reserve*;

16.4.1.1.8  $P10SRef_t^1$  designates the Pass 1 time-step  $t$  *locational marginal prices* for synchronized *ten-minute operating reserve* at the *reference bus*;

16.4.1.1.9  $P10SCong_{t,b}^1$  designates the Pass 1 time-step  $t$  congestion component for synchronized *ten-minute operating reserve*; and

16.4.1.1.10  $ORREG_b \subseteq ORREG$  as the subset of  $ORREG$  consisting of regions that include bus  $b$ .

16.4.1.2 The *pre-dispatch calculation engine* shall calculate an initial *locational marginal price*, a *locational marginal price at the reference bus*, and congestion components for Pass 1 for a *delivery point* associated with the *dispatchable generation resource* and *dispatchable load* at bus  $b \in B$  in time-step  $t \in TS$ , for each class of *operating reserve*, as follows:

$$InitL30RP_{t,b}^1 = InitP30RRef_t^1 + InitP30RCong_{t,b}^1$$

where

$$InitP30RRef_t^1 = SP30R_t^1$$

and

$$InitP30RCong_{t,b}^1 = \sum_{r \in ORREG_b} SPREGMin30R_{t,r}^1 + \sum_{r \in ORREG_b} SPREGMax30R_{t,r}^1$$

$$InitL10NP_{t,b}^1 = InitP10NRef_t^1 + InitP10NCong_{t,b}^1$$

where

$$InitP10NRef_t^1 = SP10R_t^1 + SP30R_t^1$$

and

$$InitP10NCong_{t,b}^1 = \sum_{r \in ORREG_b} (SPREGMin10R_{r,t}^1 + SPREGMin30R_{r,t}^1) + \sum_{r \in ORREG_b} (SPREGMax10R_{r,t}^1 + SPREGMax30R_{r,t}^1)$$

$$InitL10SP_{t,b}^1 = InitP10SRef_t^1 + InitP10SCong_{t,b}^1$$

where

$$InitP10SRef_t^1 = SP10S_t^1 + SP10R_t^1 + SP30R_t^1$$

and

$$\begin{aligned} InitP10SCong_{t,b}^1 &= \sum_{r \in ORREG_b} (SPREGMin10R_{r,t}^1 \\ &+ SPREGMin30R_{r,t}^1) \\ &+ \sum_{r \in ORREG_b} (SPREGMax10R_{r,t}^1 \\ &+ SPREGMax30R_{r,t}^1) \end{aligned}$$

- 16.4.1.3 If the initial *locational marginal price* at the *reference bus* ( $InitP30RRef_t^1$ ,  $InitP10NRef_t^1$ , or  $InitP10SRef_t^1$ ) is not within the *settlement bounds* ( $ORPrcFlr$ ,  $ORPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the *locational marginal price* at the *reference bus* for each class of *operating reserve* as follows:

If  $InitP30RRef_t^1 > ORPrcCeil$ , set  $P30RRef_t^1 = ORPrcCeil$ ;

If  $InitP30RRef_t^1 < ORPrcFlr$ , set  $P30RRef_t^1 = ORPrcFlr$ ;

Otherwise, set  $P30RRef_t^1 = InitP30RRef_t^1$ .

If  $InitP10NRef_t^1 > ORPrcCeil$ , set  $P10NRef_t^1 = ORPrcCeil$

If  $InitP10NRef_t^1 < ORPrcFlr$ , set  $P10NRef_t^1 = ORPrcFlr$

Otherwise, set  $P10NRef_t^1 = InitP10NRef_t^1$

If  $InitP10SRef_t^1, ORPrcFlr > ORPrcCeil$ , set  $10SRef_t^1 = ORPrcCeil$

If  $InitP10SRef_t^1, ORPrcFlr < ORPrcFlr$ , set  $10SRef_t^1 = ORPrcFlr$

Otherwise, set  $10SRef_t^1 = InitP10SRef_t^1$

- 16.4.1.4 If the initial *locational marginal price* ( $InitL30RP_{t,b}^1$ ,  $InitL10NP_{t,b}^1$ , or  $InitL10SP_{t,b}^1$ ) is not within the *settlement bounds* ( $ORPrcFlr$ ,  $ORPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the *locational marginal price* for each class of *operating reserve* as follows:

If  $InitL30RP_{t,b}^1 > ORPrcCeil$ , set  $L30RP_{t,b}^1 = ORPrcCeil$ ;

If  $InitL30RP_{t,b}^1 < ORPrcFlr$ , set  $L30RP_{t,b}^1 = ORPrcFlr$ ;

Otherwise, set  $L30RP_{t,b}^1 = InitL30RP_{t,b}^1$ .

If  $InitL10NP_{t,b}^1 > ORPrcCeil$ , set  $L10NP_{t,b}^1 = ORPrcCeil$ ;

If  $InitL10NP_{t,b}^1 < ORPrcFlr$ , set  $L10NP_{t,b}^1 = ORPrcFlr$ ;

Otherwise, set  $L10NP_{t,b}^1 = InitL10NP_{t,b}^1$ .

If  $InitL10SP_{t,b}^1 > ORPrcCeil$ , set  $L10SP_{t,b}^1 = ORPrcCeil$ ;

If  $InitL10SP_{t,b}^1 < ORPrcFlr$ , set  $L10SP_{t,b}^1 = ORPrcFlr$ ;

Otherwise, set  $L10SP_{t,b}^1 = InitL10SP_{t,b}^1$ .

- 16.4.1.5 If the initial *locational marginal price* ( $InitL30RP_{t,b}^1$ ,  $InitL10NP_{t,b}^1$ , or  $InitL10SP_{t,b}^1$ ) is not within the *settlement bounds* ( $ORPrcFlr$ ,  $ORPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the congestion component for each class of *operating reserve* as follows:

Set  $P30RCong_{t,b}^1 = L30RP_{t,b}^1 - P30RRef_t^1$ ;

Set  $P10NCong_{t,b}^1 = L10NP_{t,b}^1 - P10NRef_t^1$ ; and

Set  $P10SCong_{t,b}^1 = L10SP_{t,b}^1 - P10SRef_t^1$ .

- 16.4.1.6 Operating Reserve Locational Marginal Prices for Intertie Metering Points

- 16.4.1.7 The *pre-dispatch calculation engine* shall calculate a *locational marginal price* and components for *operating reserve* for Pass 1 and each time-step  $t \in TS$  for *intertie zone bus*  $d \in D$ , where:

16.4.1.7.1  $ExtL30RP_{t,d}^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *thirty-minute operating reserve*;

16.4.1.7.2  $P30RRef_t^1$  designates the Pass 1 time-step  $t$  *locational marginal price* for *thirty-minute operating reserve* at the *reference bus*;

16.4.1.7.3  $P30RIntCong_{t,d}^1$  designates the Pass 1 time-step  $t$  *internal congestion component* for *thirty-minute operating reserve*;

16.4.1.7.4  $P30RExtCong_{t,d}^1$  designates the Pass 1 time-step  $t$  *intertie congestion component* for *thirty-minute operating reserve*;

- 16.4.1.7.5  $ExtL10NP_{t,d}^1$  designates the Pass 1 time-step  $t$  locational marginal price for non-synchronized *ten-minute operating reserve*;
- 16.4.1.7.6  $P10NRef_t^1$  designates the Pass 1 time-step  $t$  locational marginal price for non-synchronized *ten-minute operating reserve* at the *reference bus*;
- 16.4.1.7.7  $P10NIntCong_{t,d}^1$  designates the Pass 1 time-step  $t$  internal congestion component for non-synchronized *ten-minute operating reserve*;
- 16.4.1.7.8  $P10NExtCong_{t,d}^1$  designates the Pass 1 time-step  $t$  external congestion component for non-synchronized *ten-minute operating reserve*; and
- 16.4.1.7.9  $ORREG_d \subseteq ORREG$  as the subset of  $ORREG$  consisting of regions that include bus  $d$ .

16.4.1.8 The *pre-dispatch calculation engine* shall calculate initial *locational marginal price*, *locational marginal price at the reference bus*, internal congestion component and external congestion component for Pass 1 at *intertie zone bus*  $d \in D_a$  in *intertie zone*  $a \in A$  in time-step  $t \in TS$ , for each class of *operating reserve*, subject to sections 16.4.1.11 and 16.4.1.12, as follows:

$$InitExtL30RP_{t,d}^1 = InitP30RRef_t^1 + InitP30RIntCong_{t,d}^1 + InitP30RExtCong_{t,d}^1$$

where:

$$InitP30RRef_t^1 = SP30R_t^1;$$

$$InitP30RIntCong_{t,d}^1 = \sum_{r \in ORREG_d} SPREGMin30R_{t,r}^1 + \sum_{r \in ORREG_d} SPREGMax30R_{t,r}^1;$$

and

$$InitP30RExtCong_{t,d}^1 = \sum_{z \in Z_{Sch}} 0.5 \cdot (EnCoeff_{a,z} + 1) \cdot SPExtT_{t,z}^1.$$



$$InitExtL10NP_{t,d}^1 = InitP10NRef_t^1 + InitP10NIntCong_{t,d}^1 + InitP10NExtCong_{t,d}^1$$

where:

$$InitP10NRef_t^1 = SP10R_t^1 + SP30R_t^1;$$

$$InitP10NIntCong_{t,d}^1 = \sum_{r \in ORREG_d} (SPREGMin10R_{r,t}^1 + SPREGMin30R_{r,t}^1) + \sum_{r \in ORREG_d} (SPREGMax10R_{r,t}^1 + SPREGMax30R_{r,t}^1);$$

and

$$InitP10NExtCong_{t,d}^1 = \sum_{z \in Z_{Sch}} 0.5 \cdot (EnCoeff_{a,z} + 1) \cdot SPExtT_{t,z}^1$$

- 16.4.1.9 If the initial *locational marginal price* ( $InitExtL30RP_{t,b}^1$ ) is not within the *settlement bounds* ( $ORPrcFlr$ ,  $ORPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the *locational marginal price*, the *locational marginal price at the reference bus*, and the external congestion component for *thirty-minute operating reserve* as follows:

$$IntL30R = InitP30RRef_t^1 + InitP30RIntCong_{t,d}^1;$$

If  $InitP30RRef_t^1 > ORPrcCeil$ , set  $P30RRef_t^1 = ORPrcCeil$ ;

If  $InitP30RRef_t^1 < ORPrcFlr$ , set  $P30RRef_t^1 = ORPrcFlr$ ;

Otherwise, set  $P30RRef_t^1 = InitP30RRef_t^1$ ;

Set  $P30RIntCong_{t,d}^1 = ExtL30RP_{t,b}^1 - P30RRef_t^1$ ;

If  $InitExtL30RP_{t,b}^1 > ORPrcCeil$ , set  $ExtL30RP_{t,b}^1 = ORPrcCeil$ ;

If  $InitExtL30RP_{t,b}^1 < ORPrcFlr$ , set  $ExtL30RP_{t,b}^1 = ORPrcFlr$ ;

Otherwise,  $ExtL30RP_{t,b}^1 = InitExtL30RP_{t,b}^1$ ; and

Set  $P30RExtCong_{t,d}^1 = ExtL30RP_{t,b}^1 - P30RRef_t^1 - P30RIntCong_{t,d}^1$

- 16.4.1.10 If the initial *locational marginal price* ( $InitExtL10NP_{t,b}^1$ ) is not within the *settlement bounds* ( $ORPrcFlr$ ,  $ORPrcCeil$ ), then the *pre-dispatch calculation engine* shall modify the *initial locational marginal price*, *locational marginal price at the reference bus*, and the external congestion component for *ten-minute operating reserve* as follows:

$$IntL10N = InitP10NRef_t^1 + InitP10NIntCong_{t,d}^1;$$

If  $InitP10NRef_t^1 > ORPrcCeil$ , set  $P10NRef_t^1 = ORPrcCeil$ ;

If  $InitP10NRef_t^1 < ORPrCFlr$ , set  $P10NRef_t^1 = ORPrCFlr$ ;

Otherwise,  $P10NRef_t^1 = InitP10NRef_t^1$ ; and

Set  $P10NIntCong_{t,d}^1 = L10NP_{t,b}^1 - P10NRef_t^1$ ;

If  $InitExtL10NP_{t,b}^1 > ORPrCCeil$ , set  $ExtL10NP_{t,b}^1 = ORPrCCeil$ ;

If  $InitExtL10NP_{t,b}^1 < ORPrCFlr$ , set  $ExtL10NP_{t,b}^1 = ORPrCFlr$ ;

Otherwise,  $ExtL30RP_{t,b}^1 = InitExtL10NP_{t,b}^1$ ; and

Set  $P10NExtCong_{t,d}^1 = ExtL10NP_{t,b}^1 - P10NRef_t^1 - P10NIntCong_{t,d}^1$

- 16.4.1.11 The *locational marginal price* calculated by the *pre-dispatch calculation engine* shall be the same for all *boundary entity resource* buses at the same *intertie zone*. Reserve imports associated with the same *boundary entity resource* bus, but specified as occurring at a different *intertie zone*, subject to phase shifter operation, shall be modelled as flowing across independent paths. Pricing of these reserve imports shall utilize shadow prices associated with *intertie* limits and regional minimum and maximum *operating reserve* requirements applicable to the path associated to the relevant *intertie zone*.
- 16.4.1.12 When an *intertie zone* is out-of-service, the *intertie* limits for that *intertie zone* will be set to zero and all *boundary entity resources* for that *intertie zone* will receive a zero schedule for *energy* and *operating reserve* and the *intertie operating reserve* prices shall be set equal to the *locational marginal price* for the *reference bus* for that class of *operating reserve* plus the applicable shadow prices associated with regional minimum and maximum *operating reserve* requirements.

## 16.5 Pricing for Islanded Nodes

- 16.5.1 For *non-quick start resources* that are not connected to the *main island*, the *pre-dispatch calculation engine* may use the following reconnection logic where enabled by the *IESO* in the order set out below to calculate the *locational marginal prices* for *energy*:
- 16.5.1.1 Determine the connection paths over open switches that connect the *non-quick start resource* to the *main island*;
- 16.5.1.2 Determine the priority rating for each connection path identified based on a weighted sum of the base voltage over all open switches used by the

reconnection path and the MW ratings of the newly connected branches;  
and

16.5.1.3 Select the reconnection path with the highest priority rating, breaking ties arbitrarily.

16.5.2 For all (i) *resources* other than those specified in section 16.5.1 not connected to the *main island*; (ii) *non-quick start resources* where a price was not able to be determined in accordance with section 16.5.1; the *pre-dispatch calculation engine* shall use the following logic in the order set out below to calculate *locational marginal prices for energy*, using a node-level and *facility*-level substitution list determined by the *IESO*:

16.5.2.1 Use the *locational marginal price for energy* at a node in the node-level substitution list where defined and enabled by the *IESO*, provided such node is connected to the *main island*;

16.5.2.2 If no such nodes are identified, use the average *locational marginal price for energy* of all nodes at the same voltage level within the same *facility* that are connected to the *main island*;

16.5.2.3 If no such nodes are identified, use the average *locational marginal price for energy* of all nodes within the same *facility* that are connected to the *main island*;

16.5.2.4 If no such nodes are identified, use the average *locational marginal price for energy* of all nodes from another *facility* that is connected to the *main island*, as determined by the *facility*-level substitution list where defined and enabled by the *IESO*; and

16.5.2.5 If a price is unable to be determined in accordance with sections 16.5.2.2 through 16.5.2.4, use the *locational marginal price for energy* for the *reference bus*.