

IESO Engagement

From: Ng, Jeffrey
Sent: July 19, 2021 2:46 PM
To: IESO Engagement
Cc: Leith, Dean
Subject: Regional Electricity Planning in North/East Sudbury Public Engagement - Question

Hello,

I was part of the public engagement webinar today. I had asked the question/comment:

- Any plans to bring a redundant feeder to communities to support hospital developments? CSA Z32 (health care standard) has a requirement for dual feeders (one redundant or 50%/50% capacity) to support the hospital.
- Stable power has been a concern in the community for which this development is being planned for Moosonee/Moose Factory in the WAHA area.

Thank you,
Jeffrey

Jeffrey Ng P.Eng.
Senior Associate, Electrical Engineering Lead

Mobile: [REDACTED]
Fax: [REDACTED]

Stantec Consulting Ltd.
100-401 Wellington Street West, Toronto ON M5V 1E7



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

Please consider the environment before printing this email.