

# Stakeholder Feedback and IESO Response

## Updates to IESO Monitoring Requirements: Phasor Data

Following the engagement session on June 26, 2025, the Independent Electricity System Operator (IESO) invited stakeholders to provide comments and feedback on the materials presented.

The IESO received written feedback submissions from:

Ontario Power Generation (OPG)

The presentation materials and stakeholder feedback submissions have been posted on the IESO [Updates to IESO Monitoring Requirements: Phasor Data](#) webpage.

### Specific Comments/Feedback

Feedback/Common Themes	IESO Response
<p>OPG had no concerns with the increase of the minimum required reporting rate to 60 samples/sec.</p> <p>They also stated that for future electricity storage facilities, they would take into account the installation of a PMU and any future new synchrophasor requirements will be added to the existing IESO/OPGG Implementation Plan</p>	<p>The IESO thanks OPG for their feedback.</p>