

# Ontario Enforcement Dates for PRC-030-1 IBR Standard Implementation Plan



<b>Ontario Effective Date of PRC-030-1 – October 1, 2026</b>	
<b>Enforcement Dates for Requirements R1 to R4</b>	
<b>BES Inverter Based Resources (IBRs)</b>	<b>October 1, 2026</b>
<b>Applicable non-BES IBRs (Category 2 GO/GOP)</b>	<b>January 1, 2027</b>

- Non-BES Inverter-Based Resources are those that either have or contribute to an aggregate nameplate capacity of greater than or equal to 20 MVA, connected through a system designed primarily for delivering such capacity to a common point of connection at a voltage greater than or equal to 60 kV.
- In Ontario, applicable Non-BES Inverter-Based Resources meeting Category 2 GO/GOP criteria will be subject to applicable NERC Reliability Standards, in addition to IESO connection requirements (effective May 15, 2026).