

# Feedback Form

## Regional Electricity Planning in South Georgian Bay/Muskoka – November 4, 2025

### Feedback Provided by:

Name: Morteza Mirkeshmiri

Title: Manage Stations, System Planning And Asset Optimization

Organization: InnPower

Email: [REDACTED]

Date: 2025-11-18

To promote transparency, feedback submitted will be posted on the [South Georgian Bay/Muskoka engagement webpage](#) unless otherwise requested by the sender.

The Independent Electricity System Operator (IESO) is seeking feedback on the scoping assessment report. A copy of the report and a recording of the webinar can be accessed from the [engagement web page](#).

**Please submit feedback to [engagement@ieso.ca](mailto:engagement@ieso.ca) by November 18, 2025.**

| Topic                                                                               | Feedback                                                                                                         |
|-------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------|
| What additional information should be considered as part of the Scoping Assessment? | In Figure 1 the existing 115kV corridor is missing from the map. This is connection between Holand and Barrie TS |

| Topic                                                                                                                                              | Feedback                                                                                      |
|----------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|
| What additional considerations, informed by local developments, should be taken into account for the areas identified as needing further analysis? | Section 2.1 , construct of a new 230kV/27.6kV required by 2030. It is saying 2025 in the IRRP |
| What other areas or specific considerations should be examined through regional planning?                                                          | N/A                                                                                           |

## General Comments/Feedback

Click or tap here to enter text.