

Summary of Stakeholder and Technical Panel Comments on the Impact of the Market Rule Amendment on Consumers Re: Price, Reliability, Quality of Electricity Service

This form summarizes any stakeholder comments and comments received from any *technical panel* discussions on the impact of a *market rule amendment* on the interests of consumers with respect to price and the *reliability* and quality of electricity service.

Terms and acronyms used in this Form that are italicized have the meanings ascribed thereto in Chapter 11 of the *Market Rules*.

Part 1 – Market Rule Information

Identification No.: MR-00471-R00
Title: Updates to Synchrophasor Monitoring Requirements
Date of Assessment: April 29, 2022

Part 2 – Summary of Comments

The following indicates the forum at which the comments were made and the applicable *market participant* class, if any, of the person making the comment.

Technical Panel Comments:

A Technical Panel member representing industrial consumers asked about the total cost of the initiative. As a part of the stakeholder engagement process, the IESO provided an estimated quantitative cost range analysis report for the deployment of synchrophasor measurement units for transmitters and generators in Ontario's power system.

Stakeholder Comments:

In the stakeholder engagement, generators asked for a staged implementation plan, and for requirements to be applicable only to new facilities. The IESO responded that the reliability benefits of the initiative would be greater if existing, applicable facilities were included. A staged implementation plan was introduced to ensure a smooth and successful transition for generators, transmitters and the IESO