



Market Rule Amendment Written Submission

This form is used to provide comment on a market rule amendment under consideration by the IMO. Please complete all four sections of this form and submit the completed form by email or fax to the following:

Email Address: Rule.Amendments@theIMO.com

Fax No.: (416) 506-2847 Attention: Market Rules Group

Subject: *Market Rule Written Submission*

All information submitted in this process will be used by the *IMO* solely in support of its obligations under the *Electricity Act, 1998*, the *Ontario Energy Board Act, 1998*, the *Market Rules* and associated policies, standards and procedures and its licence. All submitted information will be assigned the *confidentiality classification* of “public” upon receipt. You should be aware that the *IMO* intends to *publish* this written submission.

Terms and acronyms used in this Form that are italicized have the meanings ascribed thereto in Chapter 11 of the *Market Rules*.

PART 1 –SUBMITTER’S INFORMATION

Please enter your organization and contact information in full

Name: Hamilton Hydro Inc.	
<i>(If applicable) Market Participant / 102084 Metering Service Provider No. ¹:</i>	Market Participant Class: Distributor
Telephone: 905-317-4788	Fax: 905-523-5764
Email Address: tkarp@hamiltonhydro.com	

¹ This number is a maximum of 12 characters and does not include any spaces or underscore.

PART 2 – MARKET RULE AMENDMENT REFERENCE

Type of Rule Amendment being commented on (please indicate with X):

 Amendment Submission X *Proposed Rule Amendment* *Recommended Rule Amendment*

MR-# 00247-R00

This Market Rule number is located on the “Current Market Rule Amendment” web page.

Date relevant *Amendment Submission*, *Proposed* or *Recommended Rule Amendment* posted for comment: **May 4, 2004**

PART 3 – COMMENTS ON RULE AMENDMENT

Provide your comments.

If Hamilton Hydro’s facility is part of a Special Protection System (SPS), Hamilton Hydro’s on-duty system operator must be notified by telephone of the arming of that SPS because status annunciation of arming is not available to Hamilton Hydro Inc. Present protocol calls for the transmitter, Hydro One Networks Inc., to notify Hamilton Hydro Inc. of rotational load shedding under the Ontario Emergency Restoration Plan. Otherwise, the IMO is expected to notify Hamilton Hydro Inc.

PART 4 – EXTERNAL CONSULTATION MEETING

If you believe that a special meeting of stakeholders would be necessary/desirable to discuss the issues raised by the rule amendment, please complete the following information:

External Stakeholdering meeting necessary/desirable (please indicate with X):

Reason(s) why you believe a meeting is necessary/desirable:

In general, distributors may be unaware of their obligation to inform the IMO, through its outage management system, if their facility is unavailable for arming. A distributor may need to make its facility unavailable for arming where the arming would endanger the safety of any person, damage equipment or violate a law. Alternatively, it may need to provide notification of arming to some or all of its customers to mitigate the potential for endangering the safety of persons, damaging equipment or violating a law.